

RHYLL, Australia

WMO: **948920**

Lat: **38.4611S** Lon: **145.3100E** Elev: **46** StdP: **14.67** Time Zone: **10.00 (AUS)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	7	43.6	45.0	34.9	29.7	50.8	36.8	32.1	50.6	34.2	54.3	31.0	54.2	7.6	0	0.519	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	2	13.1	86.3	69.3	82.2	68.4	78.8	67.1	71.5	81.4	69.9	79.3	68.3	76.6	11.5	350	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	68.1	103.5	75.7	66.6	98.0	74.3	65.1	93.1	73.1	35.3	81.5	33.9	79.7	32.6	76.8	79.2	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	27.9	24.3	21.0	DB	40.2	94.6	1.5	3.7	39.2	97.3	38.3	99.4	37.4	101.5	36.3	104.2	(4)
(5)				WB	39.1	75.3	1.4	2.0	38.1	76.7	37.3	77.9	36.5	79.0	35.5	80.4	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	59.0	66.9	67.7	65.1	60.6	56.2	52.5	51.2	52.1	54.5	57.4	60.7	63.5	(6)
(7)			DBStd	7.11	5.65	5.31	5.18	4.15	3.15	2.68	2.39	2.85	3.52	4.41	5.18	5.68	(7)
(8)			HDD50	37	0	0	0	0	1	8	14	11	3	0	0	0	(8)
(9)			HDD65	2551	39	27	62	143	272	374	428	401	314	239	153	99	(9)
(10)			CDD50	3323	525	496	469	318	193	84	52	75	139	231	321	420	(10)
(11)			CDD65	362	99	103	66	11	0	0	0	0	0	5	24	54	(11)
(12)			CDH74	2087	631	562	325	30	0	0	0	0	0	31	136	372	(12)
(13)			CDH80	599	218	160	79	2	0	0	0	0	0	2	22	116	(13)
(14)	Wind		WSAvg	9.5	9.8	9.7	9.4	8.7	8.9	9.5	10.5	9.9	9.5	9.4	9.6	9.6	(14)
(15)	Precipitation		PrecAvg	31.5	1.8	2.0	1.9	2.8	2.9	3.1	3.0	3.1	3.2	2.8	2.6	2.2	(15)
(16)			PrecMax	39.2	5.3	6.0	3.1	6.9	6.3	5.8	5.5	5.3	5.9	4.8	5.9	4.7	(16)
(17)			PrecMin	21.3	0.2	0.3	0.8	0.9	1.1	0.8	1.4	0.8	1.4	0.7	0.9	0.2	(17)
(18)			PrecStd	5.0	1.1	1.3	0.6	1.4	1.3	1.3	1.1	1.2	1.2	1.2	1.2	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		93.0	90.3	87.1	77.5	68.3	61.9	60.3	64.7	71.2	78.2	82.7	88.9	(19)
(20)			MCWB		72.2	70.1	68.8	63.4	58.9	55.4	52.8	55.2	58.6	62.5	67.5	69.2	(20)
(21)		2%	DB		85.9	84.8	81.6	73.3	65.3	59.7	58.1	61.5	66.5	72.9	78.0	83.0	(21)
(22)			MCWB		69.5	69.8	67.5	62.3	57.6	54.4	52.3	53.7	56.9	61.1	65.9	68.0	(22)
(23)		5%	DB		80.8	80.8	77.3	69.9	63.2	58.1	56.5	59.0	63.5	69.1	73.6	77.7	(23)
(24)			MCWB		68.9	68.7	66.1	61.1	56.6	53.5	51.3	52.3	55.5	59.6	64.1	66.5	(24)
(25)		10%	DB		76.2	76.8	73.5	67.0	61.3	56.7	55.3	56.9	60.9	65.4	69.7	73.0	(25)
(26)			MCWB		67.5	67.4	64.9	60.0	55.9	52.6	50.7	51.2	54.3	58.2	62.3	64.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		74.2	73.2	71.5	65.6	60.5	57.4	54.9	57.0	60.3	65.0	69.8	71.5	(27)
(28)			MCDB		86.3	83.7	83.3	73.9	64.5	59.8	58.2	62.6	67.1	72.4	78.5	83.2	(28)
(29)		2%	WB		71.7	71.2	68.8	63.5	59.0	55.5	53.4	54.7	58.2	62.5	67.3	69.1	(29)
(30)			MCDB		81.1	80.8	77.9	70.0	63.1	58.0	56.2	59.4	64.6	70.6	75.1	79.3	(30)
(31)		5%	WB		69.7	69.7	67.0	62.1	57.8	54.4	52.2	53.1	56.5	60.5	65.0	67.3	(31)
(32)			MCDB		79.1	78.4	74.9	67.9	61.9	57.2	55.2	57.2	61.9	67.3	72.0	76.2	(32)
(33)		10%	WB		67.8	68.1	65.4	60.8	56.6	53.2	51.3	52.0	54.9	58.5	62.9	65.2	(33)
(34)			MCDB		76.0	75.3	72.4	66.0	60.6	56.2	54.3	55.8	60.0	64.7	69.3	72.8	(34)
(35)	Mean Daily Temperature Range		MDBR		13.3	13.1	12.0	10.3	8.0	7.4	7.5	8.9	10.4	11.7	12.3	13.0	(35)
(36)		5% DB	MCDBR		22.9	21.3	19.6	15.5	10.9	8.9	8.9	11.8	14.6	18.7	20.1	22.9	(36)
(37)			MCWBR		10.6	9.8	9.1	7.6	6.1	5.8	5.3	6.5	7.9	9.8	10.7	11.3	(37)
(38)		5% WB	MCDBR		20.3	18.1	17.3	13.7	9.7	8.3	8.2	10.6	13.1	17.2	18.2	20.3	(38)
(39)			MCWBR		10.5	9.3	8.8	7.4	6.2	5.8	5.5	6.5	8.0	10.2	10.6	11.1	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.359	0.359	0.338	0.334	0.319	0.309	0.310	0.322	0.345	0.345	0.351	0.347	(40)
(41)		taud			2.498	2.509	2.569	2.555	2.577	2.590	2.580	2.540	2.472	2.488	2.498	2.526	(41)
(42)		Ebn at Noon			308	301	295	275	260	253	261	275	287	302	309	314	(42)
(43)		Edh at Noon			36	34	30	26	22	20	22	26	32	34	36	35	(43)
(44)	All-Sky Solar Radiation	RadAvg			2230	1948	1533	1064	703	559	629	890	1276	1710	2005	2234	(44)
(45)		RadStd			134	97	84	55	36	39	26	46	77	116	108	124	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.85	N/A	N/A	+1.44	N/A	N/A	-18	-259	+371	+115	(46)
(47)	Regional (32 neighbors)	+0.90	N/A	N/A	+1.40	N/A	N/A	-29	-241	+313	+101	(47)

Nomenclature: See separate page