LAMEROO AUSTIN PLAINS, Australia

WMO: **946900**

Lat: **35.3778S** Lon: **140.5378E** Elev: **111** StdP: **100.00** Time Zone: **9.50 (AUA)** Period: **04-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	7	1.3	2.3	-5.1	2.5	25.4	-3.3	2.9	25.1	13.5	13.3	12.1	13.0	3.4	70	0.601	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	1	16.8	39.1	18.7	36.6	18.0	34.3	17.3	21.0	29.3	20.0	29.2	19.0	29.5	6.2	310	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	19.0	13.9	22.8	17.5	12.7	22.1	16.0	11.5	21.4	61.2	28.5	57.6	28.9	54.4	29.4	26.0	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	12.2	10.8	9.6	DB	-0.8	43.1	0.5	1.7	-1.2	44.4	-1.5	45.4	-1.8	46.4	-2.2	47.6	(4)
(5)				WB	-1.1	22.6	0.6	1.6	-1.5	23.8	-1.8	24.7	-2.1	25.7	-2.5	26.8	(5)

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	22.7	21.7	19.7	16.2	12.7	9.9	9.5	10.0	12.0	15.3	18.2	20.4	(6)
(7)		DBStd	5.83	4.38	4.22	4.27	3.40	2.58	1.93	1.97	2.22	2.97	3.99	4.52	4.48	(7)
(8)		HDD10.0	101	0	0	0	0	4	25	34	27	8	2	0	0	(8)
(9)		HDD18.3	1487	7	12	33	84	174	254	276	257	192	116	58	26	(9)
(10)		CDD10.0	2164	394	328	300	185	89	21	17	28	69	164	246	323	(10)
(11)		CDD18.3	509	142	106	76	18	1	0	0	0	2	20	54	91	(11)
(12)		CDH23.3	7668	2081	1457	1003	274	11	0	0	4	63	426	907	1442	(12)
(13)		CDH26.7	3983	1182	774	483	96	1	0	0	1	16	178	466	789	(13)
(14)	Wind	WSAvg	5.0	5.5	5.3	4.9	4.5	4.6	4.3	4.8	4.8	5.0	5.2	5.3	5.5	(14)
(15)	Precipitation	PrecAvg	375	18	22	17	27	36	40	43	46	41	37	28	25	(15)
(16)		PrecMax	618	82	156	96	113	88	107	83	90	109	139	68	88	(16)
(17)		PrecMin	203	0	0	0	1	3	6	9	12	11	1	0	2	(17)
(18)		PrecStd	89	17	30	18	25	22	24	21	21	21	29	18	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	42.8	40.1	38.0	33.4	24.8	19.0	18.8	23.3	28.6	34.9	38.7	41.5		(19)
(20)		0.4% MCWB	19.7	19.9	17.9	17.0	14.1	11.9	12.0	12.8	14.0	15.8	17.8	18.8		(20)
(21)		2% DB	39.8	37.0	34.6	29.2	22.2	17.0	16.4	19.8	24.9	31.3	34.9	37.8		(21)
(22)		2% MCWB	18.7	18.6	17.7	15.6	13.8	11.7	11.5	12.1	13.4	15.0	16.5	17.8		(22)
(23)		5% DB	36.5	34.6	32.1	26.5	19.7	15.6	15.0	17.1	21.7	28.2	32.1	34.5		(23)
(24)		5% MCWB	18.2	17.8	17.4	14.6	13.0	11.4	11.0	11.2	12.4	13.9	16.1	16.7		(24)
(25)		10% DB	33.3	31.7	29.0	23.6	18.0	14.4	13.7	15.3	19.1	24.9	28.9	31.2		(25)
(26)		10% MCWB	17.5	17.2	16.5	13.8	12.5	10.9	10.5	10.7	11.8	13.4	15.5	16.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	22.3	22.6	20.7	18.3	16.2	14.4	13.5	14.1	15.5	18.1	20.1	21.5		(27)
(28)		0.4% MCDB	28.7	33.5	27.1	24.4	21.0	16.0	16.0	19.5	22.8	27.1	28.3	30.9		(28)
(29)		2% WB	21.1	20.8	19.5	17.1	14.9	12.9	12.5	12.8	14.3	16.5	18.8	19.6		(29)
(30)		2% MCDB	29.3	28.8	27.8	24.3	19.3	15.7	15.0	18.0	21.5	25.3	28.1	28.6		(30)
(31)		5% WB	20.0	19.6	18.5	16.0	14.0	12.0	11.7	11.9	13.4	15.3	17.7	18.4		(31)
(32)		5% MCDB	31.3	28.3	28.0	23.0	17.7	14.7	14.3	15.8	20.1	24.6	28.3	29.4		(32)
(33)		10% WB	18.8	18.5	17.6	15.0	13.3	11.3	10.9	11.1	12.4	14.3	16.5	17.3		(33)
(34)		10% MCDB	30.9	28.8	27.3	21.8	16.8	13.8	13.3	14.8	18.1	23.1	25.8	28.2		(34)
(35)	Mean Daily Temperature Range	MDBR	16.8	16.0	14.6	13.3	10.4	9.6	9.1	10.8	13.2	15.9	16.0	16.3		(35)
(36)		5% DB MCDBR	21.0	19.6	18.1	17.4	13.3	11.1	10.5	14.4	18.4	20.9	21.0	21.5		(36)
(37)		5% DB MCWBR	6.6	6.3	6.2	7.0	6.4	6.6	6.6	7.9	8.4	8.1	6.9	7.0		(37)
(38)		5% WB MCDBR	15.5	15.2	14.3	14.1	10.6	9.5	9.1	11.8	15.3	16.9	16.8	15.9		(38)
(39)		5% WB MCWBR	6.2	5.6	5.8	6.2	5.8	6.1	6.2	7.2	7.7	7.4	6.3	6.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.333	0.316	0.308	0.297	0.290	0.292	0.301	0.328	0.336	0.340	0.329		(40)
(41)		taud	2.477	2.517	2.553	2.560	2.574	2.586	2.575	2.534	2.452	2.440	2.458	2.507		(41)
(42)		Ebn at Noon	995	981	961	912	867	847	864	905	932	967	989	1010		(42)
(43)		Edh at Noon	116	107	96	84	73	67	71	85	104	115	118	114		(43)
(44)	All-Sky Solar Radiation	RadAvg	7.80	6.92	5.62	4.06	2.77	2.29	2.46	3.37	4.57	6.00	7.02	7.63		(44)
(45)		RadStd	0.38	0.35	0.27	0.21	0.14	0.14	0.10	0.19	0.37	0.41	0.36	0.29		(45)

Note: rows (19)–(45) have no Annual value; their values run from Jan to Dec.

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (25 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	-90	+154	+69	(47)

Nomenclature: See separate page