MERAUKE MOPAH, Indonesia

WMO: **979800**

Lat: **8.5183S** Lon: **140.4140E** Elev: **3** StdP: **101.29** Time Zone: **9.00 (E09)** Period: **05-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	8	20.7	21.5	18.2	13.1	24.3	18.8	13.7	24.2	10.0	27.6	9.1	27.7	1.2	120	0.353	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	12	6.5	32.7	26.2	32.2	26.2	31.8	26.1	27.4	30.9	27.1	30.7	26.8	30.4	3.9	100	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	26.4	21.9	29.3	26.1	21.5	29.1	25.8	21.1	28.8	86.8	31.2	85.5	31.0	84.4	30.7	31.7	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	8.5	7.5	6.4	DB	19.3	34.4	1.0	0.5	18.6	34.7	18.0	35.0	17.5	35.2	16.7	35.6	(4)
(5)				WB	18.4	28.5	1.0	1.1	17.7	29.3	17.1	29.9	16.5	30.5	15.8	31.3	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	27.1	27.8	27.8	27.7	27.7	27.2	26.3	25.6	25.5	26.1	27.2	28.0	28.3	(6)
(7)			DBStd	1.33	0.95	0.91	0.86	0.85	0.88	0.95	0.97	1.03	1.09	1.05	0.74	0.88	(7)
(8)			HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)			HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)			CDD10.0	6236	552	498	547	531	533	489	484	479	482	532	541	567	(10)
(11)			CDD18.3	3194	294	265	289	281	275	239	226	221	232	274	291	309	(11)
(12)			CDH23.3	31499	3126	2801	2991	2943	2679	1999	1622	1647	2036	2815	3291	3551	(12)
(13)			CDH26.7	9464	1062	920	929	924	721	368	249	282	491	913	1233	1372	(13)
(14)	Wind		WSAvg	2.8	2.6	2.5	2.3	2.1	2.7	3.0	3.2	3.4	3.4	3.1	2.7	2.2	(14)
(15)	Precipitation		PrecAvg	1302	234	241	254	159	98	33	24	22	35	33	58	177	(15)
(16)			PrecMax	2047	461	503	606	511	362	89	94	93	135	117	200	554	(16)
(17)			PrecMin	507	50	18	34	8	7	1	1	0	0	0	0	39	(17)
(18)			PrecStd	348	111	119	134	119	86	25	24	24	37	37	66	116	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		33.0	32.5	32.5	32.6	32.2	31.1	30.6	30.7	31.7	33.0	33.1	33.4	(19)
(20)			MCWB		26.6	26.7	26.4	26.0	26.1	25.4	24.3	23.7	24.6	25.4	26.1	26.4	(20)
(21)		2%	DB		32.2	31.7	31.7	31.7	31.2	30.1	29.5	29.6	30.5	31.8	32.2	32.6	(21)
(22)			MCWB		26.6	26.4	26.3	25.9	25.8	25.3	24.2	24.1	25.0	25.5	26.2	26.4	(22)
(23)		5%	DB		31.6	31.3	31.1	31.1	30.5	29.3	28.7	28.8	29.7	30.9	31.7	32.1	(23)
(24)			MCWB		26.4	26.3	26.2	25.9	25.7	25.1	24.1	24.1	24.8	25.5	26.0	26.3	(24)
(25)		10%	DB		30.9	30.7	30.4	30.5	29.8	28.6	28.1	28.2	29.0	30.3	31.2	31.5	(25)
(26)			MCWB		26.2	26.2	26.1	25.9	25.6	24.9	24.0	23.9	24.5	25.3	25.8	26.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		27.6	27.5	27.6	27.5	27.4	26.7	26.0	26.0	26.7	27.0	27.6	27.6	(27)
(28)			MCDB		31.4	31.2	30.7	30.6	30.3	29.2	28.5	28.9	29.8	30.7	31.5	31.6	(28)
(29)		2%	WB		27.1	27.1	27.1	27.0	26.7	26.1	25.3	25.3	26.0	26.4	27.0	27.1	(29)
(30)			MCDB		31.1	30.7	30.2	30.3	29.7	28.7	28.0	28.1	29.3	30.3	31.0	31.3	(30)
(31)		5%	WB		26.7	26.7	26.7	26.6	26.3	25.7	24.9	24.8	25.4	26.1	26.6	26.8	(31)
(32)			MCDB		30.5	30.2	29.8	29.7	29.3	28.3	27.6	27.6	28.6	30.0	30.6	30.8	(32)
(33)		10%	WB		26.4	26.4	26.4	26.3	26.0	25.3	24.5	24.4	24.9	25.6	26.2	26.5	(33)
(34)			MCDB		30.0	29.7	29.4	29.2	28.9	27.8	27.1	27.2	28.0	29.4	30.1	30.4	(34)
(35)	Mean Daily Temperature Range		MDBR		6.1	5.9	5.8	5.9	5.6	5.1	5.5	6.1	6.6	6.8	6.8	6.5	(35)
(36)		5% DB	MCDBR		7.1	6.6	6.6	6.9	6.6	5.9	6.4	6.9	7.3	7.5	7.4	7.4	(36)
(37)			MCWBR		2.7	2.5	2.4	2.4	2.5	2.3	2.6	2.9	3.2	3.0	2.8	2.8	(37)
(38)		5% WB	MCDBR		6.6	6.3	6.1	6.0	5.7	5.2	5.1	5.5	6.3	6.8	6.8	6.8	(38)
(39)			MCWBR		2.8	2.6	2.5	2.4	2.5	2.3	2.5	2.7	3.0	3.0	2.9	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.418	0.414	0.406	0.421	0.432	0.428	0.421	0.426	0.440	0.466	0.462	0.445	(40)
(41)		taud			2.495	2.502	2.531	2.481	2.438	2.446	2.465	2.443	2.398	2.296	2.320	2.394	(41)
(42)		Ebn at Noon			923	923	916	873	834	823	837	857	872	866	876	895	(42)
(43)		Edh at Noon			115	114	109	110	109	106	105	113	123	139	136	127	(43)
(44)	All-Sky Solar Radiation	RadAvg			5.13	5.21	5.03	4.90	4.61	4.17	4.29	4.92	5.56	6.07	5.96	5.47	(44)
(45)		RadStd			0.38	0.43	0.27	0.42	0.35	0.30	0.27	0.46	0.46	0.43	0.41	0.46	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page