 © 2021 ASHRAE, Inc.

DOUBLE ISLAND POINT, Australia

WMO: **945840**

Lat: **25.9319S** Lon: **153.1906E** Elev: **96** StdP: **100.18** Time Zone: **10.00 (E10)** Period: **95-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	7	11.8	13.2	-1.6	3.3	15.6	0.6	4.0	15.3	19.6	16.8	18.0	17.3	6.6	230	0.620	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	1	5.4	31.0	24.3	30.0	23.8	29.1	23.2	25.8	28.7	25.2	28.0	24.6	27.4	4.8	0	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	25.1	20.4	27.2	24.3	19.5	26.8	23.7	18.8	26.5	80.4	28.9	77.6	28.1	75.1	27.4	29.0	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	18.0	15.8	14.4	DB	9.6	33.6	1.4	1.4	8.6	34.7	7.8	35.5	7.0	36.3	6.0	37.4	(4)
(5)				WB	4.9	27.1	1.2	0.9	4.1	27.7	3.4	28.3	2.7	28.7	1.9	29.4	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	22.0	25.9	25.7	24.9	22.8	20.2	18.2	17.4	18.4	20.5	22.0	23.6	25.0	(6)
(7)			DBStd	3.42	1.57	1.56	1.43	1.60	1.87	2.05	1.90	1.97	1.82	1.67	1.74	1.76	(7)
(8)			HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)			HDD18.3	101	0	0	0	0	6	27	40	24	4	1	0	0	(9)
(10)			CDD10.0	4388	493	439	461	386	315	246	231	259	314	373	409	463	(10)
(11)			CDD18.3	1447	234	206	202	136	62	22	12	25	68	115	159	205	(11)
(12)			CDH23.3	6741	1650	1396	1049	319	51	8	4	22	109	285	646	1202	(12)
(13)			CDH26.7	1193	364	263	147	25	2	0	0	0	6	26	105	256	(13)
(14)	Wind		WSAvg	7.5	7.7	8.7	8.7	8.5	7.3	7.5	7.2	7.0	6.9	6.9	6.6	7.2	(14)
(15)	Precipitation		PrecAvg	1569	193	185	174	146	167	131	107	70	43	88	118	145	(15)
(16)			PrecMax	2489	721	615	615	345	435	582	676	250	122	267	281	266	(16)
(17)			PrecMin	756	30	23	19	33	39	31	13	1	0	1	20	14	(17)
(18)			PrecStd	395	149	136	121	84	98	114	114	52	34	68	69	66	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		32.2	32.1	31.1	29.0	26.3	24.3	24.0	25.4	27.5	28.8	30.4	31.7	(19)
(20)			MCWB		25.0	25.2	24.4	22.2	20.2	19.4	18.2	18.3	20.5	21.6	22.9	24.3	(20)
(21)		2%	DB		30.9	30.6	29.4	27.2	24.7	22.8	22.3	23.8	25.8	27.2	29.0	30.4	(21)
(22)			MCWB		24.4	24.5	23.7	21.5	19.4	18.3	17.1	17.5	19.5	20.8	22.2	23.7	(22)
(23)		5%	DB		29.8	29.4	28.3	26.1	23.5	21.6	21.0	22.5	24.6	26.0	27.8	29.2	(23)
(24)			MCWB		23.8	23.9	22.9	20.8	18.8	17.5	16.2	16.8	18.7	20.3	21.6	23.0	(24)
(25)		10%	DB		28.8	28.3	27.2	25.1	22.6	20.7	20.0	21.2	23.4	24.9	26.8	28.1	(25)
(26)			MCWB		23.3	23.3	22.3	20.4	18.4	17.1	16.0	16.2	18.0	19.5	20.9	22.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		27.1	26.5	26.3	24.4	22.1	20.8	19.9	20.1	21.7	23.4	24.1	25.7	(27)
(28)			MCDB		30.4	30.2	28.1	26.5	23.7	23.0	21.9	23.6	25.8	26.8	28.7	29.8	(28)
(29)		2%	WB		25.8	25.5	25.4	22.7	21.2	19.5	18.6	19.0	20.7	22.4	23.2	25.0	(29)
(30)			MCDB		28.8	28.7	27.3	25.4	23.0	21.3	20.5	21.9	24.2	25.2	27.3	28.5	(30)
(31)		5%	WB		25.1	24.8	24.5	21.9	20.3	18.8	17.6	18.2	20.0	21.6	22.5	24.3	(31)
(32)			MCDB		27.9	27.8	26.7	24.5	22.3	20.8	19.9	20.8	23.1	24.3	26.2	27.4	(32)
(33)		10%	WB		24.4	24.2	23.6	21.2	19.5	18.0	16.9	17.5	19.2	20.8	21.9	23.6	(33)
(34)			MCDB		27.2	27.0	26.1	23.9	21.7	20.1	19.3	20.1	22.1	23.6	25.2	26.6	(34)
(35)	Mean Daily Temperature Range		MDBR		5.4	4.9	4.8	4.3	4.4	4.3	4.8	5.6	5.9	5.9	6.0	5.8	(35)
(36)		5% DB	MCDBR		6.8	6.6	6.3	5.7	5.4	5.2	6.2	7.3	7.6	7.5	7.4	7.4	(36)
(37)			MCWBR		3.2	3.0	3.0	3.0	3.3	3.5	4.0	4.2	3.9	3.8	3.4	3.4	(37)
(38)		5% WB	MCDBR		6.5	6.0	6.0	5.1	4.7	4.7	5.2	6.4	6.9	6.8	7.0	7.0	(38)
(39)			MCWBR		3.4	3.0	3.2	3.1	3.2	3.5	3.8	3.8	3.8	3.7	3.6	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.387	0.380	0.364	0.341	0.321	0.315	0.305	0.318	0.350	0.372	0.375	0.385	(40)
(41)		taud			2.532	2.560	2.601	2.650	2.656	2.665	2.676	2.622	2.525	2.494	2.518	2.522	(41)
(42)		Ebn at Noon			956	948	935	914	891	876	900	924	934	945	962	960	(42)
(43)		Edh at Noon			112	106	97	85	77	73	74	85	103	112	113	113	(43)
(44)	All-Sky Solar Radiation	RadAvg			6.68	6.10	5.28	4.54	3.76	3.19	3.66	4.56	5.62	6.22	6.82	6.77	(44)
(45)		RadStd			0.52	0.51	0.38	0.29	0.20	0.24	0.32	0.35	0.40	0.49	0.56	0.72	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (19 neighbors)	+0.35	+0.59	N/A	N/A	N/A	N/A	N/A	-71	+189	+113	(47)

Nomenclature: See separate page