ASELE, Sweden

WMO: **022540**

Lat: **64.165N** Lon: **17.315E** Elev: **1010** StdP: **14.17** Time Zone: **1.00 (EUC)** Period: **01-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	-24.8	-18.5	-30.7	1.0	-24.7	-23.6	1.5	-18.3	16.1	33.0	13.9	31.8	0.1	110	0.656	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	7	21.9	77.7	61.8	74.1	60.6	70.7	58.7	64.7	73.6	62.4	71.0	60.3	67.8	4.9	210	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	61.3	84.2	67.5	59.1	77.5	65.2	56.9	71.6	63.6	30.2	73.3	28.5	71.0	27.1	67.8	72.7	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	14.0	11.9	10.1	DB	-30.2	81.6	5.5	3.8	-34.1	84.3	-37.3	86.5	-40.4	88.7	-44.4	91.4	(4)
(5)				WB	-30.6	67.6	5.3	2.8	-34.4	69.6	-37.5	71.2	-40.4	72.8	-44.3	74.8	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	34.2	12.1	13.7	21.9	33.3	43.9	52.0	57.6	53.8	45.4	34.0	24.5	16.9	(6)
(7)			DBStd	18.19	14.12	13.57	10.72	6.54	6.66	6.08	5.47	5.45	5.69	7.55	10.01	13.70	(7)
(8)			HDD50	6291	1174	1016	870	501	212	45	4	24	159	496	765	1025	(8)
(9)			HDD65	11244	1639	1436	1335	951	653	390	237	349	589	960	1215	1490	(9)
(10)			CDD50	533	0	0	0	0	24	106	240	142	20	1	0	0	(10)
(11)			CDD65	10	0	0	0	0	0	1	7	2	0	0	0	0	(11)
(12)			CDH74	316	0	0	0	0	10	76	191	39	0	0	0	0	(12)
(13)			CDH80	36	0	0	0	0	0	5	30	1	0	0	0	0	(13)
(14)	Wind		WSAvg	3.9	3.1	3.3	4.5	4.3	4.9	5.1	4.1	3.6	4.0	3.9	3.3	3.2	(14)
(15)	Precipitation		PrecAvg	23.9	1.8	1.2	1.1	1.2	1.7	2.5	3.5	3.3	2.1	2.0	1.9	1.7	(15)
(16)			PrecMax	32.4	3.4	2.6	2.3	2.6	2.9	4.7	6.8	6.6	5.6	5.4	3.9	3.1	(16)
(17)			PrecMin	16.5	0.2	0.1	0.6	0.2	0.4	0.6	0.9	0.9	0.5	0.7	0.8	0.2	(17)
(18)			PrecStd	4.1	0.7	0.6	0.4	0.6	0.8	1.1	1.5	1.8	1.2	1.0	1.0	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		40.4	41.5	45.8	62.9	75.5	80.5	83.8	78.3	66.5	55.7	47.5	40.5	(19)
(20)			MCWB		37.3	37.9	39.3	48.0	56.6	60.7	65.5	63.9	57.2	49.9	45.7	38.2	(20)
(21)		2%	DB		36.9	39.0	42.0	54.5	70.0	76.0	78.8	74.3	62.1	50.2	42.1	37.7	(21)
(22)			MCWB		35.1	35.8	36.8	43.8	54.3	58.7	63.3	62.1	55.3	47.2	40.7	35.7	(22)
(23)		5%	DB		33.8	35.3	39.6	50.0	65.3	70.6	75.3	70.5	58.7	47.9	38.7	35.6	(23)
(24)			MCWB		32.3	33.2	35.4	41.2	52.3	57.0	62.3	60.2	53.2	45.5	37.5	34.4	(24)
(25)		10%	DB		31.3	32.1	37.1	45.8	59.9	66.5	71.8	66.2	56.0	45.7	36.4	33.5	(25)
(26)			MCWB		30.6	30.6	33.6	39.0	49.1	54.7	60.4	58.3	51.7	43.6	35.4	32.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		37.8	38.2	40.2	48.6	58.9	63.8	68.2	66.4	59.1	50.3	45.8	38.6	(27)
(28)			MCDB		40.1	40.8	45.7	60.7	70.2	76.0	77.4	75.0	63.6	53.2	47.5	40.1	(28)
(29)		2%	WB		35.3	36.0	37.6	45.1	56.1	60.3	65.7	63.6	56.3	47.9	41.0	36.0	(29)
(30)			MCDB		36.8	38.6	41.1	53.6	67.7	71.2	74.2	70.9	60.5	49.6	42.0	37.2	(30)
(31)		5%	WB		32.6	33.4	35.8	42.0	53.0	58.0	63.7	61.2	54.4	45.9	37.9	34.4	(31)
(32)			MCDB		33.6	35.0	39.0	48.5	63.8	67.9	72.7	67.9	57.9	47.6	38.6	35.3	(32)
(33)		10%	WB		30.4	30.5	34.0	39.5	49.8	55.7	61.6	59.2	52.6	43.7	35.6	32.6	(33)
(34)			MCDB		31.3	31.8	36.7	45.2	58.6	64.7	69.9	65.3	55.5	45.6	36.4	33.4	(34)
(35)	Mean Daily Temperature Range		MDBR		16.6	18.6	20.9	19.4	21.7	21.1	21.9	20.3	17.4	13.0	11.1	14.5	(35)
(36)		5% DB	MCDBR		15.4	14.9	18.6	27.8	33.2	29.6	29.2	28.4	22.3	15.6	10.2	13.5	(36)
(37)			MCWBR		14.5	13.0	14.0	17.8	18.6	14.6	15.3	16.9	15.6	12.6	9.3	12.7	(37)
(38)		5% WB	MCDBR		15.6	14.3	17.3	25.0	30.8	26.7	25.4	24.6	19.6	14.3	9.7	13.4	(38)
(39)			MCWBR		14.9	12.8	13.6	16.4	18.0	14.0	14.4	15.2	14.4	12.1	9.0	12.7	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.196	0.265	0.292	0.328	0.333	0.332	0.345	0.333	0.305	0.288	0.345	0.351	(40)
(41)		taud			1.993	2.206	2.268	2.339	2.475	2.501	2.479	2.502	2.568	2.455	2.758	2.758	(41)
(42)		Ebn at Noon			123	208	253	270	279	281	274	267	254	205	117	66	(42)
(43)		Edh at Noon			8	18	26	31	30	30	30	26	20	15	7	5	(43)
(44)	All-Sky Solar Radiation	RadAvg			47	236	682	1214	1499	1683	1537	1157	676	283	70	19	(44)
(45)		RadStd			4	36	72	98	176	127	170	115	80	46	14	2	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-241	N/A	N/A	N/A	(47)

Nomenclature: See separate page