IRBID, Jordan

WMO: **402550**

Lat: **32.550N** Lon: **35.850E** Elev: **2031** StdP: **13.65** Time Zone: **2.00 (JOR)** Period: **94-19** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	1	35.2	38.1	18.4	14.9	52.4	22.6	18.3	54.4	21.0	47.4	18.9	48.4	3.8	130	0.371	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	8	18.6	94.6	67.0	91.6	66.9	89.4	66.7	74.0	84.0	72.5	81.8	71.3	80.2	7.0	290	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	71.4	125.2	77.7	70.0	119.2	76.1	68.8	114.1	75.0	39.2	84.1	37.7	81.5	36.5	80.9	82.0	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	18.6	16.3	14.2	DB	30.9	101.7	1.6	3.2	29.7	104.0	28.7	105.9	27.8	107.7	26.6	110.1	(4)
(5)				WB	28.8	75.5	2.5	2.4	27.0	77.3	25.5	78.7	24.1	80.1	22.3	81.8	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours		DBAvg	65.1	48.4	51.0	56.1	62.7	71.2	75.5	78.4	79.0	76.2	70.1	60.0	52.2	(6)
(7)			DBStd	12.13	4.94	5.24	6.56	7.91	6.47	4.74	3.26	3.33	3.81	5.44	5.42	5.33	(7)
(8)			HDD50	188	88	44	14	4	0	0	0	0	0	0	3	35	(8)
(9)			HDD65	1931	516	394	289	137	15	0	0	0	0	16	166	398	(9)
(10)			CDD50	5710	38	71	202	384	657	764	880	900	786	623	302	103	(10)
(11)			CDD65	1977	0	1	13	67	206	314	415	435	336	174	15	1	(11)
(12)			CDH74	16202	0	4	89	634	1914	2745	3514	3665	2483	1076	74	4	(12)
(13)			CDH80	6100	0	0	17	200	743	1072	1380	1494	876	313	5	0	(13)
(14)	Wind		WSAvg	5.3	4.5	4.7	5.5	5.4	5.4	7.0	7.8	7.1	5.7	3.6	3.3	3.8	(14)
(15)	Precipitation		PrecAvg	19.0	3.9	3.6	3.5	1.0	0.2	0.0	0.0	0.0	0.0	0.6	2.0	3.7	(15)
(16)			PrecMax	26.6	10.6	9.7	8.5	7.6	1.5	0.7	0.0	0.0	0.3	2.0	8.4	9.9	(16)
(17)			PrecMin	10.5	0.7	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	(17)
(18)			PrecStd	4.0	2.2	2.2	1.8	1.3	0.4	0.1	0.0	0.0	0.1	0.6	1.8	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		66.9	73.3	81.3	90.7	97.7	96.5	96.3	98.1	97.0	91.7	80.7	72.6	(19)
(20)			MCWB		51.8	55.8	62.6	63.6	65.2	65.5	69.9	68.6	66.0	65.2	61.0	56.7	(20)
(21)		2%	DB		62.4	67.7	75.7	85.3	91.7	92.9	91.7	92.3	91.4	87.0	76.7	67.1	(21)
(22)			MCWB		50.0	53.7	56.7	61.0	63.3	66.8	68.7	69.2	65.8	64.3	59.1	53.6	(22)
(23)		5%	DB		59.2	63.3	71.7	80.9	87.6	89.2	89.3	89.7	87.6	83.3	73.0	63.2	(23)
(24)			MCWB		49.0	50.9	55.0	59.3	62.5	65.7	67.7	69.2	65.9	63.5	57.5	51.6	(24)
(25)		10%	DB		56.5	59.9	67.7	76.9	83.7	86.1	87.2	87.4	84.7	80.0	69.8	60.2	(25)
(26)			MCWB		48.5	49.5	53.0	57.3	61.7	65.0	67.3	68.4	66.3	62.9	56.3	50.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		55.1	60.5	66.1	69.0	71.2	75.9	77.2	75.5	74.0	72.2	65.7	59.6	(27)
(28)			MCDB		61.2	69.3	79.7	82.0	86.2	88.4	88.4	85.9	83.3	82.3	76.4	67.9	(28)
(29)		2%	WB		52.5	55.4	61.2	64.7	67.4	71.5	73.9	73.5	71.6	69.2	62.8	56.4	(29)
(30)			MCDB		58.2	63.1	71.2	80.4	82.4	82.2	83.3	83.1	80.6	78.0	71.5	62.6	(30)
(31)		5%	WB		51.0	53.0	57.0	61.1	65.2	68.9	72.0	72.4	70.2	67.4	60.6	54.2	(31)
(32)			MCDB		56.3	60.1	68.3	75.9	80.9	80.6	81.1	81.3	78.4	76.1	68.0	59.9	(32)
(33)		10%	WB		49.6	51.0	54.4	58.8	63.4	67.2	70.6	71.4	69.2	66.0	58.9	52.5	(33)
(34)			MCDB		54.6	57.5	64.7	73.4	78.0	79.5	79.6	79.8	77.2	74.6	65.3	57.7	(34)
(35)	Mean Daily Temperature Range		MDBR		12.9	13.7	15.3	18.1	20.0	19.9	18.6	18.6	18.0	16.8	15.6	13.6	(35)
(36)		5% DB	MCDBR		18.0	20.1	21.8	24.3	24.5	22.6	20.2	20.3	21.1	21.2	20.4	17.9	(36)
(37)			MCWBR		10.0	11.0	11.5	11.6	10.8	10.1	9.0	8.4	8.9	10.1	11.1	9.6	(37)
(38)		5% WB	MCDBR		14.5	16.9	19.5	22.1	21.1	19.8	18.6	18.9	17.9	17.7	16.2	13.8	(38)
(39)			MCWBR		9.6	10.8	12.4	12.0	11.1	10.0	8.5	8.1	8.1	9.7	10.1	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.346	0.373	0.412	0.451	0.450	0.386	0.395	0.401	0.391	0.408	0.365	0.349	(40)
(41)		taud			2.325	2.231	2.104	1.999	2.032	2.255	2.240	2.224	2.255	2.190	2.300	2.330	(41)
(42)		Ebn at Noon			273	277	273	267	268	284	281	278	277	260	264	265	(42)
(43)		Edh at Noon			33	40	48	56	55	44	44	44	41	41	33	31	(43)
(44)	All-Sky Solar Radiation	RadAvg			915	1160	1616	1987	2342	2611	2533	2315	1961	1476	1094	859	(44)
(45)		RadStd			65	108	106	118	105	45	27	37	52	64	61	61	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (20 neighbors)	+0.79	N/A	-3.11	N/A	N/A	N/A	N/A	-115	+284	+185	(47)

Nomenclature: See separate page