DARAA, Syrian Arab Republic

WMO: **400950**

Lat: **32.600N** Lon: **36.100E** Elev: **1781** StdP: **13.77** Time Zone: **2.00 (SYR)** Period: **94-11** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	**1**	**33.9**	**36.7**	**14.4**	**12.2**	**50.1**	**19.4**	**15.6**	**54.7**	**24.8**	**55.4**	**20.5**	**50.9**	**1.3**	**150**	**0.365**	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	**7**	**22.8**	**97.6**	**66.7**	**94.9**	**66.9**	**92.5**	**67.2**	**73.3**	**88.3**	**71.9**	**86.0**	**70.8**	**84.1**	**8.4**	**270**	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	**69.2**	**114.8**	**77.3**	**68.1**	**110.3**	**76.8**	**67.0**	**106.0**	**76.1**	**38.2**	**87.1**	**36.9**	**86.3**	**35.9**	**84.0**	**87.1**	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	**20.4**	**17.4**	**15.0**	DB	**29.3**	**104.2**	**3.4**	**4.2**	**26.9**	**107.2**	**24.9**	**109.7**	**23.0**	**112.0**	**20.6**	**115.1**	(4)
(5)				WB	**26.8**	**76.5**	**3.7**	**4.0**	**24.2**	**79.4**	**22.0**	**81.7**	**20.0**	**83.9**	**17.3**	**86.9**	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg		65.0	48.5	50.3	55.6	62.1	70.0	75.9	79.5	79.9	76.1	70.0	59.4	51.2	(6)
(7)		DBStd		12.37	4.58	4.83	6.31	6.82	5.91	3.86	2.94	3.05	3.43	5.61	6.02	4.80	(7)
(8)		HDD50		193	83	46	14	2	0	0	0	0	0	0	5	43	(8)
(9)		HDD65		2010	513	412	302	134	19	0	0	0	0	18	183	429	(9)
(10)		CDD50		5656	35	55	188	366	619	778	915	928	783	621	289	79	(10)
(11)		CDD65		1997	0	0	11	48	173	328	450	463	333	174	16	1	(11)
(12)		CDH74		20817	0	7	161	721	2141	3539	4654	4668	3078	1655	192	1	(12)
(13)		CDH80		9481	0	0	39	246	929	1685	2293	2295	1316	644	34	0	(13)
(14)	Wind	WSAvg		4.5	4.4	4.5	4.8	5.0	5.2	5.5	6.3	5.3	3.8	2.9	2.9	3.3	(14)
(15)	Precipitation	PrecAvg		10.4	2.4	2.3	1.3	0.6	0.2	0.0	0.0	0.0	0.0	0.4	1.1	2.1	(15)
(16)		PrecMax		18.4	6.6	6.6	3.4	5.4	1.1	0.7	0.2	0.0	0.2	1.3	5.2	5.6	(16)
(17)		PrecMin		4.4	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	(17)
(18)		PrecStd		4.3	1.6	1.7	1.0	1.1	0.2	0.2	0.0	0.0	0.0	0.4	1.3	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		67.6	73.6	84.5	92.3	99.2	99.9	101.0	101.1	98.0	95.8	84.0	71.5	(19)
(20)			MCWB		51.2	54.4	58.5	61.7	64.0	65.5	70.1	69.2	65.1	63.3	58.2	51.7	(20)
(21)		2%	DB		63.4	66.8	78.6	86.4	93.4	96.3	96.0	95.6	93.6	90.6	79.1	66.1	(21)
(22)			MCWB		50.2	51.0	56.3	59.5	62.7	65.0	69.3	70.0	65.4	61.7	56.7	50.6	(22)
(23)		5%	DB		60.3	63.5	73.4	82.6	89.4	92.6	93.1	92.7	90.3	86.6	75.2	63.0	(23)
(24)			MCWB		49.4	49.9	53.9	58.2	61.8	65.5	69.0	70.1	66.4	61.2	56.0	50.3	(24)
(25)		10%	DB		57.5	60.0	68.9	77.9	85.4	89.1	90.9	90.4	87.2	82.9	72.0	60.3	(25)
(26)			MCWB		48.1	49.3	53.2	57.2	60.9	65.5	68.5	69.4	66.1	61.6	55.0	49.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		55.5	56.9	62.0	64.7	68.8	71.1	75.1	75.6	73.5	67.4	62.1	56.1	(27)
(28)			MCDB		62.4	69.0	76.8	82.5	89.4	87.8	91.7	92.7	88.6	80.7	73.6	64.1	(28)
(29)		2%	WB		52.3	53.3	58.2	62.1	65.6	69.3	72.9	73.6	70.9	65.9	60.1	54.2	(29)
(30)			MCDB		58.8	62.9	72.1	79.8	86.2	86.2	89.1	88.0	83.2	79.3	71.7	61.2	(30)
(31)		5%	WB		50.9	51.7	56.3	60.0	63.7	68.0	71.5	72.4	69.4	64.7	58.6	52.8	(31)
(32)			MCDB		57.4	59.7	69.9	77.9	83.4	84.3	86.7	85.8	81.0	77.6	70.1	59.2	(32)
(33)		10%	WB		49.4	50.3	54.3	58.3	62.2	66.9	70.3	71.3	68.3	63.6	57.2	51.4	(33)
(34)			MCDB		55.7	57.2	65.8	75.6	81.1	83.2	84.3	83.8	79.7	76.5	68.5	57.5	(34)
(35)	Mean Daily Temperature Range		MDBR		16.0	16.1	19.4	23.1	25.4	24.9	22.8	22.4	22.9	23.3	21.8	17.5	(35)
(36)		5% DB	MCDBR		21.2	23.5	28.4	31.0	32.4	31.2	26.4	25.5	28.3	29.9	27.3	22.4	(36)
(37)			MCWBR		11.9	11.7	12.7	12.7	11.9	10.8	9.1	7.7	9.4	12.1	12.8	12.1	(37)
(38)		5% WB	MCDBR		16.9	18.8	24.5	26.7	27.9	25.5	23.3	22.7	21.9	24.0	22.5	16.9	(38)
(39)			MCWBR		10.8	10.6	12.2	12.8	11.4	9.3	8.1	6.9	8.0	10.8	11.6	10.4	(39)
(40)	Clear-Sky Solar Irradiance	taub			0.348	0.377	0.418	0.461	0.461	0.392	0.400	0.405	0.396	0.416	0.369	0.351	(40)
(41)		taud			2.319	2.220	2.085	1.973	2.005	2.238	2.225	2.210	2.239	2.167	2.285	2.320	(41)
(42)		Ebn at Noon			272	275	272	264	265	283	280	277	275	258	262	264	(42)
(43)		Edh at Noon			33	40	49	58	56	44	45	45	42	42	34	31	(43)
(44)	All-Sky Solar Radiation	RadAvg			924	1171	1630	1997	2359	2631	2549	2331	1981	1489	1100	865	(44)
(45)		RadStd			65	109	102	114	107	39	27	36	51	63	63	59	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	**N/A**	(46)
(47)	Regional (21 neighbors)	**+0.79**	**N/A**	**-3.11**	**N/A**	**N/A**	**N/A**	**N/A**	**-115**	**+284**	**+185**	(47)

Nomenclature: See separate page