 © 2021 ASHRAE, Inc.

RUSSKAYA GAVAN, Russian Federation

WMO: **203570**

Lat: **76.189N** Lon: **62.597E** Elev: **9** StdP: **101.22** Time Zone: **3.00 (E03)** Period: **82-93** WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

	Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF	
				99.6%			99%			0.4%		1%					
		99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(1)	2	-32.8	-30.6	-36.2	0.1	-32.6	-34.1	0.2	-30.6	28.0	-23.4	23.8	-16.3	2.3	270	1.107	(1)

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

	Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB		
			0.4%		1%		2%		0.4%		1%		2%				
			DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD	
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(2)	7	3.4	11.4	7.7	9.6	6.5	8.0	5.5	8.0	10.9	6.8	9.3	5.7	7.7	3.7	180	(2)

	Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB	
	0.4%			1%			2%			0.4%		1%		2%			
	DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
	(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(3)	5.7	5.7	9.0	4.6	5.3	7.6	3.8	5.0	6.4	24.8	11.0	22.2	9.5	20.0	7.7	15.1	(3)

Extreme Annual Design Conditions

	Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
					Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
	1%	2.5%	5%		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
	(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4)	21.0	18.2	15.6	DB	-34.2	14.7	2.4	2.4	-35.9	16.4	-37.3	17.8	-38.7	19.2	-40.4	20.9	(4)
(5)				WB	-34.3	10.3	2.4	2.2	-36.0	11.8	-37.4	13.1	-38.8	14.3	-40.5	15.9	(5)

Monthly Climatic Design Conditions

				Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
				(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg		-7.9	-17.5	-17.7	-15.4	-14.8	-5.4	0.8	3.9	3.7	1.1	-5.8	-11.9	-16.1	(6)
(7)		DBStd		9.96	7.17	8.13	7.40	7.38	4.19	3.37	3.03	2.46	2.88	4.99	6.35	6.22	(7)
(8)		HDD10.0		6524	851	774	788	744	478	278	193	197	266	490	656	809	(8)
(9)		HDD18.3		9563	1109	1008	1046	994	737	527	449	455	516	748	906	1068	(9)
(10)		CDD10.0		3	0	0	0	0	0	1	2	1	0	0	0	0	(10)
(11)		CDD18.3		0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3		0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7		0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg		5.8	7.0	6.2	6.8	5.0	4.8	4.7	4.6	4.1	5.4	6.0	7.0	7.6	(14)
(15)	Precipitation	PrecAvg		500	45	41	34	30	26	32	42	54	51	59	42	43	(15)
(16)		PrecMax		713	89	81	72	54	48	69	108	97	104	115	97	85	(16)
(17)		PrecMin		235	20	12	14	3	14	10	9	5	18	25	17	17	(17)
(18)		PrecStd		129	16	17	15	12	9	15	21	20	20	22	19	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB		-0.5	-0.4	0.2	4.2	4.6	12.3	13.7	12.9	8.9	5.8	1.5	-0.3	(19)
(20)			MCWB		-1.7	-1.4	-0.9	1.2	2.2	7.8	9.7	8.3	6.3	3.7	0.1	-1.2	(20)
(21)		2%	DB		-1.8	-1.5	-1.2	0.7	2.8	10.0	11.7	9.9	7.2	3.5	0.5	-2.3	(21)
(22)			MCWB		-2.9	-2.4	-1.8	-0.9	0.7	6.4	8.1	6.8	5.0	2.2	-0.5	-3.4	(22)
(23)		5%	DB		-3.7	-3.2	-2.2	-0.8	1.5	7.2	10.2	8.3	6.0	2.0	-0.6	-4.2	(23)
(24)			MCWB		-4.8	-4.2	-3.0	-2.1	-0.3	4.3	7.1	5.7	4.0	0.7	-1.5	-5.3	(24)
(25)		10%	DB		-6.1	-5.5	-4.0	-3.2	0.2	5.4	8.8	6.9	5.1	0.5	-2.2	-6.6	(25)
(26)			MCWB		-7.0	-6.3	-4.9	-4.4	-1.3	3.0	6.0	4.9	3.5	-0.8	-3.2	-7.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB		-1.2	-1.0	-0.6	1.1	2.2	8.3	10.5	8.6	6.4	3.7	0.5	-0.9	(27)
(28)			MCDB		-0.6	-0.5	0.1	4.0	4.3	11.7	13.2	11.6	8.2	5.0	1.0	-0.2	(28)
(29)		2%	WB		-2.9	-2.4	-1.7	-0.6	0.9	6.3	8.5	7.1	5.1	2.3	-0.4	-3.2	(29)
(30)			MCDB		-1.9	-1.6	-1.3	0.7	2.5	9.7	11.2	9.6	6.9	3.4	0.4	-2.5	(30)
(31)		5%	WB		-4.6	-4.1	-2.9	-2.1	-0.1	4.4	7.4	6.0	4.3	0.9	-1.5	-5.1	(31)
(32)			MCDB		-3.7	-3.2	-2.2	-0.9	1.3	6.9	10.1	7.5	5.6	2.0	-0.5	-4.2	(32)
(33)		10%	WB		-7.1	-6.3	-4.9	-4.4	-1.1	3.1	6.2	5.2	3.6	-0.8	-3.3	-7.5	(33)
(34)			MCDB		-6.1	-5.4	-4.1	-3.2	0.2	5.1	8.6	6.7	4.9	0.5	-2.0	-6.5	(34)
(35)	Mean Daily Temperature Range		MDBR		6.2	5.9	7.6	7.3	4.3	3.5	3.4	3.2	3.2	4.3	5.0	5.7	(35)
(36)		5% DB	MCDBR		7.4	7.1	8.3	8.6	5.0	6.2	5.7	5.7	4.1	5.8	5.5	6.9	(36)
(37)			MCWBR		7.1	7.1	7.9	7.3	4.3	4.2	4.1	3.7	3.2	5.1	5.5	6.5	(37)
(38)		5% WB	MCDBR		7.6	7.0	8.4	8.7	5.0	6.0	5.7	4.8	3.9	5.8	4.8	7.3	(38)
(39)			MCWBR		7.3	7.0	8.1	8.0	4.3	4.2	4.3	3.4	3.2	5.3	5.1	7.0	(39)
(40)	Clear-Sky Solar Irradiance	taub			N/A	0.193	0.265	0.294	0.321	0.312	0.326	0.310	0.265	0.188	N/A	N/A	(40)
(41)		taud			N/A	1.873	2.016	2.070	2.094	2.227	2.273	2.316	2.260	1.931	N/A	N/A	(41)
(42)		Ebn at Noon			0	139	582	764	807	842	808	758	622	120	0	0	(42)
(43)		Edh at Noon			0	12	62	97	114	105	96	77	50	9	0	0	(43)
(44)	All-Sky Solar Radiation	RadAvg			0.00	0.06	1.01	3.21	5.05	5.58	4.55	2.77	1.17	0.19	0.00	0.00	(44)
(45)		RadStd			0.00	0.01	0.13	0.36	0.59	0.65	0.41	0.25	0.08	0.02	0.00	0.00	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page