

JAN MAYEN, Svalbard and Jan Mayen

WMO: 010010

Lat: 70.940N

Lon: 8.668W

Elev: 30

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.8	10.7	-0.1	5.5	8.3	3.4	6.6	11.4	47.2	24.6	43.3	24.2	20.9	350	0.976

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.3	49.2	46.5	48.0	45.9	47.1	45.3	47.5	48.5	46.7	47.6	45.8	46.8	10.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.7	47.2	48.0	45.9	45.7	47.2	45.0	44.2	46.5	19.0	48.8	18.5	47.7	18.1	47.0	57.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.3	35.4	31.7	DB	5.1	54.5	5.6	3.2	1.1	56.8	-2.1	58.7	-5.2	60.5	-9.3	62.9	(4)
(5)			WB	4.1	50.5	5.3	2.8	0.3	52.5	-2.9	54.1	-5.8	55.7	-9.7	57.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	26.7	26.1	25.4	28.2	32.9	37.8	42.4	43.7	40.3	34.6	29.8	27.5
	DBStd	8.38	7.59	6.70	6.56	5.73	4.14	3.33	2.96	2.57	4.17	5.55	6.03	6.84
	HDD50	6202	721	669	763	653	529	365	234	196	290	479	605	698
	HDD65	11677	1186	1089	1228	1103	994	815	699	661	740	944	1055	1163
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.6	17.2	17.0	16.9	15.0	13.6	11.0	10.3	10.5	13.7	15.5	16.6	18.0
Precipitation	PrecAvg	26.2	2.3	2.0	2.2	1.6	1.5	1.2	1.7	2.3	3.1	3.1	2.6	2.6
	PrecMax	35.6	4.6	4.6	4.9	3.6	3.7	4.1	3.9	5.2	7.9	6.1	6.2	5.0
	PrecMin	19.3	0.7	0.2	0.2	0.4	0.2	0.2	0.2	0.7	0.6	0.7	0.8	0.6
	PrecStd	4.0	1.0	1.1	1.0	0.7	0.9	0.8	0.9	0.9	1.4	1.4	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	38.7	38.6	41.5	44.5	49.2	52.0	51.4	49.1	46.3	42.3	42.9
		MCWB	37.4	36.5	36.1	37.8	40.5	43.7	47.5	46.9	47.1	44.6	40.6	39.8
	2%	DB	37.4	36.9	36.3	37.8	41.0	45.6	49.3	49.1	47.7	44.9	40.5	39.1
		MCWB	35.7	35.4	34.7	36.3	38.7	42.8	46.4	46.6	46.1	43.7	39.1	37.6
	5%	DB	36.4	35.8	35.0	36.4	39.5	43.8	47.7	48.0	46.8	43.9	39.2	37.7
		MCWB	35.0	34.5	33.7	35.1	37.6	41.7	45.5	46.2	45.5	42.7	37.9	36.5
	10%	DB	35.5	34.7	33.9	35.2	38.3	42.5	46.6	47.2	45.9	42.5	38.1	36.4
		MCWB	34.4	33.4	32.7	34.0	36.7	40.8	44.8	45.5	44.7	41.2	36.9	35.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.6	37.4	36.8	38.7	41.2	45.8	49.5	48.6	47.7	45.3	41.3	40.3
		MCDB	38.6	38.2	38.0	40.8	43.2	47.7	50.5	49.7	48.2	45.9	42.0	42.4
	2%	WB	36.1	36.0	35.1	36.7	39.3	43.5	47.5	47.5	46.7	44.1	39.5	38.0
		MCDB	36.9	36.8	35.9	37.6	40.4	44.7	48.6	48.5	47.4	44.6	40.2	39.0
	5%	WB	35.4	34.8	34.0	35.5	38.1	42.3	46.2	46.7	45.8	43.0	38.2	36.8
		MCDB	36.2	35.7	34.9	36.2	39.2	43.5	47.3	47.7	46.6	43.8	39.1	37.7
	10%	WB	34.5	33.6	32.9	34.3	37.0	41.1	45.2	46.0	44.9	41.3	36.9	35.4
		MCDB	35.4	34.6	33.9	35.2	38.1	42.4	46.3	47.0	45.8	42.5	38.0	36.4
Mean Daily Temperature Range	5% DB	MDBR	7.0	6.7	6.6	5.6	4.8	5.2	4.8	4.3	4.4	5.0	5.9	6.6
		MCDBR	6.6	6.2	6.9	6.0	6.5	7.0	6.4	5.0	4.9	4.5	5.9	6.8
		MCWBR	6.3	6.1	6.7	5.4	5.3	5.2	4.9	4.1	4.7	4.6	5.9	6.7
	5% WB	MCDBR	6.1	6.5	6.7	5.6	6.1	5.9	5.5	4.4	4.5	4.3	5.9	6.6
		MCWBR	6.1	6.5	6.5	5.1	5.3	5.0	4.7	3.9	4.4	4.6	6.0	6.7
Clear-Sky Solar Irradiance	taub	N/A	0.257	0.310	0.351	0.353	0.333	0.335	0.337	0.324	0.268	N/A	N/A	
	taud	N/A	2.094	2.312	2.290	2.372	2.504	2.520	2.523	2.417	2.072	N/A	N/A	
	Ebn at Noon	0	131	217	244	261	273	267	251	213	115	0	0	
	Edh at Noon	0	11	20	29	30	28	26	23	19	11	0	0	
All-Sky Solar Radiation	RadAvg	0	53	298	725	1139	1408	1156	772	407	95	0	0	
	RadStd	0	5	37	99	113	128	117	81	44	12	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.53	+3.13	+2.99	+1.42	+1.31	+1.31	-655	-657	N/A	N/A
Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page