

JAN MAYEN, Svalbard and Jan Mayen

WMO: 010010

Lat: 70.940N

Lon: 8.668W

Elev: 9

StdP: 101.22

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-14.0	-11.8	-17.8	0.8	-13.2	-15.9	0.9	-11.4	21.1	-4.1	19.4	-4.4	9.3	350	0.976

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.4	9.6	8.0	8.9	7.7	8.4	7.4	8.6	9.2	8.1	8.7	7.7	8.2	4.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.2	6.7	8.9	7.7	6.5	8.5	7.2	6.3	8.1	26.3	9.3	25.2	8.7	24.3	8.3	14.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	15.8	14.2	-14.9	12.5	3.1	1.8	-17.2	13.8	-19.0	14.8	-20.7	15.9	-22.9	17.2
			-15.5	10.3	3.0	1.5	-17.6	11.4	-19.4	12.3	-21.0	13.2	-23.2	14.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-2.9	-3.3	-3.7	-2.1	0.5	3.2	5.8	6.5	4.6	1.4	-1.2	-2.5
	DBStd	4.66	4.22	3.72	3.64	3.18	2.30	1.85	1.65	1.43	2.31	3.08	3.35	3.80
	HDD10.0	3446	401	372	424	363	294	203	130	109	161	266	336	388
	HDD18.3	6487	659	605	682	613	552	453	388	367	411	524	586	646
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	6.5	7.7	7.6	7.6	6.7	6.1	4.9	4.6	4.7	6.1	6.9	7.4	8.0
(15) Precipitation	PrecAvg	666	59	52	55	41	38	30	42	59	78	78	67	66
	PrecMax	905	118	118	125	91	94	105	100	132	200	155	157	126
	PrecMin	491	19	4	6	11	6	5	4	18	16	18	21	14
	PrecStd	102	25	28	26	19	23	20	22	24	35	35	28	26
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	3.7	3.7	5.3	6.9	9.5	11.1	10.8	9.5	7.9	5.7	6.1
		MCWB	3.0	2.5	2.3	3.2	4.7	6.5	8.6	8.3	8.4	7.0	4.8	4.3
	2%	DB	3.0	2.7	2.4	3.2	5.0	7.6	9.6	9.5	8.7	7.2	4.7	3.9
		MCWB	2.0	1.9	1.5	2.4	3.7	6.0	8.0	8.1	7.8	6.5	3.9	3.1
	5%	DB	2.5	2.1	1.7	2.5	4.2	6.6	8.7	8.9	8.2	6.6	4.0	3.2
		MCWB	1.7	1.4	0.9	1.7	3.1	5.4	7.5	7.9	7.5	6.0	3.3	2.5
	10%	DB	2.0	1.5	1.1	1.8	3.5	5.9	8.1	8.5	7.7	5.8	3.4	2.4
		MCWB	1.3	0.8	0.4	1.1	2.6	4.9	7.1	7.5	7.1	5.1	2.7	1.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	3.0	2.7	3.7	5.1	7.6	9.7	9.2	8.7	7.4	5.2	4.6
		MCDB	3.7	3.5	3.3	4.9	6.2	8.7	10.3	9.9	9.0	7.7	5.6	5.8
	2%	WB	2.3	2.2	1.7	2.6	4.0	6.4	8.6	8.6	8.2	6.7	4.2	3.4
		MCDB	2.7	2.7	2.2	3.1	4.7	7.1	9.2	9.1	8.6	7.0	4.6	3.9
	5%	WB	1.9	1.6	1.1	1.9	3.4	5.7	7.9	8.2	7.7	6.1	3.4	2.6
		MCDB	2.3	2.0	1.6	2.4	4.0	6.4	8.5	8.7	8.1	6.6	3.9	3.1
	10%	WB	1.4	0.9	0.5	1.3	2.8	5.0	7.3	7.8	7.2	5.2	2.7	1.9
		MCDB	1.9	1.4	1.0	1.8	3.4	5.8	7.9	8.4	7.7	5.8	3.3	2.4
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	3.7	3.7	3.1	2.7	2.9	2.6	2.4	2.5	2.8	3.3	3.7
		MCDBR	3.7	3.4	3.8	3.3	3.6	3.9	3.6	2.8	2.7	2.5	3.3	3.8
	5% WB	MCWBR	3.5	3.4	3.7	3.0	3.0	2.9	2.7	2.3	2.6	2.6	3.3	3.7
		MCDWR	3.4	3.6	3.7	3.1	3.4	3.3	3.0	2.4	2.5	2.4	3.3	3.7
(40) Clear-Sky Solar Irradiance	taub		N/A	0.257	0.310	0.351	0.353	0.333	0.335	0.337	0.324	0.268	N/A	N/A
	taud		N/A	2.094	2.312	2.290	2.372	2.504	2.520	2.523	2.417	2.072	N/A	N/A
	Ebn at Noon		0	414	683	768	822	860	843	792	672	362	0	0
	Edh at Noon		0	35	64	91	96	87	83	73	59	34	0	0
(44) All-Sky Solar Radiation	RadAvg		0.00	0.17	0.94	2.29	3.59	4.44	3.64	2.43	1.28	0.30	0.00	0.00
	RadStd		0.00	0.02	0.12	0.31	0.35	0.40	0.37	0.26	0.14	0.04	0.00	0.00

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.85	+1.74	+1.66	+0.79	+0.73	+0.73	-364	-365	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A