

EDGEØYA, Norway

WMO: 010060

Lat: 78.251N

Lon: 22.823E

Elev: 14

StdP: 101.16

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-28.0	-25.7	-30.7	0.2	-27.9	-28.3	0.3	-25.5	20.5	-8.1	18.0	-14.8	1.7	20	1.053

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.4	9.2	7.3	8.1	6.5	7.1	5.7	7.5	8.9	6.6	7.9	5.8	7.0	7.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.3	5.9	8.1	5.5	5.6	7.2	4.7	5.3	6.4	23.8	9.0	22.0	8.0	20.3	7.1	10.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	14.3	12.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.7	-10.2	-10.8	-13.4	-10.8	-4.1	0.8	3.7	3.6	1.7	-2.1	-6.5	-9.1
	DBStd	7.72	7.19	7.99	6.44	5.33	3.63	2.02	2.36	2.11	2.47	3.39	5.33	6.24
	HDD10.0	5378	627	583	725	623	437	277	195	199	249	376	495	592
	HDD18.3	8419	886	816	983	873	695	527	453	458	499	634	745	850
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	5.8	6.3	6.1	5.9	4.7	5.3	4.5	4.6	5.2	5.8	6.8	7.0	7.1
(15) Precipitation	PrecAvg	435	40	33	30	20	20	23	28	45	51	54	51	41
	PrecMax	662	77	85	64	52	39	46	63	91	94	115	96	110
	PrecMin	133	16	3	2	4	5	6	6	7	16	16	14	7
	PrecStd	124	18	20	15	11	10	12	15	20	18	23	24	22
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.8	2.4	2.2	2.7	3.1	7.9	10.9	10.7	8.4	5.8	3.8	2.9
		MCWB	1.8	1.3	1.1	1.4	1.6	6.2	8.1	8.7	7.2	4.6	2.7	2.1
	2%	DB	1.5	1.6	0.3	1.5	2.2	6.3	9.6	9.0	7.2	4.6	2.5	1.0
		MCWB	0.8	0.7	-0.5	0.5	1.0	4.8	7.5	7.2	6.1	3.6	1.5	0.1
	5%	DB	-0.6	0.1	-1.2	-0.2	1.6	5.0	8.5	7.8	6.3	3.0	1.3	-0.4
		MCWB	-1.2	-0.5	-1.6	-0.6	0.6	3.6	6.7	6.2	5.2	2.3	0.6	-0.9
	10%	DB	-1.8	-1.4	-3.2	-2.8	0.8	3.8	7.5	6.7	5.2	2.0	0.0	-1.4
		MCWB	-2.3	-1.8	-3.6	-3.6	0.0	2.7	5.9	5.4	4.2	1.3	-0.4	-1.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	1.6	1.5	1.7	2.0	6.5	8.6	9.0	7.2	4.7	2.7	2.0
		MCDB	2.7	2.2	2.3	2.5	2.7	7.7	10.2	10.5	8.0	5.5	3.7	2.7
	2%	WB	0.9	0.7	-0.3	0.6	1.3	4.9	7.7	7.4	6.3	3.6	1.6	0.2
		MCDB	1.6	1.5	0.3	1.3	2.0	6.3	9.3	8.7	7.1	4.4	2.3	0.7
	5%	WB	-1.1	-0.5	-1.5	-0.8	0.7	3.8	6.8	6.4	5.3	2.4	0.6	-0.8
		MCDB	-0.7	0.0	-1.2	-0.2	1.4	4.9	8.4	7.6	6.2	3.0	1.3	-0.5
	10%	WB	-2.2	-1.7	-3.6	-3.6	0.1	2.7	5.9	5.6	4.3	1.4	-0.4	-1.7
		MCDB	-1.8	-1.4	-3.2	-3.0	0.8	3.7	7.3	6.6	5.1	1.9	0.1	-1.4
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.4	5.4	3.6	2.7	3.4	3.0	3.0	3.2	4.2	5.1
		MCDBR	5.7	5.9	6.3	5.7	3.9	4.2	5.3	4.5	4.5	3.6	4.5	5.4
	5% WB	MCWBR	5.6	5.6	6.2	5.2	3.2	3.2	3.8	3.4	3.9	3.3	4.4	5.2
		MCDWR	5.7	5.4	6.2	6.0	3.7	4.0	5.2	4.4	4.5	3.7	4.3	5.1
(40) Clear-Sky Solar Irradiance	taub	N/A	0.195	0.248	0.283	0.304	0.295	0.302	0.295	0.253	N/A	N/A	N/A	N/A
	taud	N/A	1.870	2.006	2.107	2.126	2.289	2.444	2.468	2.373	N/A	N/A	N/A	N/A
	Ebn at Noon	0	25	543	755	812	851	830	769	609	0	0	0	0
	Edh at Noon	0	4	53	88	106	95	78	63	39	0	0	0	0
(44) All-Sky Solar Radiation	RadAvg	0.00	0.02	0.85	3.26	5.29	5.90	4.78	2.84	1.00	0.00	0.00	0.00	0.00
	RadStd	0.00	0.00	0.07	0.29	0.44	0.56	0.47	0.30	0.09	0.00	0.00	0.00	0.00

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+1.52	+4.63	+4.10	N/A	N/A	N/A	-552	-549	N/A