

ANDOYA, Norway

WMO: 010100

Lat: 69.293N

Lon: 16.144E

Elev: 13

StdP: 101.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.7	-8.2	-15.1	1.0	-8.0	-13.7	1.2	-7.1	18.4	1.7	16.8	1.9	4.4	180	0.833

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	19.0	14.2	17.1	13.3	15.5	12.5	14.9	18.0	13.8	16.4	12.8	15.1	4.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	9.5	16.4	12.2	8.9	15.2	11.4	8.4	14.2	41.6	18.2	38.7	16.4	36.2	15.2	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	13.4	11.9	-12.1	22.2	1.2	2.3	-13.0	23.8	-13.7	25.1	-14.4	26.4	-15.3	28.0
			-12.8	16.6	1.1	1.6	-13.6	17.8	-14.3	18.7	-14.9	19.6	-15.7	20.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.2	-1.2	-1.8	-1.0	1.7	5.7	8.7	11.5	11.3	8.7	4.7	1.5	-0.1
	DBStd	5.60	3.43	3.47	3.19	2.97	2.90	2.46	2.54	2.42	2.58	3.04	3.12	3.44
	HDD10.0	2268	349	329	339	249	137	54	11	13	54	167	255	312
	HDD18.3	5166	607	562	598	498	391	289	213	219	289	424	505	570
	CDD10.0	145	0	0	0	0	4	16	57	52	15	1	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	2	0	0	0	0	0	1	2	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.8	6.9	6.9	6.6	5.4	5.3	5.2	4.5	4.5	5.0	5.8	6.1	6.8
Precipitation	PrecAvg	1053	108	99	106	69	62	45	53	65	106	134	101	105
	PrecMax	1359	218	182	204	138	148	121	135	234	206	254	220	229
	PrecMin	710	0	41	33	17	14	5	0	15	46	34	9	0
	PrecStd	147	51	35	46	26	34	26	38	44	45	53	60	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	6.8	6.7	12.1	17.7	19.8	22.2	21.0	16.5	12.8	9.7	8.0
		MCWB	5.6	5.2	4.4	7.3	11.0	12.8	16.4	15.7	12.4	9.7	8.0	6.5
	2%	DB	5.7	5.4	5.4	9.1	14.1	16.8	19.5	18.2	14.8	11.2	8.3	6.8
		MCWB	4.0	3.7	3.6	6.0	9.2	11.8	15.1	14.2	11.8	8.9	6.7	5.3
	5%	DB	4.4	4.2	4.3	7.2	11.9	14.1	17.3	16.5	13.5	10.1	7.1	5.6
		MCWB	2.7	2.6	2.4	4.9	8.0	10.7	13.9	13.5	11.1	8.2	5.3	3.8
	10%	DB	3.2	3.0	3.3	5.9	9.9	12.2	15.6	15.1	12.5	9.1	6.0	4.4
		MCWB	1.6	1.5	1.6	3.8	7.0	9.9	12.9	12.7	10.4	7.4	4.2	2.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	5.5	4.9	7.7	11.5	13.6	17.2	16.2	13.4	10.2	8.2	6.8
		MCDB	6.9	6.6	6.3	10.6	16.7	18.4	21.4	19.2	15.6	12.0	9.4	7.7
	2%	WB	4.1	3.9	3.7	6.3	9.7	12.1	15.4	14.6	12.3	9.3	6.9	5.2
		MCDB	5.3	5.3	5.2	8.7	13.6	15.6	18.9	17.5	14.2	11.0	8.1	6.6
	5%	WB	2.8	2.7	2.7	5.1	8.3	11.1	14.2	13.7	11.5	8.4	5.5	4.0
		MCDB	4.2	4.0	4.1	7.1	11.1	13.9	16.9	16.2	13.3	9.9	6.9	5.3
	10%	WB	1.8	1.6	1.8	4.0	7.3	10.1	13.1	12.8	10.7	7.5	4.3	2.8
		MCDB	3.0	2.8	3.1	5.7	9.5	12.2	15.4	15.0	12.4	9.0	5.7	4.2
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.3	4.4	4.8	4.9	4.0	4.3	4.5	4.6	4.0	3.9	4.1
		MCDBR	4.3	4.5	4.3	6.4	8.2	7.6	8.2	7.5	6.0	4.4	4.4	4.3
		MCWBR	3.9	4.1	3.5	4.4	4.8	4.2	5.0	4.6	4.1	3.7	4.0	4.1
	5% WB	MCDBR	4.2	4.6	4.2	6.2	7.2	6.7	7.6	6.6	5.4	4.3	4.4	4.3
		MCWBR	4.0	4.4	3.7	4.5	4.5	4.1	5.0	4.4	3.9	3.8	4.1	4.3
Clear-Sky Solar Irradiance	taub	0.372	0.283	0.324	0.344	0.350	0.348	0.352	0.342	0.326	0.285	0.351	N/A	
	taud	2.545	2.125	2.236	2.347	2.437	2.485	2.485	2.505	2.518	2.502	2.224	2.542	N/A
	Ebn at Noon	51	451	681	795	838	850	833	799	705	446	43	0	
	Edh at Noon	9	42	74	89	92	90	86	76	59	37	7	0	
All-Sky Solar Radiation	RadAvg	0.01	0.27	1.24	2.97	4.53	4.95	4.39	3.13	1.66	0.52	0.05	0.00	
	RadStd	0.00	0.05	0.18	0.29	0.34	0.64	0.43	0.26	0.16	0.09	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.48	+0.63	+1.19	N/A	N/A	N/A	-149	-168	N/A
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page