

SKIBOTN, Norway

WMO: 010370

Lat: 69.388N

Lon: 20.282E

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	1.4	-8.9	3.4	-0.5	-5.0	4.2	3.3	22.5	21.7	20.2	20.8	5.3	130	0.688

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	73.2	59.1	69.4	57.7	66.2	56.6	61.2	69.8	59.2	67.2	57.3	64.9	6.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.2	69.9	65.2	55.1	64.8	63.1	53.3	60.5	60.9	27.2	69.9	25.9	67.5	24.7	65.2	
				</											

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.0	(b) 15.2	(c) 13.6	(e) -8.2	(f) 81.5	(g) 4.9	(h) 5.4	(i) -11.7	(j) 85.4	(k) -14.6	(l) 88.6	(m) -17.3	(n) 91.6	(o) -20.9	(p) 95.6		
(4) 17.0	(5) 15.2	(6) 13.6	(7) -8.7	(8) 63.9	(9) 4.8	(10) 3.5	(11) -12.1	(12) 66.4	(13) -15.0	(14) 68.4	(15) -17.7	(16) 70.3	(17) -21.1	(18) 72.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.1	20.7	21.0	26.3	34.9	43.8	50.1	56.0	53.7	47.1	36.7	29.0	25.5		
	DBStd	14.48	10.18	10.59	8.93	6.46	6.23	5.24	5.63	5.35	6.36	8.42	8.14	9.13		
	HDD50	5151	909	813	736	452	212	61	8	22	130	418	630	760		
	HDD65	10177	1374	1233	1201	902	658	448	287	353	538	878	1080	1225		
	CDD50	458	0	0	0	0	18	64	192	136	42	6	0	0		
	CDD65	8	0	0	0	0	0	1	6	1	0	0	0	0		
	CDH74	110	0	0	0	0	0	12	80	18	0	0	0	0		
	CDH80	21	0	0	0	0	0	1	16	4	0	0	0	0		
	WSAvg	6.0	6.6	6.9	6.3	6.3	6.4	6.1	5.5	5.3	5.5	5.4	6.0	6.3		
	PrecAvg	20.6	2.3	1.6	1.5	0.8	0.9	1.4	2.2	2.0	1.8	2.2	1.6	2.1		
(15) Precipitation	PrecMax	26.4	5.4	3.9	5.4	2.4	2.5	2.5	4.6	4.2	3.4	4.7	3.6	4.3		
	PrecMin	14.6	0.3	0.1	0.2	0.1	0.2	0.2	0.4	0.9	0.4	0.5	0.1	0.6		
	PrecStd	2.8	1.4	0.8	1.3	0.5	0.6	0.6	0.9	0.8	0.8	1.1	1.1	1.0		
	PrecStd	2.8	1.4	0.8	1.3	0.5	0.6	0.6	0.9	0.8	0.8	1.1	1.1	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	47.0	47.2	49.9	56.7	70.5	75.3	82.2	75.7	67.5	58.7	52.3	49.1			
	0.4% MCWB	40.3	40.3	39.4	45.2	54.3	58.2	65.2	60.5	56.9	49.8	46.1	42.3			
	2% DB	42.7	43.2	45.3	51.8	64.7	68.2	75.1	70.8	63.1	55.4	47.3	45.0			
	2% MCWB	37.5	38.0	38.6	43.2	51.6	56.1	61.1	58.7	54.4	48.2	42.0	39.0			
	5% DB	38.6	39.2	41.9	48.0	59.3	63.7	70.9	67.2	60.4	52.5	43.4	41.4			
	5% MCWB	34.4	35.2	36.3	40.7	48.6	53.2	59.1	57.7	52.9	46.6	38.8	36.2			
	10% DB	34.9	35.6	38.7	45.2	55.3	60.4	67.3	64.2	57.6	49.2	40.2	38.0			
	10% MCWB	31.4	31.8	33.8	38.7	46.1	51.5	57.8	56.1	51.0	44.1	36.0	33.7			
	0.4% WB	40.8	41.1	40.6	46.7	55.7	60.1	66.3	63.4	57.5	50.6	46.3	43.0			
	0.4% MCDB	46.3	45.9	47.2	55.1	67.9	70.7	80.4	71.3	65.2	57.3	52.0	48.4			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	37.8	37.8	38.6	43.6	52.0	56.8	62.4	60.2	55.2	48.6	42.3	39.5			
	2% MCDB	42.6	42.8	44.8	51.4	63.9	66.4	72.2	67.3	62.0	54.5	47.1	44.7			
	5% WB	34.7	35.4	36.5	41.0	49.2	54.6	60.2	58.5	53.4	46.7	39.0	36.4			
	5% MCDB	38.5	38.9	41.6	47.4	58.3	62.3	68.8	65.9	59.3	52.0	43.1	40.7			
	10% WB	31.7	32.3	34.3	39.2	46.8	52.3	58.3	56.6	51.6	44.2	36.3	33.8			
	10% MCDB	34.6	35.4	38.6	44.7	54.5	58.6	66.0	63.5	56.7	48.6	40.0	37.6			
(35) Mean Daily Temperature Range	MDBR	11.8	12.4	15.0	14.8	15.7	14.0	15.4	16.0	14.6	11.7	11.0	11.3			
	5% DB	13.9	13.3	12.7	17.5	24.5	21.8	23.6	22.3	17.7	12.9	12.9	12.1			
	5% WB	11.0	10.2	8.5	11.0	13.4	11.5	11.4	12.1	10.6	8.6	9.4	9.0			
	MCDBR	13.7	14.0	12.6	16.9	23.6	19.4	21.0	20.6	16.2	12.9	12.9	12.2			
	MCWBR	11.1	11.2	8.9	10.8	13.0	10.6	10.8	11.7	10.1	8.8	9.5	9.5			
	MCWBR	11.1	11.2	8.9	10.8	13.0	10.6	10.8	11.7	10.1	8.8	9.5	9.5			
(40) Clear-Sky Solar Irradiance	taub	0.216	0.265	0.316	0.337	0.350	0.352	0.357	0.343	0.314	0.272	N/A	N/A			
	taud	1.901	2.021	2.052	2.118	2.216	2.396	2.441	2.465	2.497	2.166	N/A	N/A			
	Ebn at Noon	6	143	211	249	262	267	262	252	228	142	N/A	0			
	Edh at Noon	1	14	27	35	36	31	29	25	18	12	N/A	0			
	Edh at Noon	1	14	27	35	36	31	29	25	18	12	N/A	0			
(44) All-Sky Solar Radiation	RadAvg	4	104	506	1119	1550	1552	1428	1012	533	161	18	0			
	RadStd	0	16	44	76	115	146	128	79	47	20	2	0			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page