

SORKJOSEN, Norway

WMO: 010460

Lat: 69.787N

Lon: 20.959E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.2	5.5	-7.7	3.6	2.6	-3.1	4.7	6.4	35.2	25.6	32.3	25.2	13.3	150	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	71.1	59.2	67.5	57.8	64.3	56.2	60.8	68.6	58.9	66.0	57.0	63.3	12.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.1	69.7	64.4	55.2	64.9	62.4	53.4	60.8	60.0	26.9	68.9	25.7	66.3	24.4	63.2	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.1	24.9	21.6	-3.4	79.0	5.4	5.3	-7.3	82.8	-10.4	85.9	-13.5	88.9	-17.4	92.7
			-4.1	63.8	5.2	3.3	-7.8	66.1	-10.9	68.0	-13.8	69.9	-17.5	72.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.4	22.0	21.8	27.5	34.6	43.3	48.7	54.9	53.1	47.8	37.8	29.6	27.2		
	DBStd	13.37	8.87	9.68	7.97	5.63	6.00	5.34	5.84	5.47	5.62	6.58	6.83	7.74		
	HDD50	4976	867	790	699	462	222	86	14	28	106	383	612	707		
	HDD65	10064	1332	1210	1164	912	672	490	319	371	516	844	1062	1172		
	CDD50	395	0	0	0	0	15	47	165	123	41	4	0	0		
	CDD65	8	0	0	0	0	0	1	5	2	0	0	0	0		
	CDH74	59	0	0	0	0	0	11	39	9	0	0	0	0		
	CDH80	13	0	0	0	0	0	1	9	3	0	0	0	0		
	WSAvg	9.2	12.4	12.4	10.1	8.6	8.4	7.8	7.3	6.9	7.4	8.1	10.3	11.4		
	PrecAvg	44.0	4.5	3.6	3.7	2.6	2.4	2.4	3.0	3.3	4.4	5.7	3.6	4.7		
(15) Precipitation	PrecMax	55.7	11.6	7.4	10.9	6.3	5.9	6.6	6.5	8.8	8.3	9.7	9.1	8.1		
	PrecMin	33.3	0.8	1.6	0.9	0.7	0.5	0.9	0.6	1.4	2.2	1.4	0.2	0.9		
	PrecStd	5.7	2.6	1.7	2.2	1.3	1.3	1.3	1.6	1.6	1.7	2.0	2.4	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.7	46.4	48.2	53.6	68.0	74.3	78.7	73.8	67.0	57.6	48.6	47.4		
		MCWB	38.0	38.6	40.2	44.5	53.2	59.5	64.0	59.9	55.9	49.0	41.7	40.8		
	2%	DB	40.0	42.3	44.8	48.4	61.5	66.1	72.6	69.0	62.0	54.1	44.1	43.4		
		MCWB	35.8	37.2	38.2	41.2	50.9	55.5	60.2	58.7	53.2	47.4	39.3	37.8		
	5%	DB	36.6	37.8	41.3	45.3	56.5	61.1	69.0	65.4	59.1	49.9	40.8	40.3		
		MCWB	33.3	34.0	35.7	39.1	47.5	52.3	58.9	57.1	51.9	45.0	36.8	35.3		
	10%	DB	33.4	34.5	38.4	42.9	52.9	57.3	65.5	62.4	56.6	47.1	38.5	37.6		
		MCWB	30.4	31.3	33.8	37.5	45.4	50.3	57.8	55.8	50.5	43.2	34.9	33.8		
	0.4%	WB	38.6	40.1	40.3	44.6	54.8	60.1	66.1	63.2	57.0	49.3	43.0	41.3		
		MCDB	43.4	45.5	47.1	51.7	65.7	71.6	75.9	69.0	65.6	56.4	47.1	46.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.0	37.2	38.5	42.1	51.1	56.1	61.6	59.9	54.2	47.5	39.9	38.2		
		MCDB	39.6	41.9	44.3	47.9	60.4	64.7	69.6	66.9	59.9	53.0	43.8	42.6		
	5%	WB	33.5	34.3	36.0	39.5	48.3	53.5	59.9	57.9	52.6	45.3	37.0	35.9		
		MCDB	36.3	37.4	40.7	44.6	55.3	59.7	67.2	63.9	57.8	49.5	40.3	39.8		
	10%	WB	30.9	31.5	34.0	37.8	46.0	51.2	58.2	56.2	51.2	43.4	35.0	33.8		
		MCDB	33.2	34.4	38.2	42.1	52.2	56.2	64.9	61.6	56.0	47.0	38.3	37.4		
	5% DB	MDBR	10.3	9.9	10.9	11.1	11.7	9.7	11.2	11.8	11.5	8.6	9.1	9.7		
		MCDBR	11.6	13.3	12.1	13.6	18.4	17.4	18.8	16.9	15.2	11.6	10.4	12.5		
		MCWBR	9.0	9.9	8.2	9.0	10.1	9.3	9.0	9.0	8.8	7.6	7.8	8.9		
		MCWBR	11.7	13.4	12.2	12.8	17.7	15.9	16.8	15.4	13.6	11.1	10.2	12.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	9.2	10.3	8.5	8.9	10.4	8.9	9.0	8.8	8.2	7.3	8.1	9.0		
	taub		0.206	0.254	0.306	0.324	0.338	0.339	0.346	0.332	0.307	0.261	N/A	N/A		
		taud	1.925	2.066	2.135	2.223	2.323	2.459	2.489	2.509	2.531	2.196	N/A	N/A		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		4	147	217	255	267	272	265	256	231	145	0	0		
		Edh at Noon	1	13	25	31	32	29	27	24	17	11	0	0		
	RadAvg		3	93	462	1064	1514	1551	1424	997	521	152	0	0		
(45) All-Sky Solar Radiation	RadStd		0	15	43	81	116	139	130	81	46	17	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page