

SORKJOSEN, Norway

WMO: 010460

Lat: 69.787N

Lon: 20.959E

Elev: 5

StdP: 101.27

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.1	-14.7	-22.1	0.5	-16.3	-19.5	0.7	-14.2	15.7	-3.5	14.4	-3.8	5.9	150	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	21.7	15.1	19.7	14.3	18.0	13.4	16.0	20.4	14.9	18.9	13.9	17.4	5.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.0	10.0	18.0	12.9	9.3	16.9	11.9	8.7	15.5	44.8	20.5	41.9	19.0	39.0	17.3	21.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 13.0	11.1	9.7		-19.7	26.1	3.0	2.9	-21.8	28.2	-23.6	30.0	-25.3	31.6	-27.4	33.7	
(5)			DB	-20.1	17.7	2.9	1.8	-22.1	19.0	-23.8	20.0	-25.4	21.0	-27.5	22.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.0	-5.5	-5.7	-2.5	1.4	6.3	9.3	12.7	11.7	8.8	3.2	-1.3	-2.7
	DBStd	7.43	4.93	5.38	4.43	3.13	3.33	2.97	3.25	3.04	3.12	3.66	3.79	4.30
	HDD10.0	2764	482	439	388	257	123	48	8	16	59	213	340	393
	HDD18.3	5591	740	672	647	507	373	272	177	206	287	469	590	651
	CDD10.0	219	0	0	0	0	8	26	92	68	23	2	0	0
	CDD18.3	4	0	0	0	0	0	1	3	1	0	0	0	0
	CDH23.3	33	0	0	0	0	0	6	22	5	0	0	0	0
	CDH26.7	7	0	0	0	0	0	1	5	2	0	0	0	0
(14) Wind	WSAvg	4.1	5.5	5.5	4.5	3.8	3.8	3.5	3.2	3.1	3.3	3.6	4.6	5.1
(15) Precipitation	PrecAvg	1117	114	92	94	65	62	62	76	85	113	144	92	119
	PrecMax	1416	294	188	278	160	149	168	166	224	212	247	230	205
	PrecMin	847	21	41	23	19	13	23	14	35	55	36	6	24
	PrecStd	145	65	42	55	33	33	32	41	41	42	52	60	48
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	8.0	9.0	12.0	20.0	23.5	25.9	23.2	19.5	14.2	9.2	8.6
		MCWB	3.4	3.7	4.6	7.0	11.8	15.3	17.8	15.5	13.3	9.4	5.4	4.9
	2%	DB	4.4	5.7	7.1	9.1	16.4	18.9	22.5	20.6	16.7	12.3	6.7	6.3
		MCWB	2.1	2.9	3.4	5.1	10.5	13.0	15.7	14.8	11.8	8.5	4.1	3.2
	5%	DB	2.5	3.2	5.2	7.4	13.6	16.2	20.6	18.6	15.1	9.9	4.9	4.6
		MCWB	0.7	1.1	2.1	3.9	8.6	11.3	15.0	14.0	11.1	7.2	2.6	1.8
	10%	DB	0.8	1.4	3.5	6.0	11.6	14.1	18.6	16.9	13.7	8.4	3.6	3.1
		MCWB	-0.9	-0.4	1.0	3.0	7.5	10.2	14.4	13.2	10.3	6.2	1.6	1.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	4.5	4.6	7.0	12.7	15.6	19.0	17.3	13.9	9.6	6.1	5.1
		MCDB	6.3	7.5	8.4	10.9	18.7	22.0	24.4	20.5	18.6	13.5	8.4	8.1
	2%	WB	2.2	2.9	3.6	5.6	10.6	13.4	16.4	15.5	12.3	8.6	4.4	3.4
		MCDB	4.2	5.5	6.8	8.8	15.8	18.2	20.9	19.4	15.5	11.7	6.6	5.9
	5%	WB	0.8	1.3	2.2	4.2	9.0	12.0	15.5	14.4	11.4	7.4	2.8	2.1
		MCDB	2.4	3.0	4.8	7.0	12.9	15.4	19.5	17.7	14.3	9.7	4.6	4.3
	10%	WB	-0.6	-0.3	1.1	3.2	7.8	10.6	14.5	13.4	10.6	6.3	1.7	1.0
		MCDB	0.7	1.3	3.5	5.6	11.2	13.4	18.3	16.5	13.3	8.3	3.5	3.0
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	5.5	6.1	6.2	6.5	5.4	6.2	6.6	6.4	4.8	5.0	5.4
		MCDBR	6.5	7.4	6.7	7.5	10.2	9.7	10.5	9.4	8.4	6.4	5.8	6.9
	5% WB	MCWBR	5.0	5.5	4.6	5.0	5.6	5.2	5.0	5.0	4.9	4.2	4.3	4.9
		MCWBR	6.5	7.4	6.8	7.1	9.8	8.9	9.4	8.5	7.6	6.1	5.7	6.8
(40) Clear-Sky Solar Irradiance	taub	taub	0.206	0.254	0.306	0.324	0.338	0.339	0.346	0.332	0.307	0.261	N/A	N/A
		taud	1.925	2.066	2.135	2.223	2.323	2.459	2.489	2.509	2.531	2.196	N/A	N/A
	Edn at Noon	Edn at Noon	14	463	683	805	843	856	836	806	727	456	0	0
		Edh at Noon	3	41	78	98	101	92	86	75	55	35	0	0
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.01	0.29	1.46	3.35	4.77	4.89	4.49	3.14	1.64	0.48	0.00	0.00
	RadStd	RadStd	0.00	0.05	0.14	0.25	0.37	0.44	0.41	0.26	0.14	0.06	0.00	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page