

KAUTOKEINO, Norway

WMO: 010470

Lat: 68.997N

Lon: 23.033E

Elev: 1007

StdP: 14.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.8	-27.3	-36.0	0.7	-32.3	-30.8	1.0	-27.2	26.5	16.8	23.3	18.7	2.6	180	0.791

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	73.8	59.6	69.9	57.7	66.0	55.9	61.8	70.1	59.4	67.0	57.2	64.4	8.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	75.4	64.7	55.8	68.7	62.6	53.7	63.6	60.4	28.1	70.2	26.4	67.3	25.0	64.6	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.1	22.2	16.6	-38.4	78.0	7.1	3.1	-43.5	80.3	-47.6	82.1	-51.6	83.9	-56.8	86.2		
			-38.1	64.3	6.2	2.6	-42.6	66.1	-46.2	67.7	-49.7	69.1	-54.2	71.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	29.1	5.5	6.3	14.6	26.6	38.7	49.1	55.9	51.8	42.7	30.4	16.2	10.0		
	DBStd	20.79	16.37	15.93	13.12	8.83	7.26	6.68	6.23	5.84	6.34	8.73	12.99	15.39		
	HDD50	8017	1380	1225	1096	702	360	97	15	49	232	608	1014	1239		
	HDD65	13105	1845	1645	1561	1152	814	478	288	411	670	1073	1464	1704		
	CDD50	394	0	0	0	0	10	70	198	104	12	0	0	0		
	CDD65	8	0	0	0	0	0	1	6	1	0	0	0	0		
	CDH74	97	0	0	0	0	6	9	69	13	0	0	0	0		
	CDH80	6	0	0	0	0	0	0	5	1	0	0	0	0		
	WSAvg	7.5	6.4	7.1	8.2	7.6	9.1	9.0	8.2	7.3	7.2	7.3	6.2	6.7		
	PrecAvg	17.5	0.9	0.8	0.7	0.7	1.3	2.2	2.8	2.6	1.7	1.5	1.2	1.0		
Precipitation	PrecMax	26.7	1.9	1.6	1.5	1.8	2.9	4.0	5.9	5.3	3.5	3.7	2.2	2.1		
	PrecMin	11.0	0.2	0.2	0.3	0.2	0.2	0.1	0.7	1.3	0.4	0.4	0.3	0.2		
	PrecStd	3.1	0.4	0.4	0.3	0.4	0.8	1.1	1.3	1.1	0.7	0.8	0.6	0.5		
	PrecStd	3.1	0.4	0.4	0.3	0.4	0.8	1.1	1.3	1.1	0.7	0.8	0.6	0.5		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	39.0	40.5	48.3	71.8	75.0	79.6	75.3	62.0	49.9	39.8	40.0		
		MCWB	35.0	34.7	35.4	41.2	56.1	58.1	63.5	59.5	52.4	46.9	37.2	35.8		
	2%	DB	32.8	34.7	37.1	43.9	62.7	70.0	75.5	70.4	58.1	47.3	35.9	35.0		
		MCWB	30.6	31.8	33.3	38.1	50.6	56.3	60.9	58.3	51.5	44.4	34.0	32.6		
	5%	DB	29.3	30.9	34.0	41.2	55.3	65.4	71.6	65.6	55.4	44.2	33.9	32.1		
		MCWB	27.7	29.0	30.7	36.0	46.3	53.8	59.3	56.6	50.5	41.0	32.7	30.4		
	10%	DB	25.7	27.8	31.2	38.6	50.5	61.3	67.7	62.2	52.9	41.3	32.1	29.7		
		MCWB	24.4	26.3	28.6	34.5	43.3	51.9	57.5	54.9	48.9	39.0	30.9	28.2		
	0.4%	WB	35.4	35.3	36.0	41.9	56.8	61.0	65.5	63.6	55.4	48.4	37.8	36.0		
		MCDB	37.6	39.0	39.8	47.7	70.0	71.9	75.7	71.1	58.4	48.9	39.4	39.3		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	31.0	31.8	33.5	39.0	50.7	57.8	63.0	59.9	53.1	44.2	34.4	32.9		
		MCDB	32.7	34.2	36.8	43.0	61.2	66.2	71.9	66.5	56.3	46.8	35.6	34.7		
	5%	WB	27.8	29.2	31.1	36.6	46.9	55.3	60.9	57.6	51.4	41.4	32.8	30.5		
		MCDB	29.3	30.9	33.7	40.1	54.8	63.5	68.9	64.3	54.3	43.7	33.8	32.0		
	10%	WB	24.5	26.3	28.7	34.9	43.8	52.8	58.7	55.6	49.3	39.1	31.0	28.2		
		MCDB	25.6	27.9	31.0	38.2	49.8	60.6	66.0	61.2	52.5	41.2	32.1	29.8		
Mean Daily Temperature Range	5% DB	MDBR	15.6	16.3	18.1	16.0	13.3	13.8	15.1	14.5	12.6	9.6	12.7	14.9		
		MCDBR	12.8	15.8	13.4	14.8	22.7	21.8	22.1	22.6	16.1	10.2	8.5	12.3		
		MCWBR	11.8	14.2	11.0	10.1	13.2	10.8	9.9	12.3	10.6	8.2	7.9	11.6		
	5% WB	MCDBR	12.5	15.4	12.9	12.9	22.3	18.5	18.9	18.9	13.2	9.1	7.8	11.2		
		MCWBR	11.6	13.9	11.0	9.3	13.3	10.2	9.3	11.0	9.5	7.7	7.4	10.6		
		MCWBR	11.6	13.9	11.0	9.3	13.3	10.2	9.3	11.0	9.5	7.7	7.4	10.6		
Clear-Sky Solar Irradiance	taub		0.182	0.235	0.278	0.306	0.326	0.330	0.337	0.322	0.290	0.249	0.183	N/A		
	taud		1.916	2.079	2.176	2.216	2.382	2.485	2.484	2.504	2.552	2.259	1.964	N/A		
	Ebn at Noon		16	168	235	264	273	276	270	261	242	166	14	0		
	Edh at Noon		2	14	24	32	30	29	28	24	17	11	1	0		
All-Sky Solar Radiation	RadAvg		6	134	604	1241	1610	1555	1445	1017	540	170	22	0		
	RadStd		1	11	26	55	149	117	139	75	50	21	3	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	-2.18	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page