

KAUTOKEINO, Norway

WMO: 010470

Lat: 68.997N

Lon: 23.033E

Elev: 307

StdP: 97.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.0	-33.0	-37.8	0.1	-35.7	-34.9	0.1	-32.9	11.9	-8.4	10.4	-7.4	1.2	180	0.791

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	23.2	15.3	21.0	14.3	18.9	13.3	16.5	21.1	15.2	19.4	14.0	18.0	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	10.8	18.2	13.2	9.8	17.0	12.0	9.1	15.8	47.4	21.2	43.6	19.6	40.2	18.1	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.9	7.4	-39.1	25.6	3.9	1.7	-41.9	26.8	-44.2	27.9	-46.4	28.8	-49.3	30.1		
(5)			-38.9	17.9	3.4	1.4	-41.4	19.0	-43.4	19.8	-45.4	20.6	-47.9	21.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.6	-14.7	-14.3	-9.6	-3.0	3.7	9.5	13.3	11.0	5.9	-0.9	-8.8	-12.2		
	DBStd	11.55	9.10	8.85	7.29	4.91	4.03	3.71	3.46	3.24	3.52	4.85	7.22	8.55		
	HDD10.0	4454	767	681	609	390	200	54	8	27	129	338	563	688		
	HDD18.3	7281	1025	914	867	640	452	266	160	228	372	596	813	947		
	CDD10.0	219	0	0	0	0	6	39	110	58	7	0	0	0		
	CDD18.3	4	0	0	0	0	0	1	3	1	0	0	0	0		
	CDH23.3	54	0	0	0	0	3	5	38	7	0	0	0	0		
	CDH26.7	3	0	0	0	0	0	0	3	1	0	0	0	0		
(14) Wind	WSAvg	3.4	2.9	3.2	3.6	3.4	4.1	4.0	3.6	3.3	3.2	3.3	2.8	3.0		
(15) Precipitation	PrecAvg	444	23	21	18	19	32	55	70	65	42	39	30	26		
	PrecMax	677	49	41	39	46	73	102	149	135	89	93	57	54		
	PrecMin	279	5	5	7	4	5	2	17	33	9	7	6	6		
	PrecStd	78	9	9	8	9	20	28	32	28	19	21	14	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.0	3.9	4.7	9.1	22.1	23.9	26.5	24.1	16.6	9.9	4.4	4.4		
		MCWB	1.7	1.5	1.9	5.1	13.4	14.5	17.5	15.3	11.3	8.3	2.9	2.1		
	2%	DB	0.4	1.5	2.8	6.6	17.0	21.1	24.2	21.4	14.5	8.5	2.2	1.7		
		MCWB	-0.8	-0.1	0.7	3.4	10.4	13.5	16.0	14.6	10.8	6.9	1.1	0.4		
	5%	DB	-1.5	-0.6	1.1	5.1	12.9	18.6	22.0	18.6	13.0	6.8	1.0	0.0		
		MCWB	-2.4	-1.7	-0.7	2.2	7.9	12.1	15.2	13.7	10.3	5.0	0.4	-0.9		
	10%	DB	-3.5	-2.3	-0.5	3.7	10.3	16.3	19.8	16.8	11.6	5.2	0.0	-1.3		
		MCWB	-4.2	-3.2	-1.9	1.4	6.3	11.1	14.2	12.7	9.4	3.9	-0.6	-2.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.9	1.9	2.2	5.5	13.8	16.1	18.6	17.6	13.0	9.1	3.2	2.2		
		MCDB	3.1	3.9	4.3	8.7	21.1	22.1	24.3	21.7	14.7	9.4	4.1	4.0		
	2%	WB	-0.5	-0.1	0.8	3.9	10.4	14.3	17.2	15.5	11.7	6.8	1.3	0.5		
		MCDB	0.4	1.2	2.6	6.1	16.2	19.0	22.2	19.1	13.5	8.2	2.0	1.5		
	5%	WB	-2.3	-1.6	-0.5	2.5	8.3	12.9	16.0	14.2	10.8	5.2	0.4	-0.8		
		MCDB	-1.5	-0.6	0.9	4.5	12.6	17.5	20.5	17.9	12.4	6.5	1.0	0.0		
	10%	WB	-4.2	-3.1	-1.8	1.6	6.6	11.6	14.8	13.1	9.6	4.0	-0.6	-2.1		
		MCDB	-3.5	-2.3	-0.5	3.5	9.9	15.9	18.9	16.2	11.4	5.1	0.1	-1.2		
(35) Mean Daily Temperature Range	MDBR		8.7	9.1	10.0	8.9	7.4	7.7	8.4	8.1	7.0	5.3	7.1	8.3		
	5% DB	MCDBR	7.1	8.8	7.4	8.2	12.6	12.1	12.3	12.5	9.0	5.7	4.7	6.8		
		MCWBR	6.6	7.9	6.1	5.6	7.3	6.0	5.5	6.9	5.9	4.6	4.4	6.4		
	5% WB	MCDBR	6.9	8.6	7.1	7.1	12.4	10.3	10.5	10.5	7.3	5.1	4.3	6.2		
		MCWBR	6.4	7.7	6.1	5.2	7.4	5.7	5.2	6.1	5.3	4.3	4.1	5.9		
(40) Clear-Sky Solar Irradiance	taub		0.182	0.235	0.278	0.306	0.326	0.330	0.337	0.322	0.290	0.249	0.183	N/A		
	taud		1.916	2.079	2.176	2.216	2.382	2.485	2.484	2.504	2.552	2.259	1.964	N/A		
	Ebn at Noon		52	531	742	833	862	871	850	823	763	523	43	0		
	Edh at Noon		5	43	76	100	96	90	87	76	55	35	4	0		
(44) All-Sky Solar Radiation	RadAvg		0.02	0.42	1.90	3.91	5.08	4.90	4.55	3.21	1.70	0.54	0.07	0.00		
	RadStd		0.00	0.03	0.08	0.17	0.47	0.37	0.44	0.24	0.16	0.07	0.01	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (38 neighbors)	N/A	N/A	N/A	N/A	-1.21	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page