

HEIMDAL OIL PLATFORM, Norway

WMO: 010875

Lat: 59.567N

Lon: 2.217E

Elev: 90

StdP: 100.25

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.2	1.1	-8.2	1.9	1.3	-6.2	2.3	2.6	30.5	3.0	28.5	3.7	9.8	130	1.025

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	18.2	15.5	17.0	15.0	16.0	14.5	16.2	17.7	15.4	16.6	14.9	15.9	6.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.3	11.0	16.5	15.0	10.8	16.0	14.2	10.2	15.3	45.5	17.6	43.2	16.6	41.8	15.6	19.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	22.3	19.9	DB	-1.2	20.9	1.9	2.3	-2.6	22.5	-3.7	23.9	-4.8	25.2	-6.2	26.8	(4)
(5)			WB	-2.9	17.2	2.1	1.4	-4.4	18.1	-5.7	18.9	-6.8	19.7	-8.4	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	5.1	4.9	5.3	6.6	8.6	11.1	13.4	14.0	12.5	10.1	7.8	6.4		
	DBStd	3.68	1.80	1.81	1.91	1.90	2.25	1.62	2.10	1.43	1.57	1.63	1.73	1.87		
	HDD10.0	807	153	143	146	104	56	7	0	0	1	17	68	112		
	HDD18.3	3469	412	376	404	353	303	218	154	133	174	254	317	370		
	CDD10.0	382	0	0	0	1	12	39	106	126	77	21	1	0		
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	9.8	12.7	11.9	10.0	8.8	8.5	7.7	7.4	7.9	9.2	10.4	10.8	12.5		
(15) Precipitation	PrecAvg	1255	150	126	116	64	47	64	76	92	112	128	135	145		
	PrecMax	1559	215	263	209	104	92	105	134	232	166	224	182	290		
	PrecMin	964	60	61	57	42	21	29	33	37	41	49	63	73		
	PrecStd	153	49	48	39	17	16	19	22	34	34	41	32	43		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	9.1	10.8	13.0	18.2	17.1	21.9	18.9	17.2	14.2	11.6	10.8		
		MCWB	8.6	8.2	7.7	9.1	13.7	13.9	17.9	14.7	14.6	11.8	10.4	9.6		
	2%	DB	8.9	8.2	8.9	11.1	15.0	14.9	19.3	17.6	15.9	13.5	11.1	10.0		
		MCWB	8.3	7.6	7.6	8.3	12.0	12.7	16.6	15.0	14.2	11.6	10.0	9.4		
	5%	DB	8.1	7.9	8.1	9.8	12.9	13.8	17.3	16.8	15.1	12.8	10.7	9.2		
		MCWB	7.5	7.4	7.2	7.9	10.2	12.1	15.6	14.9	13.9	11.2	9.7	8.6		
	10%	DB	7.8	7.2	7.7	8.9	11.1	13.0	16.1	16.0	14.4	12.1	10.2	9.0		
		MCWB	7.1	6.4	6.8	7.4	9.5	11.8	14.8	14.6	13.3	10.6	9.2	8.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	8.3	8.5	9.5	14.3	14.3	18.3	16.7	15.5	13.2	11.2	10.1		
		MCDB	9.0	8.4	9.1	11.3	17.9	16.2	20.6	17.5	16.4	13.7	11.3	10.3		
	2%	WB	8.1	7.7	7.9	8.7	12.1	13.1	16.8	15.7	14.9	12.3	10.6	9.4		
		MCDB	8.4	7.8	8.4	10.2	14.4	14.2	19.0	16.6	15.6	13.1	10.8	9.6		
	5%	WB	7.6	7.2	7.3	8.1	10.7	12.6	15.8	15.2	14.3	11.7	10.0	8.9		
		MCDB	8.0	7.5	7.7	9.1	12.1	13.6	17.4	16.1	14.9	12.5	10.3	9.1		
	10%	WB	7.0	6.6	6.8	7.6	9.9	12.1	15.1	14.8	13.7	11.1	9.4	8.3		
		MCDB	7.4	7.1	7.3	8.4	10.8	13.0	16.2	15.8	14.5	11.7	10.0	8.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	2.4	2.3	2.6	2.6	2.2	2.3	2.2	2.1	2.2	2.3	2.6		
		MCDBR	2.7	2.8	2.8	4.1	5.8	3.8	4.1	3.7	2.9	3.1	2.5	2.7		
	5% WB	MCWBR	3.5	3.0	2.7	2.5	3.5	2.5	2.8	2.7	2.5	2.8	2.9	3.5		
		MCWBR	2.6	2.5	2.2	3.1	4.9	3.3	3.8	2.7	2.6	2.7	2.3	2.5		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.348	0.363	0.378	0.366	0.363	0.378	0.374	0.363	0.347	0.323	0.434		
		taud	2.110	2.237	2.301	2.320	2.425	2.467	2.440	2.450	2.448	2.335	2.174	2.566		
	Ebn at Noon		418	641	762	821	864	871	846	821	765	640	428	308		
		Edh at Noon	49	73	92	106	103	100	101	93	79	65	45	35		
(44) All-Sky Solar Radiation	RadAvg		0.26	0.83	2.06	3.82	5.21	5.26	4.84	3.83	2.41	1.15	0.39	0.16		
	RadStd		0.03	0.13	0.19	0.35	0.38	0.53	0.40	0.27	0.17	0.10	0.04	0.01		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (22 neighbors)		N/A	+0.65	N/A	N/A	N/A	N/A	-83	-118	N/A	N/A

Nomenclature: See separate page