

NORNE OIL PLATFORM, Norway

WMO: 010876

Lat: 66.017N

Lon: 8.083E

Elev: 295

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	28.1	29.9	15.5	12.2	32.1	17.5	13.4	33.2	63.1	40.1	58.3	41.3	26.9	90	1.108

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	61.1	57.8	59.3	56.4	57.6	55.0	58.5	61.1	57.2	59.5	55.8	57.9	16.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.2	70.7	59.9	55.7	66.7	58.4	55.0	65.1	57.7	25.5	60.4	24.7	59.4	23.7	57.5	62.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 52.1	47.2	43.1	DB	24.4	65.0	1.7	3.5	23.1	67.5	22.1	69.5	21.1	71.5	19.9	74.0	(4)
(5)			WB	22.9	59.6	1.4	2.5	21.9	61.4	21.1	62.9	20.3	64.3	19.3	66.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	38.1	38.7	37.8	40.4	44.2	48.2	53.0	54.2	51.8	46.5	42.4	39.9
	DBStd	6.89	4.28	3.82	4.47	4.17	3.77	3.26	3.62	2.90	2.90	3.71	4.09	3.66
	HDD50	2289	369	317	378	289	183	73	7	1	15	117	228	312
	HDD65	7433	834	737	843	739	644	503	372	336	395	575	678	777
	CDD50	329	0	0	0	0	4	19	99	130	70	7	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	22.5	26.8	26.8	26.3	20.9	19.1	18.5	16.8	18.1	20.5	24.0	24.8	27.7
Precipitation	PrecAvg	39.5	5.0	3.8	3.2	2.2	1.7	1.9	2.4	3.1	3.7	3.9	4.0	4.5
	PrecMax	48.8	9.5	6.7	5.4	3.9	2.3	3.4	3.6	4.9	6.0	7.4	6.1	8.3
	PrecMin	23.8	2.8	1.1	0.9	1.1	0.9	0.8	0.8	1.5	1.4	1.3	0.9	1.5
	PrecStd	5.9	1.8	1.5	1.3	0.7	0.4	0.6	0.7	1.0	1.2	1.7	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	46.8	46.7	51.6	57.1	57.6	64.8	62.8	59.1	55.0	50.4	48.5
		MCWB	45.5	45.3	43.9	45.6	53.1	53.5	60.3	58.6	55.5	51.5	48.5	47.0
	2%	DB	46.5	46.3	46.2	49.6	52.0	55.5	62.4	61.0	57.5	53.5	50.0	46.8
		MCWB	45.1	44.8	44.2	45.9	48.8	52.3	59.4	57.6	54.3	50.0	48.0	45.3
	5%	DB	45.0	44.9	44.9	46.6	50.1	53.8	60.4	59.4	56.9	52.0	48.5	46.5
		MCWB	43.1	42.8	42.9	44.7	47.7	51.2	57.5	56.6	53.9	49.3	47.0	44.9
	10%	DB	44.5	44.5	44.4	44.9	48.4	53.2	58.6	58.7	55.5	51.4	48.0	45.0
		MCWB	42.4	42.2	42.4	43.4	46.7	50.7	56.0	56.1	53.1	48.9	46.4	42.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	45.8	45.5	46.8	52.9	54.8	61.3	59.5	56.0	52.2	49.7	47.6
		MCDB	46.6	46.1	45.7	48.5	57.3	57.5	64.5	62.2	57.9	54.1	50.2	47.7
	2%	WB	45.0	44.4	44.3	45.7	49.8	53.0	59.3	58.4	55.2	51.0	48.3	46.4
		MCDB	45.7	45.3	45.0	47.4	51.5	55.2	62.2	60.8	57.2	52.7	48.9	46.7
	5%	WB	43.6	43.1	43.1	44.8	47.9	52.1	57.4	57.4	54.6	50.1	47.3	45.1
		MCDB	44.8	44.5	44.5	45.9	49.2	54.0	59.8	59.7	56.6	51.5	48.3	46.0
	10%	WB	42.1	41.9	41.8	43.8	46.7	51.1	56.0	56.2	53.9	49.2	46.0	43.0
		MCDB	43.9	43.8	43.8	45.0	47.8	52.9	58.1	58.4	55.9	50.8	47.3	44.9
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.0	5.4	4.3	3.9	3.4	3.5	3.4	3.3	3.8	4.7	5.2
		MCDBR	5.8	5.3	5.5	4.5	5.9	5.5	6.6	4.8	4.2	3.6	4.4	6.3
		MCWBR	7.1	6.1	6.6	4.0	4.3	4.0	4.5	3.8	4.1	4.4	5.0	7.2
	5% WB	MCDBR	5.7	5.6	5.3	4.5	5.0	5.4	6.1	4.7	3.8	3.6	4.6	6.4
		MCWBR	7.2	6.8	7.0	4.8	4.5	4.1	4.3	4.0	4.3	4.9	5.7	7.9
Clear-Sky Solar Irradiance	taub	0.376	0.322	0.340	0.357	0.350	0.346	0.354	0.349	0.336	0.317	0.359	0.373	
	taud	2.392	2.170	2.297	2.356	2.455	2.504	2.502	2.509	2.495	2.279	2.434	2.367	
	Ebn at Noon	54	164	228	255	271	275	268	258	233	166	56	9	
	Edh at Noon	7	17	25	30	30	29	28	25	21	15	6	3	
All-Sky Solar Radiation	RadAvg	20	129	481	1020	1508	1608	1434	1087	642	235	40	3	
	RadStd	2	16	47	93	85	179	151	94	66	38	5	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page