

SNORRE A OIL PLATFORM, Norway

WMO: 010878

Lat: 61.450N

Lon: 2.133E

Elev: 295

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	32.2	34.0	17.5	13.4	35.2	20.8	15.8	36.5	66.4	42.6	60.3	43.0	25.4	0	1.166

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.6	64.3	59.7	61.2	57.7	60.4	57.2	60.1	63.5	58.8	61.3	57.5	59.9	19.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	74.8	61.6	57.3	70.9	60.2	55.8	67.0	58.6	26.5	63.7	25.7	60.8	25.0	59.5	67.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 59.6	52.8	47.7	DB	28.4	69.6	2.5	3.5	26.6	72.1	25.1	74.2	23.7	76.2	21.8	78.8	(4)
(5)			WB	26.0	62.0	2.6	2.5	24.1	63.9	22.5	65.3	21.1	66.8	19.2	68.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	41.9	41.8	41.9	43.7	47.0	51.1	55.4	56.6	53.7	49.7	45.8	43.6
	DBStd	6.30	3.54	3.35	3.86	3.98	3.85	2.81	3.88	2.67	2.88	3.22	3.90	3.73
	HDD50	1431	252	230	252	191	106	19	1	0	5	43	132	200
	HDD65	6317	717	650	717	639	558	418	301	262	339	475	576	665
	CDD50	592	0	0	0	2	13	51	168	203	116	33	6	0
	CDD65	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	25.1	29.8	30.1	26.5	23.1	21.7	21.2	19.1	20.5	23.7	26.2	28.0	31.8
Precipitation	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	48.6	50.1	53.9	60.8	60.4	70.1	65.9	61.0	57.2	53.9	51.7
		MCWB	47.5	46.8	47.2	47.9	55.2	55.9	61.9	59.0	56.9	53.0	51.0	49.5
	2%	DB	48.5	48.4	48.5	51.8	55.7	57.3	66.3	62.9	59.2	55.6	52.2	50.3
		MCWB	46.8	46.7	46.5	47.1	50.7	53.8	60.8	58.5	55.9	51.8	49.7	48.8
	5%	DB	48.2	47.9	48.1	49.9	53.4	55.6	62.7	61.2	58.6	54.0	51.9	49.9
		MCWB	46.7	46.2	46.3	46.7	49.4	52.6	59.2	57.6	55.6	50.7	49.5	48.5
	10%	DB	46.8	46.6	46.7	48.4	51.6	54.0	60.6	60.5	57.4	53.7	51.4	48.5
		MCWB	44.8	44.6	44.4	46.3	48.6	51.6	57.7	57.2	55.0	50.5	49.0	46.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.4	47.6	48.2	49.5	55.3	56.2	62.9	60.3	58.3	54.6	52.5	50.2
		MCDB	48.5	48.0	48.5	51.8	59.9	59.1	67.7	63.2	60.6	56.4	54.7	50.4
	2%	WB	47.4	46.9	47.3	48.2	51.9	54.7	61.3	59.4	57.1	53.1	51.3	49.2
		MCDB	48.1	47.5	48.0	49.4	54.8	57.1	65.8	62.1	58.8	54.8	52.5	49.7
	5%	WB	46.4	45.7	46.3	47.3	50.3	53.6	59.6	58.6	56.3	52.2	50.4	48.3
		MCDB	47.6	46.9	47.4	48.8	51.8	55.5	62.8	61.0	58.1	54.1	51.6	48.9
	10%	WB	45.1	44.6	44.7	46.4	49.3	52.7	58.0	57.5	55.6	51.4	49.2	47.1
		MCDB	46.7	46.2	46.3	48.2	50.7	54.7	60.4	60.0	57.5	53.3	50.7	48.4
Mean Daily Temperature Range	5% DB	MDBR	4.7	4.6	4.7	4.6	4.7	3.9	4.6	4.6	3.9	4.0	4.4	5.1
		MCDBR	4.6	4.5	5.0	5.8	7.3	6.1	8.1	6.8	4.7	4.2	4.4	5.3
		MCWBR	5.9	5.3	5.7	4.1	5.0	4.5	4.6	4.7	3.7	4.3	5.0	6.9
	5% WB	MCDBR	4.4	4.7	4.7	4.5	6.1	5.7	7.2	6.0	4.3	4.3	4.1	5.1
		MCWBR	5.9	6.0	6.2	4.4	4.9	4.4	4.6	4.9	4.2	5.0	5.4	7.0
Clear-Sky Solar Irradiance	taub	0.324	0.349	0.362	0.377	0.365	0.357	0.374	0.365	0.359	0.340	0.311	0.373	
	taud	2.062	2.196	2.282	2.314	2.422	2.481	2.451	2.475	2.443	2.319	2.126	2.293	
	Ebn at Noon	109	190	236	258	272	276	267	260	238	193	114	66	
	Edh at Noon	14	22	28	33	32	31	31	28	24	19	12	8	
All-Sky Solar Radiation	RadAvg	57	210	569	1121	1570	1625	1463	1151	693	320	90	35	
	RadStd	7	28	76	108	108	185	121	102	57	44	13	3	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)	N/A	+1.21	N/A	N/A	N/A	N/A	N/A	-196	-299	N/A	N/A

Nomenclature: See separate page