

MAKKAUR FYR, Norway

WMO: 010920

Lat: 70.707N

Lon: 30.079E

Elev: 9

StdP: 101.22

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.9	-10.9	-17.3	0.8	-11.8	-15.0	1.0	-10.4	25.4	-13.2	24.0	-10.7	10.3	220	0.887

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.5	20.6	14.3	17.8	13.2	15.4	11.8	14.9	19.9	13.5	17.3	12.1	15.0	5.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.0	17.0	11.1	8.2	15.2	10.2	7.7	13.7	41.8	20.0	38.0	17.5	34.3	15.1	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 19.3	16.3	14.0	DB	-15.3	24.7	2.7	3.2	-17.3	26.9	-18.9	28.8	-20.4	30.6	-22.3	32.9	(4)
(5)			WB	-15.6	16.3	2.4	2.1	-17.3	17.8	-18.7	19.0	-20.1	20.2	-21.8	21.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-4.0	-4.1	-2.8	0.3	4.1	7.2	10.8	10.4	8.1	3.7	-0.2	-1.9	(6)
(7)		DBStd	6.15	3.59	3.77	3.08	3.15	3.09	3.15	3.60	2.82	2.81	3.06	2.79	3.07	(7)
(8)		HDD10.0	2798	433	394	397	289	186	98	30	28	72	195	307	368	(8)
(9)		HDD18.3	5718	692	628	656	539	442	334	237	248	307	452	557	626	(9)
(10)		CDD10.0	124	0	0	0	0	2	13	54	39	14	1	0	0	(10)
(11)		CDD18.3	4	0	0	0	0	0	0	3	1	0	0	0	0	(11)
(12)		CDH23.3	26	0	0	0	0	0	1	23	2	0	0	0	0	(12)
(13)		CDH26.7	3	0	0	0	0	0	0	3	0	0	0	0	0	(13)
(14)	Wind	WSAvg	6.3	8.0	8.3	8.1	6.2	5.1	4.7	4.3	4.2	5.1	6.3	7.1	7.9	(14)
(15)	Precipitation	PrecAvg	578	45	40	39	32	31	48	58	66	56	74	45	40	(15)
(16)		PrecMax	690	64	63	59	54	62	92	140	145	91	114	79	55	(16)
(17)		PrecMin	515	15	14	14	10	13	8	12	28	34	28	9	13	(17)
(18)		PrecStd	56	14	13	13	13	12	29	35	32	16	24	19	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.6	4.7	5.2	9.5	15.5	20.8	26.3	22.5	17.1	12.3	8.0	6.2	(19)
(20)			MCWB	3.9	2.9	2.6	6.0	9.2	13.9	17.1	15.5	12.5	9.5	5.9	4.3	(20)
(21)		2%	DB	3.6	3.5	4.0	7.4	12.4	16.7	22.1	19.0	15.4	10.5	6.0	4.6	(21)
(22)			MCWB	1.9	1.9	2.1	4.4	7.9	12.1	14.8	14.0	11.8	8.1	4.5	2.9	(22)
(23)		5%	DB	2.3	2.4	2.6	5.7	10.4	13.9	19.1	16.5	13.8	9.2	4.5	3.3	(23)
(24)			MCWB	0.7	0.9	0.9	3.3	6.9	10.0	14.1	12.6	10.8	7.1	3.0	1.6	(24)
(25)		10%	DB	1.2	1.1	1.6	4.4	8.6	11.1	16.2	14.3	12.2	7.9	3.5	2.3	(25)
(26)			MCWB	-0.3	-0.3	0.1	2.4	5.6	8.3	12.7	11.4	9.5	6.2	2.1	0.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	3.4	3.2	6.3	9.9	15.0	17.8	16.2	13.4	9.7	6.2	4.6	(27)
(28)			MCDWB	5.5	4.5	4.8	9.2	14.1	19.9	25.1	21.3	16.6	11.9	7.7	6.2	(28)
(29)		2%	WB	2.0	2.0	2.1	4.7	8.4	12.6	15.6	14.3	12.1	8.2	4.6	3.1	(29)
(30)			MCDWB	3.4	3.2	3.8	7.1	12.0	16.6	21.1	18.2	14.9	10.2	6.0	4.6	(30)
(31)		5%	WB	0.9	1.0	1.0	3.5	7.1	10.2	14.2	12.8	10.9	7.3	3.2	1.8	(31)
(32)			MCDWB	2.2	2.4	2.5	5.4	10.4	13.5	18.8	15.7	13.4	9.0	4.4	3.2	(32)
(33)		10%	WB	-0.2	-0.2	0.1	2.5	5.9	8.4	12.5	11.6	9.8	6.4	2.3	0.9	(33)
(34)			MCDWB	1.1	1.0	1.5	4.1	8.3	10.7	16.0	14.0	11.9	8.0	3.5	2.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	4.5	4.0	3.8	3.7	3.6	4.5	3.9	3.4	3.1	3.7	4.2	(35)
(36)			MCDBR	5.4	4.9	4.1	4.3	7.1	8.8	10.5	8.5	5.5	3.6	3.9	4.8	(36)
(37)			MCWBR	4.8	4.4	3.6	3.0	4.3	5.3	5.2	4.7	3.5	2.8	3.6	4.2	(37)
(38)		5% WB	MCDWR	5.3	4.9	3.9	4.0	6.8	8.3	9.8	7.9	5.0	3.3	3.9	4.7	(38)
(39)			MCWBR	4.8	4.5	3.7	3.0	4.3	5.2	5.4	4.8	3.5	2.8	3.7	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.261	0.314	0.335	0.350	0.341	0.357	0.344	0.315	0.266	N/A	N/A	(40)	
(41)		taud	N/A	2.058	2.176	2.269	2.369	2.482	2.472	2.490	2.503	2.154	N/A	N/A	(41)	
(42)		Ebn at Noon	0	409	662	787	826	851	818	784	699	397	0	0	(42)	
(43)		Edh at Noon	0	38	73	93	96	89	87	76	55	32	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.21	1.23	2.83	4.05	4.71	4.23	2.87	1.50	0.39	0.00	0.00	(44)	
(45)		RadStd	0.00	0.03	0.10	0.22	0.46	0.34	0.38	0.29	0.14	0.04	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page