

SKLINNA FYR, Norway

WMO: 011020

Lat: 65.202N

Lon: 10.996E

Elev: 52

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.3	22.9	8.8	8.7	21.2	12.2	10.3	24.4	53.4	35.4	50.2	35.4	19.1	140	0.950

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	66.9	59.6	63.9	58.2	61.7	57.0	60.6	65.4	59.0	63.1	57.5	61.0	13.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	72.7	63.2	56.8	68.9	61.4	55.5	65.7	59.8	26.8	65.6	25.8	63.3	24.8	61.3	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.9	43.4	38.8	17.6	70.9	5.0	3.3	13.9	73.3	11.0	75.3	8.2	77.2	4.5	79.6		
(5)			15.2	62.1	4.3	2.8	12.2	64.1	9.6	65.8	7.2	67.4	4.1	69.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	35.4	34.0	35.6	40.1	45.4	50.1	55.0	56.1	52.3	45.8	40.1	36.8		
	DBStd	9.04	5.06	6.08	4.86	4.06	4.58	4.39	4.46	4.08	3.89	4.55	5.14	5.72		
	HDD50	2728	453	448	447	297	157	50	5	1	20	142	298	410		
	HDD65	7687	918	868	912	747	607	447	311	278	380	596	748	875		
	CDD50	521	0	0	0	0	15	54	161	190	90	11	0	0		
	CDD65	4	0	0	0	0	0	0	2	2	0	0	0	0		
	CDH74	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	19.4	25.0	23.6	21.5	17.0	15.5	14.8	13.7	14.2	17.9	21.4	23.5	24.7		
	PrecAvg	63.0	6.7	6.0	5.7	3.9	3.1	3.5	3.7	4.4	6.0	6.4	5.9	7.6		
(15) Precipitation	PrecMax	81.1	12.5	13.2	11.0	7.1	5.6	6.5	7.4	8.0	12.2	11.0	11.6	11.9		
	PrecMin	48.7	1.2	1.1	2.1	1.3	1.5	1.3	1.7	1.3	1.7	2.1	1.1	3.0		
	PrecStd	8.6	2.8	2.8	2.4	1.6	1.0	1.5	1.5	1.7	2.9	2.4	3.0	2.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.8	45.5	46.0	53.1	63.0	67.0	72.2	70.4	63.6	56.3	51.6	47.9		
		MCWB	43.6	43.7	41.9	45.8	53.4	57.0	62.0	61.7	57.6	51.1	48.4	45.9		
	2%	DB	44.7	44.1	44.4	49.4	58.2	62.1	67.5	66.7	60.9	54.5	49.7	46.7		
		MCWB	42.9	42.4	42.0	44.1	51.0	55.3	60.4	60.0	55.7	50.3	47.0	44.8		
	5%	DB	43.5	42.9	43.4	46.8	54.5	59.0	64.0	63.9	59.0	53.0	48.3	45.5		
		MCWB	41.5	41.1	41.0	42.7	49.1	53.9	58.5	58.9	54.4	49.6	45.6	43.3		
	10%	DB	42.2	41.5	42.2	45.1	51.6	56.2	61.1	61.9	57.4	51.6	46.8	44.1		
		MCWB	40.0	39.3	39.9	42.0	47.3	52.5	57.0	57.8	53.7	48.6	43.9	41.7		
	0.4%	WB	44.7	44.2	44.0	46.6	54.2	58.3	63.2	62.9	59.2	52.9	49.6	46.8		
		MCDB	45.3	44.9	44.5	51.6	61.5	64.3	70.4	68.5	62.2	54.4	50.9	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.2	42.8	42.7	44.8	51.5	55.9	60.6	61.0	56.4	51.3	47.5	45.3		
		MCDB	44.2	43.8	43.9	47.8	57.1	60.9	66.4	65.3	59.5	53.5	49.2	46.4		
	5%	WB	41.9	41.4	41.4	43.7	49.5	54.3	58.9	59.5	55.2	50.2	46.0	43.7		
		MCDB	43.3	42.8	43.0	46.1	54.0	58.4	63.3	63.2	58.0	52.4	48.1	45.2		
	10%	WB	40.3	39.5	40.1	42.7	47.7	52.8	57.4	58.1	54.1	49.1	44.3	42.1		
		MCDB	42.0	41.3	42.0	44.7	51.0	56.0	60.8	61.4	56.9	51.5	46.7	43.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.2	5.1	5.4	6.1	5.3	5.6	5.3	4.6	4.3	4.6	5.1		
		MCDBR	6.3	5.9	5.5	7.2	11.0	10.6	11.1	8.8	6.3	5.0	4.9	5.8		
		MCWBR	6.7	6.3	5.3	4.7	5.9	5.5	5.7	4.7	4.2	4.6	5.1	6.2		
		MCDBR	6.2	5.8	5.3	6.0	10.0	9.3	9.9	7.8	5.9	4.7	5.1	6.0		
	5% WB	MCWBR	6.8	6.6	5.6	4.5	5.8	5.5	5.4	4.7	4.6	4.7	5.8	6.6		
(40) Clear-Sky Solar Irradiance	taub		0.367	0.314	0.337	0.358	0.354	0.352	0.359	0.348	0.338	0.314	0.345	0.363		
	taud		2.479	2.213	2.312	2.368	2.451	2.490	2.498	2.521	2.515	2.358	2.474	2.433		
	Ebn at Noon		76	177	233	257	271	274	268	260	236	180	75	21		
	Edh at Noon		7	18	25	30	30	30	29	25	21	15	7	3		
(44) All-Sky Solar Radiation	RadAvg		28	154	517	1061	1495	1619	1491	1150	640	259	51	8		
	RadStd		3	24	78	104	90	193	160	109	81	44	9	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page