

SKROVA FYR, Norway

WMO: 011600

Lat: 68.153N

Lon: 14.649E

Elev: 11

StdP: 101.19

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.8	-5.6	-13.2	1.2	-5.2	-11.6	1.4	-4.3	19.4	3.3	17.7	3.1	6.6	50	0.816

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	21.4	14.9	19.5	14.0	17.9	13.3	15.9	19.9	14.8	18.1	14.0	16.9	4.8	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.0	17.1	13.2	9.5	16.3	12.4	9.0	15.4	44.5	20.1	41.5	18.2	39.2	17.0	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.7	12.9	-7.9	23.8	1.9	2.6	-9.2	25.7	-10.3	27.2	-11.3	28.7	-12.7	30.5		
(5)			-9.1	16.9	1.6	1.5	-10.3	18.0	-11.2	18.8	-12.2	19.6	-13.4	20.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	0.4	-0.2	0.6	3.1	6.8	10.4	13.5	13.2	10.5	6.4	3.6	1.8
	DBStd	5.60	3.01	2.95	2.50	2.56	3.07	3.19	2.95	2.55	2.58	2.80	2.79	3.03
	HDD10.0	1813	299	286	291	209	109	31	2	2	25	114	193	253
	HDD18.3	4553	557	519	549	458	357	239	154	159	236	369	443	512
	CDD10.0	309	0	0	0	1	11	43	111	102	39	3	0	0
	CDD18.3	7	0	0	0	0	0	1	4	2	0	0	0	0
	CDH23.3	15	0	0	0	0	0	2	12	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
	WSAvg	6.2	6.9	7.1	6.4	5.9	5.6	5.4	4.9	5.4	6.1	6.7	6.8	7.4
(15) Precipitation	PrecAvg	1695	190	160	154	106	86	74	89	102	165	184	174	188
	PrecMax	2149	355	261	219	180	159	196	191	247	256	353	446	363
	PrecMin	1323	3	73	54	26	27	12	26	51	78	81	35	24
	PrecStd	215	81	51	51	38	36	47	46	46	54	75	103	86
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	6.0	6.4	12.2	19.0	22.3	24.9	22.5	17.9	13.7	10.3	8.2
		MCWB	5.3	4.7	3.9	6.9	11.0	14.1	17.5	16.0	12.8	9.8	8.2	6.6
	2%	DB	6.1	5.2	5.4	9.7	15.7	19.7	22.0	20.4	16.2	12.0	9.3	7.2
		MCWB	4.7	3.9	3.7	5.6	9.7	12.9	15.5	14.7	11.9	9.2	7.4	5.8
	5%	DB	5.3	4.6	4.8	7.6	13.2	17.5	20.0	18.7	15.0	10.9	8.5	6.6
		MCWB	4.0	3.3	3.3	4.4	8.4	11.9	14.9	14.1	11.3	8.7	6.7	5.0
	10%	DB	4.5	3.8	4.1	6.1	11.1	15.3	18.1	17.1	13.8	10.0	7.6	5.9
		MCWB	3.2	2.6	2.8	4.0	7.3	11.0	13.8	13.3	11.0	8.1	5.7	4.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.4	4.9	7.2	12.0	15.2	18.0	16.9	13.9	10.6	8.8	7.4
		MCDB	6.5	5.7	5.4	11.7	17.9	20.5	23.9	21.0	16.4	12.5	9.7	7.7
	2%	WB	5.2	4.4	4.2	6.0	10.1	13.6	16.4	15.7	12.7	9.9	8.0	6.4
		MCDB	5.8	4.9	5.0	8.5	14.8	18.3	21.1	19.2	14.7	11.4	9.1	7.1
	5%	WB	4.3	3.5	3.7	5.1	8.9	12.4	15.3	14.6	12.0	9.2	7.0	5.3
		MCDB	5.1	4.3	4.6	6.7	12.9	16.5	18.9	17.6	13.9	10.6	8.2	6.4
	10%	WB	3.4	2.6	3.0	4.5	7.7	11.4	14.3	13.9	11.4	8.4	6.0	4.4
		MCDB	4.5	3.6	4.1	5.8	10.4	14.9	17.3	16.5	13.4	9.9	7.3	5.7
(35) Mean Daily Temperature Range	5% DB	MDBR	2.8	2.7	2.5	2.9	3.5	3.6	3.9	3.3	2.6	2.4	2.6	2.7
		MCDBR	3.2	3.6	2.9	4.3	6.0	6.3	7.2	5.7	3.9	2.7	3.1	3.5
		MCWBR	3.1	3.6	2.7	2.5	3.0	3.1	3.3	2.6	2.1	2.3	3.0	3.7
	5% WB	MCDBR	3.0	3.5	2.8	3.4	5.7	5.6	6.5	4.7	3.3	2.6	3.1	3.6
		MCWBR	3.3	3.7	2.8	2.4	3.1	3.3	3.4	2.7	2.3	2.7	3.3	3.9
(40) Clear-Sky Solar Irradiance	taub	0.367	0.291	0.323	0.341	0.345	0.343	0.349	0.340	0.326	0.295	0.349	N/A	
	taud	2.552	2.159	2.276	2.389	2.460	2.509	2.522	2.531	2.528	2.276	2.520	N/A	
	Ebn at Noon	106	490	705	810	849	861	843	810	724	487	91	0	
	Edh at Noon	13	46	74	87	91	89	86	76	59	40	11	0	
(44) All-Sky Solar Radiation	RadAvg	0.03	0.33	1.43	3.10	4.40	4.85	4.46	3.26	1.72	0.59	0.08	0.00	
	RadStd	0.00	0.07	0.21	0.29	0.34	0.69	0.49	0.34	0.17	0.12	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page