

DIVIDALEN II, Norway

WMO: 011980

Lat: 68.782N

Lon: 19.702E

Elev: 669

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.9	-12.9	-22.2	1.7	-16.9	-17.7	2.1	-12.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	76.9	60.0	72.3	58.1	67.9	55.7	62.0	73.6	59.8	69.0	57.6	65.4	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	72.2	65.2	55.4	67.0	63.1	53.5	62.4	61.2	28.0	74.3	26.5	68.5	25.1	65.4	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	-22.0	83.3	3.3	4.5	-24.4	86.5	-26.3	89.2	-28.2	91.7	-30.6	95.0		
(5)			-23.0	63.5	3.7	4.4	-25.6	66.7	-27.8	69.3	-29.8	71.7	-32.5	74.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	12.7	15.2	20.5	31.2	41.3	48.6	56.1	51.9	45.0	32.7	22.4	17.0		
	DBStd	17.22	11.95	11.77	10.64	7.53	7.10	6.28	6.35	5.56	5.99	8.07	10.23	11.81		
	HDD50	6612	1156	975	913	564	287	101	13	45	171	536	828	1023		
	HDD65	11698	1621	1395	1378	1014	736	494	285	407	601	1001	1278	1488		
	CDD50	402	0	0	0	0	16	58	203	104	20	1	0	0		
	CDD65	12	0	0	0	0	0	1	10	1	0	0	0	0		
	CDH74	276	0	0	0	0	19	37	205	15	0	0	0	0		
	CDH80	53	0	0	0	0	3	5	43	2	0	0	0	0		
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	PrecAvg	22.0	1.9	1.5	1.4	0.9	1.2	2.0	2.9	2.4	2.1	2.2	1.6	1.9		
(15) Precipitation	PrecMax	28.5	4.8	3.2	3.9	3.2	2.4	3.8	5.8	5.9	3.6	3.8	3.7	3.8		
	PrecMin	16.4	0.7	0.2	0.3	0.3	0.2	0.2	1.1	1.1	0.4	0.7	0.3	0.8		
	PrecStd	3.0	1.1	0.7	0.9	0.6	0.6	0.8	1.3	1.0	0.8	0.8	0.9	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.2	44.1	44.0	57.7	76.4	78.4	85.2	76.1	67.1	53.9	45.6	42.2		
		MCWB	34.7	38.5	36.7	44.9	55.4	58.1	63.6	60.7	54.6	46.7	40.6	37.3		
	2%	DB	35.3	39.1	40.9	50.1	67.9	71.8	79.5	69.9	62.3	50.5	41.2	38.3		
		MCWB	32.2	34.2	35.0	40.4	51.2	56.1	62.0	58.0	52.8	45.2	37.8	33.9		
	5%	DB	32.9	35.7	38.5	45.7	61.9	66.5	75.2	66.5	59.0	47.1	37.0	35.7		
		MCWB	30.4	32.5	33.8	37.6	48.8	52.4	60.3	56.5	51.3	43.0	34.3	32.3		
	10%	DB	30.0	32.9	35.7	42.8	55.6	62.4	70.5	63.4	56.3	44.0	34.7	32.7		
		MCWB	28.1	30.4	31.3	36.4	45.3	51.3	57.9	55.3	50.2	40.7	32.3	30.4		
	0.4%	WB	35.0	38.3	37.6	44.6	55.8	60.2	65.8	63.1	56.4	47.5	41.4	37.9		
		MCDB	37.3	42.9	42.5	55.3	73.6	72.9	76.4	70.1	63.9	52.4	44.3	41.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	32.5	34.9	35.6	40.7	52.3	57.4	63.2	59.4	53.8	45.6	38.2	34.3		
		MCDB	34.6	38.4	39.8	47.6	66.4	68.9	76.1	67.2	60.1	50.0	41.1	37.3		
	5%	WB	30.6	32.7	33.9	38.3	49.0	54.9	61.5	57.5	52.2	43.3	34.7	32.4		
		MCDB	32.8	35.6	38.3	44.5	60.5	64.0	73.0	65.0	58.1	46.7	36.8	35.1		
	10%	WB	28.0	30.4	31.7	36.6	45.8	52.1	59.6	55.9	50.6	40.9	32.4	30.4		
		MCDB	30.2	33.1	35.2	42.0	54.8	59.8	68.7	62.4	55.8	44.0	34.4	32.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.4	17.0	20.4	19.8	18.8	17.7	19.7	18.9	17.0	13.1	13.4	15.2		
		MCDBR	13.8	15.7	15.5	22.1	31.7	29.3	29.6	26.0	23.8	14.8	13.3	14.9		
		MCWBR	11.8	12.6	11.0	13.0	16.9	14.8	13.8	15.2	14.8	10.2	10.3	11.5		
		MCDBR	13.7	15.7	14.4	19.3	29.2	24.7	25.8	23.8	20.5	13.7	12.5	14.4		
	5% WB	MCWBR	11.8	12.9	10.7	12.0	15.9	13.1	12.4	14.5	13.3	9.9	9.9	11.5		
(40) Clear-Sky Solar Irradiance	taub		0.185	0.241	0.286	0.310	0.325	0.331	0.337	0.324	0.295	0.251	0.187	N/A		
	taud		1.916	2.086	2.149	2.198	2.286	2.451	2.491	2.509	2.545	2.229	1.962	N/A		
	Ebn at Noon		19	168	232	263	273	276	270	261	240	165	16	0		
	Edh at Noon		2	14	25	32	34	30	28	24	18	12	2	0		
(44) All-Sky Solar Radiation	RadAvg		7	119	536	1153	1555	1548	1424	1021	538	170	23	0		
	RadStd		1	16	48	67	109	149	135	86	49	24	2	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page