

DIVIDALEN II, Norway

WMO: 011980

Lat: 68.782N

Lon: 19.702E

Elev: 204

StdP: 98.90

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.2	(c) -24.9	(d) -30.1	(e) 0.2	(f) -27.2	(g) -27.6	(h) 0.3	(i) -24.8	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	25.0	15.5	22.4	14.5	19.9	13.2	16.7	23.1	15.4	20.5	14.2	18.6	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	10.3	18.4	13.0	9.6	17.3	11.9	8.9	16.2	47.3	23.5	43.8	20.3	40.5	18.6	20.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -30.0	(f) 28.5	(g) 1.8	(h) 2.5	(i) -31.3	(j) 30.3	(k) -32.4	(l) 31.8	(m) -33.4	(n) 33.2	(o) -34.8	(p) 35.0		
(a) N/A	(b) N/A	(c) N/A	(e) -30.5	(f) 17.5	(g) 2.0	(h) 2.4	(i) -32.0	(j) 19.3	(k) -33.2	(l) 20.7	(m) -34.4	(n) 22.1	(o) -35.8	(p) 23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-10.7	-9.3	-6.4	-0.4	5.1	9.2	13.4	11.1	7.2	0.4	-5.3	-8.3
	DBStd	9.57	6.64	6.54	5.91	4.18	3.94	3.49	3.53	3.09	3.33	4.48	5.69	6.56
	HDD10.0	3673	642	542	507	313	159	56	7	25	95	298	460	568
	HDD18.3	6499	901	775	766	563	409	274	158	226	334	556	710	827
	CDD10.0	223	0	0	0	0	9	32	113	58	11	1	0	0
	CDD18.3	7	0	0	0	0	0	1	6	1	0	0	0	0
	CDH23.3	153	0	0	0	0	11	21	114	8	0	0	0	0
	CDH26.7	29	0	0	0	0	2	3	24	1	0	0	0	0
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(15) Precipitation	PrecAvg	560	47	37	35	24	31	50	74	60	54	57	40	49
	PrecMax	725	121	81	99	82	60	97	147	149	92	97	95	97
	PrecMin	416	17	4	8	8	5	6	28	29	11	19	7	21
	PrecStd	77	28	17	24	15	14	21	32	25	20	20	22	20
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.4	6.7	6.7	14.3	24.7	25.8	29.5	24.5	19.5	12.2	7.5	5.6
		MCWB	1.5	3.6	2.6	7.1	13.0	14.5	17.5	15.9	12.5	8.1	4.8	2.9
	2%	DB	1.8	3.9	5.0	10.0	20.0	22.1	26.4	21.1	16.8	10.3	5.1	3.5
		MCWB	0.1	1.2	1.6	4.7	10.7	13.4	16.7	14.5	11.5	7.3	3.2	1.0
	5%	DB	0.5	2.0	3.6	7.6	16.6	19.1	24.0	19.2	15.0	8.4	2.8	2.1
		MCWB	-0.9	0.3	1.0	3.1	9.3	11.4	15.7	13.6	10.7	6.1	1.3	0.2
	10%	DB	-1.1	0.5	2.0	6.0	13.1	16.9	21.4	17.4	13.5	6.7	1.5	0.4
		MCWB	-2.2	-0.9	-0.4	2.4	7.4	10.7	14.4	12.9	10.1	4.9	0.2	-0.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	3.5	3.1	7.0	13.2	15.7	18.8	17.3	13.5	8.6	5.2	3.3
		MCDB	2.9	6.0	5.8	12.9	23.1	22.7	24.7	21.1	17.7	11.4	6.8	5.4
	2%	WB	0.3	1.6	2.0	4.8	11.3	14.1	17.3	15.2	12.1	7.5	3.5	1.3
		MCDB	1.4	3.5	4.3	8.7	19.1	20.5	24.5	19.6	15.6	10.0	5.0	3.0
	5%	WB	-0.8	0.4	1.1	3.5	9.4	12.7	16.4	14.2	11.2	6.3	1.5	0.2
		MCDB	0.5	2.0	3.5	6.9	15.8	17.8	22.8	18.3	14.5	8.2	2.7	1.7
	10%	WB	-2.2	-0.9	-0.2	2.5	7.7	11.2	15.3	13.3	10.3	5.0	0.2	-0.9
		MCDB	-1.0	0.6	1.8	5.5	12.7	15.5	20.4	16.9	13.2	6.7	1.3	0.5
(35) Mean Daily Temperature Range	MDBR		8.0	9.4	11.3	11.0	10.4	9.8	10.9	10.5	9.5	7.3	7.4	8.4
	5% DB	MCDBR	7.7	8.7	8.6	12.3	17.6	16.3	16.4	14.5	13.2	8.2	7.4	8.3
		MCWBR	6.6	7.0	6.1	7.2	9.4	8.2	7.7	8.4	8.2	5.7	5.7	6.4
	5% WB	MCDBR	7.6	8.7	8.0	10.7	16.2	13.7	14.3	13.2	11.4	7.6	6.9	8.0
		MCWBR	6.6	7.2	5.9	6.7	8.9	7.3	6.9	8.1	7.4	5.5	5.5	6.4
(40) Clear-Sky Solar Irradiance	taub		0.185	0.241	0.286	0.310	0.325	0.331	0.337	0.324	0.295	0.251	0.187	N/A
	taud		1.916	2.086	2.149	2.198	2.286	2.451	2.491	2.509	2.545	2.229	1.962	N/A
	Ebn at Noon		61	531	730	828	861	869	851	822	758	520	51	0
	Edh at Noon		6	44	79	102	106	93	87	76	56	37	5	0
(44) All-Sky Solar Radiation	RadAvg		0.02	0.37	1.69	3.63	4.90	4.88	4.49	3.22	1.70	0.54	0.07	0.00
	RadStd		0.00	0.05	0.15	0.21	0.34	0.47	0.43	0.27	0.16	0.07	0.01	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page