

SIHCCAJAVRI, Norway

WMO: 011990

Lat: 68.755N

Lon: 23.539E

Elev: 1253

StdP: 14.04

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.9	-22.4	-32.5	0.9	-26.9	-27.5	1.2	-22.4	30.0	20.9	27.2	19.5	1.2	70	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	73.4	58.5	69.0	57.1	64.9	55.5	60.6	69.4	58.5	65.9	56.7	63.3	9.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.2	73.1	62.7	55.2	67.9	60.9	53.3	63.4	59.4	27.3	69.4	25.9	66.0	24.8	63.2	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.7	21.7	19.1	DB	-36.0	77.4	3.9	4.4	-38.8	80.6	-41.1	83.2	-43.3	85.6	-46.2	88.8	(4)
(5)			WB	-36.2	62.9	3.9	3.0	-39.0	65.0	-41.3	66.8	-43.5	68.5	-46.4	70.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.7	6.1	7.0	11.8	25.0	37.1	47.6	55.4	50.7	43.7	29.6	16.9	11.7		
	DBStd	19.92	12.92	15.24	11.77	8.68	8.61	6.96	6.77	5.68	6.26	8.41	11.25	12.78		
	HDD50	8130	1362	1203	1183	749	409	127	21	62	202	631	994	1187		
	HDD65	13263	1827	1623	1648	1199	864	521	306	443	640	1096	1444	1652		
	CDD50	351	0	0	0	0	10	56	188	85	12	0	0	0		
	CDD65	10	0	0	0	0	1	0	8	1	0	0	0	0		
	CDH74	81	0	0	0	0	6	3	67	5	0	0	0	0		
	CDH80	6	0	0	0	0	0	0	6	0	0	0	0	0		
	WSAvg	8.7	8.3	9.1	9.0	8.2	9.5	10.2	9.1	8.4	8.8	8.0	7.3	8.7		
	PrecAvg	16.9	0.8	0.8	0.7	0.7	1.2	2.2	2.8	2.6	1.7	1.5	1.2	0.9		
	PrecMax	25.2	2.2	1.5	1.3	1.7	2.9	3.7	5.9	5.4	3.9	4.8	2.6	2.2		
(15) Precipitation	PrecMin	11.1	0.2	0.2	0.2	0.2	0.2	0.0	0.8	1.3	0.4	0.4	0.3	0.2		
	PrecStd	3.0	0.4	0.3	0.3	0.4	0.8	1.0	1.3	1.1	0.8	0.9	0.6	0.5		
	DB	34.7	38.5	35.7	46.8	72.6	72.3	80.3	72.7	62.1	48.8	39.5	35.9			
	MCWB	32.2	35.4	31.6	40.4	53.5	58.1	62.1	56.4	52.2	45.0	38.6	34.1			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.0	33.1	33.1	41.0	61.2	67.3	75.5	67.6	58.1	45.3	34.4	32.8			
	2% MCWB	28.8	31.0	30.5	35.8	48.2	54.4	59.1	56.9	51.6	42.8	33.1	31.4			
	5% DB	26.5	29.6	30.9	38.9	56.1	62.8	72.1	63.4	55.4	42.8	32.3	30.5			
	5% MCWB	25.6	28.5	28.8	34.3	46.0	52.5	58.2	55.1	49.9	40.7	31.5	29.4			
	10% DB	23.5	27.3	28.5	36.7	50.2	59.2	67.8	60.6	53.0	40.0	30.7	28.6			
	10% MCWB	22.6	26.4	26.7	32.9	42.9	50.9	57.7	53.9	48.9	38.4	30.1	27.8			
	0.4% WB	32.7	35.6	32.4	40.1	54.0	61.0	64.0	61.6	55.7	45.5	38.7	34.3			
	0.4% MCDB	34.2	38.7	34.7	46.6	69.3	70.1	70.9	65.3	59.7	47.4	39.2	35.7			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	29.1	31.1	30.6	36.3	50.1	57.1	61.8	58.2	52.8	43.2	33.3	31.6			
	2% MCDB	30.3	33.0	32.7	40.4	59.0	63.2	71.3	63.9	56.3	45.2	34.0	32.4			
	5% WB	25.6	28.7	29.0	34.8	46.0	55.0	59.9	56.3	50.9	40.7	31.6	29.6			
	5% MCDB	26.3	29.5	30.7	38.0	54.5	61.3	68.9	61.8	54.4	42.3	32.1	30.5			
	10% WB	22.7	26.4	26.8	33.2	43.5	51.8	58.3	54.6	49.2	38.5	30.1	27.8			
	10% MCDB	23.6	27.3	28.5	35.9	49.6	58.3	66.2	59.5	52.4	39.9	30.7	28.7			
	MDBR	15.3	15.0	20.4	17.1	14.1	13.8	14.7	14.4	11.7	9.6	12.8	14.6			
	5% DB	12.5	13.3	13.3	16.4	22.7	19.8	21.4	19.0	15.7	10.4	8.5	10.0			
(36) Mean Daily Temperature Range	MCDBR	12.0	12.3	11.6	11.9	12.4	10.0	8.6	10.0	9.8	8.5	8.2	9.4			
	5% WB	13.2	12.8	12.5	14.4	21.4	16.7	17.6	16.5	12.9	9.8	8.4	9.7			
	MCWBR	12.8	11.8	11.1	10.6	12.1	9.2	8.4	9.2	8.7	8.1	8.1	9.2			
	MCWBR	12.8	11.8	11.1	10.6	12.1	9.2	8.4	9.2	8.7	8.1	8.1	9.2			
(40) Clear-Sky Solar Irradiance	taub	0.179	0.234	0.275	0.303	0.323	0.327	0.334	0.320	0.288	0.248	0.180	N/A			
	taud	1.916	2.086	2.190	2.221	2.389	2.494	2.488	2.509	2.559	2.278	1.965	N/A			
	Ebn at Noon	22	173	239	266	275	278	271	263	244	170	18	0			
	Edh at Noon	2	14	24	32	30	29	28	24	17	11	2	0			
(44) All-Sky Solar Radiation	RadAvg	7	140	612	1248	1605	1557	1455	1028	549	176	24	0			
	RadStd	1	11	26	56	152	114	141	74	54	24	3	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page