

SVINOY FYR, Norway

WMO: 012050

Lat: 62.329N

Lon: 5.268E

Elev: 37

StdP: 100.88

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.2	-1.2	-9.7	1.7	-0.1	-7.8	1.9	0.4	24.8	6.6	22.6	5.5	5.9	120	0.878

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.6	19.3	15.5	18.0	15.0	17.0	14.5	16.6	18.3	15.7	17.3	14.9	16.5	5.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	11.3	17.5	14.9	10.6	16.6	14.1	10.1	15.9	46.7	18.4	44.0	17.4	42.0	16.5	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.5	17.3	DB	-3.7	21.9	1.7	2.0	-4.9	23.3	-5.9	24.5	-6.9	25.6	-8.1	27.0	(4)
(5)			WB	-5.1	17.5	1.5	1.5	-6.2	18.6	-7.0	19.5	-7.8	20.3	-8.9	21.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	4.1	3.5	3.8	5.7	8.1	10.6	13.3	14.2	12.6	9.5	6.7	4.8	(6)	
	DBStd	4.43	2.34	2.48	2.28	2.37	2.41	2.12	2.21	2.10	2.20	2.60	2.68	2.74	(7)	
	HDD10.0	1079	183	183	191	130	69	17	1	0	4	40	103	160	(8)	
	HDD18.3	3734	441	416	449	378	318	233	156	128	172	274	350	418	(9)	
	CDD10.0	389	0	0	0	2	10	33	104	132	82	24	3	0	(10)	
	CDD18.3	2	0	0	0	0	0	0	1	1	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	1	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.0	8.9	8.5	8.5	7.5	7.1	7.4	6.7	6.7	8.2	8.4	8.6	9.2	(14)	
(15) Precipitation	PrecAvg	1201	117	107	98	63	65	77	76	113	119	130	114	130	(15)	
	PrecMax	1410	176	152	209	120	138	135	126	234	197	208	214	210	(16)	
	PrecMin	900	20	31	43	23	25	46	34	27	56	57	31	34	(17)	
	PrecStd	138	49	33	41	26	27	27	28	49	54	40	53	41	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	9.6	9.5	14.5	17.3	19.2	21.1	21.5	19.3	17.3	13.2	10.8	(19)	
		MCWB	6.7	6.6	6.3	9.9	11.5	14.1	16.4	16.8	14.4	12.5	10.0	8.5	(20)	
	2%	DB	8.6	8.2	8.2	11.5	14.4	16.3	18.8	19.6	17.6	15.1	11.8	10.0	(21)	
		MCWB	6.4	6.3	6.1	8.0	10.7	13.8	15.8	16.2	13.9	11.7	9.1	7.9	(22)	
	5%	DB	8.0	7.4	7.4	10.0	12.5	14.4	17.5	18.2	16.6	13.8	11.0	9.3	(23)	
		MCWB	6.2	5.8	5.7	7.4	10.1	12.6	15.4	15.5	13.5	11.1	8.7	7.6	(24)	
	10%	DB	7.3	6.7	6.8	8.7	11.1	13.2	16.4	17.0	15.5	12.9	10.2	8.6	(25)	
		MCWB	5.7	5.3	5.3	7.0	9.3	11.8	14.7	14.8	13.1	10.4	8.1	7.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.7	7.8	10.2	12.7	15.4	17.3	18.7	15.7	13.4	11.2	9.5	(27)	
		MCDB	8.7	8.5	8.4	13.2	15.9	17.7	19.2	20.0	17.7	15.1	12.4	10.2	(28)	
	2%	WB	7.3	7.0	6.9	8.7	11.3	13.9	16.4	17.1	14.9	12.5	10.0	8.7	(29)	
		MCDB	8.1	7.7	7.6	10.7	13.3	15.9	18.1	18.8	16.6	14.4	11.1	9.5	(30)	
	5%	WB	6.6	6.3	6.2	7.8	10.3	12.7	15.7	15.9	14.1	11.6	9.2	8.0	(31)	
		MCDB	7.6	7.1	7.0	9.3	12.1	14.1	17.3	17.5	15.8	13.4	10.4	9.0	(32)	
	10%	WB	5.9	5.5	5.6	7.2	9.5	11.9	14.9	15.1	13.5	10.8	8.4	7.1	(33)	
		MCDB	7.1	6.4	6.5	8.4	11.0	13.1	16.3	16.6	15.1	12.6	9.9	8.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.6	2.6	2.7	2.9	2.8	2.4	2.5	2.6	2.6	2.7	2.6	2.6	(35)	
		MCDBR	3.2	3.3	3.3	4.7	5.0	4.3	4.4	4.2	3.8	4.0	3.4	3.2	(36)	
	5% WB	MCWBR	2.8	2.9	2.6	2.7	2.8	2.8	2.6	2.8	2.4	3.0	2.8	3.1	(37)	
		MCWBR	3.1	3.1	2.9	4.0	4.4	3.8	3.8	3.5	3.3	3.8	3.0	3.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.282	0.327	0.347	0.368	0.360	0.357	0.369	0.363	0.351	0.325	0.283	0.365	(40)	
		taud	2.086	2.236	2.315	2.336	2.429	2.477	2.466	2.483	2.484	2.384	2.150	2.406	(41)	
	Ebn at Noon	Ebn at Noon	364	614	755	817	859	869	845	819	756	622	363	200	(42)	
		Edh at Noon	36	64	85	101	100	97	96	87	72	55	33	22	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.15	0.61	1.70	3.39	4.87	5.09	4.56	3.45	2.05	0.92	0.24	0.09	(44)	
	RadStd	RadStd	0.02	0.11	0.28	0.36	0.32	0.55	0.37	0.35	0.27	0.14	0.05	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) +0.63	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) -130	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (21 neighbors)	N/A	+0.70	N/A	N/A	N/A	N/A	-130	N/A	N/A	N/A	(47)

Nomenclature: See separate page