

FOKSTUA II, Norway

WMO: 012380

Lat: 62.1131N

Lon: 9.2861E

Elev: 974

StdP: 90.16

Time Zone: 1.00 (EUC)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -20.1	(c) -17.6	(d) -23.5	(e) 0.5	(f) -19.2	(g) -21.5	(h) 0.6	(i) -17.1	(j) 20.3	(k) -9.7	(l) 18.2	(m) -8.0	(n) 1.5	(o) 50	(p) 0.814

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	20.6	12.4	18.5	11.6	16.6	10.8	13.4	18.1	12.5	16.8	11.5	15.4	3.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.4	14.9	10.3	8.8	14.1	9.4	8.2	13.3	40.4	18.2	38.0	16.7	35.4	15.4	15.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	12.4	10.3	-22.5	22.5	2.7	2.1	-24.5	24.0	-26.1	25.3	-27.6	26.4	-29.6	28.0
			-23.0	14.6	2.6	0.7	-24.8	15.1	-26.3	15.5	-27.8	15.9	-29.6	16.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-7.3	-6.9	-5.0	-0.5	4.1	7.9	11.0	9.8	6.3	0.6	-4.0	-6.4		
	DBStd	7.72	4.76	5.01	4.38	3.81	4.05	3.38	3.10	2.93	3.22	3.80	4.68	5.19		
	HDD10.0	3459	536	473	466	314	188	81	24	40	116	291	419	509		
	HDD18.3	6381	794	707	724	564	441	313	227	263	360	549	669	768		
	CDD10.0	120	0	0	0	0	6	18	56	35	6	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	4	0	0	0	0	0	0	4	1	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.0	4.6	4.3	4.4	4.1	4.0	3.7	3.5	3.5	4.0	3.7	3.8	4.2		
(15) Precipitation	PrecAvg	440	29	23	21	17	32	50	71	68	33	34	31	30		
	PrecMax	615	65	43	52	32	102	123	133	129	71	84	83	62		
	PrecMin	344	3	3	2	4	6	4	29	21	5	4	5	11		
	PrecStd	57	16	10	12	8	22	26	25	26	15	18	17	12		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.4	4.5	6.0	11.4	19.6	21.6	23.7	21.1	17.5	12.3	7.0	5.0		
		MCWB	1.4	2.5	2.2	5.4	10.6	11.0	13.9	13.1	11.0	7.7	4.8	3.1		
	2%	DB	1.8	2.6	4.0	8.8	16.1	18.8	21.3	18.7	14.9	9.0	5.2	3.5		
		MCWB	0.2	0.9	1.6	3.9	8.4	10.5	13.1	12.3	10.1	5.9	3.4	1.8		
	5%	DB	0.5	1.1	2.6	6.8	13.7	16.4	19.4	16.9	13.0	7.4	3.5	2.0		
		MCWB	-0.8	-0.5	0.3	3.0	7.5	9.5	12.3	11.6	9.3	5.1	2.0	0.4		
	10%	DB	-0.9	-0.4	1.1	5.1	11.0	14.1	17.0	15.1	11.3	6.0	2.0	0.3		
		MCWB	-2.0	-1.7	-0.8	2.3	6.3	8.6	11.3	11.0	8.4	4.0	0.6	-0.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.8	2.5	3.3	6.4	10.6	12.5	14.7	14.2	12.2	8.1	5.3	3.3		
		MCDB	3.2	3.7	5.2	10.5	16.7	17.1	20.8	18.9	15.9	10.2	6.7	4.7		
	2%	WB	0.4	0.7	1.6	4.6	8.9	11.4	13.6	13.3	10.8	6.4	3.6	2.0		
		MCDB	1.7	1.9	3.7	7.6	13.7	16.6	18.8	17.7	13.9	8.2	5.1	3.5		
	5%	WB	-0.7	-0.5	0.6	3.3	7.7	10.4	12.9	12.3	9.8	5.3	2.2	0.5		
		MCDB	0.4	0.7	2.5	6.2	12.0	15.3	17.5	16.1	12.5	7.1	3.6	1.8		
	10%	WB	-1.9	-1.8	-0.7	2.3	6.3	9.2	11.9	11.3	8.8	4.1	0.9	-0.9		
		MCDB	-0.8	-0.6	1.1	4.9	10.3	13.3	15.9	14.7	11.4	5.9	2.0	0.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.4	6.6	6.9	8.2	8.6	8.5	7.8	6.9	5.8	5.0	5.2		
		MCDBR	5.4	5.5	7.0	8.7	11.8	12.7	12.4	10.4	9.4	7.8	5.7	5.7		
		MCWBR	4.9	4.6	5.2	5.3	6.3	6.3	5.7	5.4	5.5	5.4	4.9	5.1		
	5% WB	MCDBR	5.3	5.2	6.7	7.5	10.3	10.6	10.4	9.1	8.0	6.4	5.6	5.5		
		MCWBR	4.9	4.7	5.1	4.7	5.9	5.7	5.2	5.1	5.1	4.9	5.1	5.1		
(40) Clear-Sky Solar Irradiance	taub		0.189	0.239	0.270	0.300	0.310	0.311	0.322	0.312	0.283	0.263	0.198	0.160		
	taud		2.083	2.257	2.246	2.243	2.375	2.490	2.479	2.498	2.562	2.451	2.118	1.956		
	Ebn at Noon		545	755	850	890	911	917	895	876	848	725	514	373		
	Edh at Noon		32	59	87	109	104	95	94	85	65	49	30	19		
(44) All-Sky Solar Radiation	RadAvg		0.25	0.90	2.38	4.31	5.22	5.08	4.67	3.63	2.30	1.04	0.33	0.14		
	RadStd		0.04	0.14	0.26	0.33	0.41	0.41	0.46	0.29	0.22	0.12	0.05	0.01		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	-120	-144	N/A	N/A

Nomenclature: See separate page