

HJERKINN II, Norway

WMO: 012390

Lat: 62.221N

Lon: 9.542E

Elev: 1012

StdP: 89.74

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.7	-18.9	-23.6	0.5	-19.6	-21.9	0.6	-18.0	13.3	-1.3	12.1	-0.9	1.7	310	0.776

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	20.8	12.5	18.7	11.5	16.8	10.7	13.9	18.2	12.8	16.7	11.7	15.5	2.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	9.9	15.1	10.9	9.2	14.5	9.8	8.5	13.3	42.2	18.1	39.1	16.8	36.2	15.6	17.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.4	8.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.7	-8.1	-6.7	-5.0	-0.9	4.4	7.9	11.0	9.4	6.4	0.5	-4.6	-6.6
	DBStd	7.92	5.31	4.93	4.83	4.25	4.72	2.86	3.40	2.48	3.14	3.60	5.23	5.57
	HDD10.0	3512	561	469	464	326	182	76	28	42	116	294	439	515
	HDD18.3	6441	819	702	723	576	431	313	227	276	359	553	689	773
	CDD10.0	112	0	0	0	0	9	12	61	24	6	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	8	0	0	0	0	0	0	8	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.3	3.4	3.7	4.2	3.4	3.2	3.3	2.7	2.6	3.1	3.0	3.1	4.0
Precipitation	PrecAvg	643	51	47	47	30	37	63	78	80	53	51	49	56
	PrecMax	811	130	85	114	104	64	125	122	160	140	108	135	121
	PrecMin	494	2	4	13	8	14	21	35	29	19	19	4	17
	PrecStd	78	33	22	28	19	13	29	23	30	26	19	36	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.5	5.8	7.4	12.5	20.7	20.3	24.6	20.2	18.1	11.3	7.3	6.5
		MCWB	1.7	2.4	3.7	6.5	10.9	10.7	14.9	12.4	10.9	7.7	4.6	4.7
	2%	DB	2.3	3.6	5.1	9.8	17.4	17.7	22.4	18.0	15.9	8.8	5.5	4.3
		MCWB	0.3	0.8	2.3	4.7	9.7	9.8	13.5	11.2	10.3	5.5	3.4	2.3
	5%	DB	0.9	1.8	3.5	7.6	15.2	15.5	20.1	16.2	13.8	7.1	3.8	2.5
		MCWB	-0.7	-0.4	1.1	3.7	8.8	9.2	12.8	10.8	9.3	4.6	2.3	0.7
	10%	DB	-0.8	0.1	1.9	5.7	12.8	13.7	17.9	14.4	11.7	5.7	2.0	0.4
		MCWB	-2.1	-1.7	-0.3	2.5	7.9	8.8	12.1	10.3	8.3	3.4	0.4	-1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.2	2.9	4.3	6.9	12.1	13.1	15.8	13.8	12.5	8.7	4.9	4.6
		MCDB	4.2	5.3	6.8	11.6	19.1	16.0	22.0	17.0	16.7	10.5	7.1	6.3
	2%	WB	0.5	1.1	2.4	5.3	10.8	11.6	14.8	12.7	10.8	6.0	3.5	2.5
		MCDB	2.2	3.1	4.8	9.0	15.9	14.8	20.4	15.9	14.2	8.0	5.2	4.3
	5%	WB	-0.7	-0.4	1.2	3.9	9.3	10.5	13.7	11.6	9.7	4.8	2.4	0.7
		MCDB	0.8	1.6	3.4	7.0	13.9	14.3	18.2	14.8	12.9	6.8	3.8	2.3
	10%	WB	-2.0	-1.8	-0.2	2.5	8.0	9.2	12.6	10.6	8.7	3.4	0.5	-1.1
		MCDB	-0.8	-0.1	1.8	5.7	12.6	12.9	16.7	13.7	11.5	5.3	1.8	0.2
Mean Daily Temperature Range	5% DB	MDBR	5.6	5.9	6.9	7.6	8.5	8.9	9.5	8.6	7.5	6.3	5.3	5.8
		MCDBR	5.7	6.3	6.8	9.2	12.3	12.9	13.5	11.4	10.7	8.0	6.2	6.9
		MCWBR	4.9	5.2	5.1	5.7	6.3	6.4	6.2	5.7	6.0	5.6	5.1	6.3
	5% WB	MCDBR	5.6	6.0	6.7	8.7	11.0	10.2	11.7	9.7	9.3	7.0	6.3	7.1
		MCWBR	4.9	5.1	5.2	5.6	6.1	5.7	5.8	5.5	5.9	5.3	5.3	6.5
Clear-Sky Solar Irradiance	taub	0.187	0.238	0.269	0.298	0.309	0.309	0.320	0.311	0.281	0.262	0.196	0.160	
	taud	2.078	2.257	2.249	2.249	2.381	2.494	2.482	2.501	2.566	2.454	2.114	1.955	
	Ebn at Noon	542	755	851	892	912	918	896	877	849	725	512	366	
	Edh at Noon	32	59	87	108	103	95	94	84	65	49	30	19	
All-Sky Solar Radiation	RadAvg	0.24	0.89	2.36	4.30	5.24	5.08	4.67	3.63	2.29	1.03	0.32	0.13	
	RadStd	0.04	0.14	0.26	0.30	0.38	0.39	0.45	0.30	0.22	0.12	0.05	0.01	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-120	-144	N/A	N/A

Nomenclature: See separate page