

KOTSOY, Norway

WMO: 012540

Lat: 62.976N

Lon: 10.561E

Elev: 127

StdP: 99.81

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.4	(c) -19.2	(d) -24.7	(e) 0.4	(f) -22.4	(g) -21.2	(h) 0.6	(i) -18.9	(j) 7.8	(k) -2.4	(l) 7.1	(m) -2.5	(n) 1.3	(o) 160	(p) 0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.4	(c) 26.2	(d) 17.0	(e) 24.0	(f) 16.0	(g) 22.0	(h) 15.2	(i) 18.5	(j) 23.8	(k) 17.2	(l) 22.0	(m) 16.1	(n) 20.6	(o) 2.3	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	11.9	20.7	15.3	11.0	19.1	14.2	10.3	17.9	52.8	23.6	48.9	22.2	45.6	20.6	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.1	(b) 5.1	(c) 4.3	(e) -23.5	(f) 29.7	(g) 4.2	(h) 2.6	(i) -26.5	(j) 31.6	(k) -29.0	(l) 33.1	(m) -31.3	(n) 34.6	(o) -34.4	(p) 36.5		
(a) 6.1	(b) 5.1	(c) 4.3	(e) -23.7	(f) 20.4	(g) 4.2	(h) 1.5	(i) -26.7	(j) 21.5	(k) -29.1	(l) 22.4	(m) -31.5	(n) 23.2	(o) -34.5	(p) 24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-5.7	-4.3	-0.6	4.0	8.9	12.2	15.5	14.2	10.5	4.1	-1.4	-4.2		
	DBStd	8.60	6.30	6.00	4.36	3.18	4.00	3.32	3.48	2.79	2.99	3.66	5.27	6.11		
	HDD10.0	2486	486	399	330	181	71	15	2	2	31	186	342	441		
	HDD18.3	5073	744	632	588	430	293	186	102	130	236	441	592	699		
	CDD10.0	472	0	0	0	2	36	81	172	133	46	4	0	0		
	CDD18.3	18	0	0	0	0	0	2	14	3	0	0	0	0		
	CDH23.3	265	0	0	0	0	24	31	176	34	0	0	0	0		
	CDH26.7	57	0	0	0	0	2	5	48	1	0	0	0	0		
(14) Wind	WSAvg	1.6	1.7	1.7	1.8	1.7	1.8	1.7	1.4	1.3	1.3	1.4	1.4	1.5		
(15) Precipitation	PrecAvg	867	71	64	60	41	59	89	97	100	86	69	64	66		
	PrecMax	1076	170	115	128	148	104	161	165	204	217	169	190	153		
	PrecMin	641	3	4	22	14	31	30	47	33	25	20	0	16		
	PrecStd	106	45	31	33	29	22	33	33	43	53	32	53	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	8.3	10.4	19.2	26.2	27.0	31.4	26.4	21.2	16.9	9.9	7.7		
		MCWB	3.4	4.8	6.1	11.0	15.6	16.3	19.5	17.0	15.0	12.8	6.9	4.2		
	2%	DB	4.5	6.4	8.2	15.6	23.3	23.6	27.5	24.1	19.4	13.7	8.0	5.7		
		MCWB	2.2	3.3	4.6	8.2	14.2	15.3	18.3	16.6	14.5	9.8	5.8	2.8		
	5%	DB	2.5	4.9	6.6	12.3	20.5	21.2	25.1	22.0	17.4	11.6	6.5	4.3		
		MCWB	1.2	2.1	3.5	6.5	13.0	14.5	17.3	15.7	13.4	8.7	4.4	1.9		
	10%	DB	1.1	3.1	4.9	10.0	17.0	18.8	22.6	20.0	15.6	9.3	4.9	2.4		
		MCWB	0.6	1.0	2.4	5.4	10.8	13.2	16.1	15.1	12.2	7.1	3.5	1.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	5.2	6.6	10.9	16.3	17.6	21.2	19.0	16.5	13.8	7.5	4.6		
		MCDB	4.8	7.8	9.3	18.4	23.5	23.6	29.4	23.9	19.7	16.2	8.8	6.8		
	2%	WB	2.4	3.8	5.2	8.7	14.9	16.3	19.4	17.6	15.1	10.2	6.1	3.1		
		MCDB	3.8	5.9	7.8	14.6	22.0	21.9	25.3	21.8	18.3	12.9	7.6	5.1		
	5%	WB	1.4	2.4	3.8	7.1	13.2	15.0	18.0	16.5	13.9	8.9	4.6	2.1		
		MCDB	2.3	4.4	6.1	11.5	19.4	20.1	23.5	20.4	16.9	11.5	6.2	3.9		
	10%	WB	0.6	1.2	2.6	5.7	11.4	13.8	16.7	15.4	12.6	7.3	3.5	1.2		
		MCDB	1.1	2.7	4.3	9.4	16.6	17.9	21.4	19.1	15.0	8.9	4.8	2.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	7.2	9.2	10.5	11.1	9.8	10.4	10.1	9.1	6.9	5.1	5.9		
		MCDBR	6.1	7.6	9.6	14.7	17.6	15.0	15.9	13.6	11.9	9.3	7.1	7.6		
		MCWBR	4.6	5.4	6.3	8.2	8.9	7.4	7.4	7.0	7.3	6.1	5.1	5.4		
		MCWBR	5.1	7.3	8.5	13.4	16.8	13.1	14.3	12.1	11.6	8.8	6.8	6.8		
(40) Clear-Sky Solar Irradiance	taub	taub	0.217	0.276	0.310	0.341	0.352	0.351	0.361	0.349	0.320	0.301	0.233	N/A		
		taud	2.031	2.190	2.189	2.246	2.393	2.442	2.433	2.463	2.528	2.436	2.122	N/A		
		Ebn at Noon	424	665	781	838	863	871	849	830	790	650	400	N/A		
		Edh at Noon	31	62	92	108	102	100	98	87	68	50	28	N/A		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.20	0.79	2.17	4.00	4.75	4.83	4.61	3.55	2.19	0.97	0.28	0.10		
		RadStd	0.03	0.10	0.23	0.29	0.29	0.45	0.48	0.38	0.22	0.13	0.04	0.01		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a) Station Only	(b) Regional (47 neighbors)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(a) Station Only	(b) Regional (47 neighbors)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) -142	(k) -178	(l) N/A	(m) N/A

Nomenclature: See separate page