

NORDOYAN FYR, Norway

WMO: 012620

Lat: 64.799N

Lon: 10.547E

Elev: 33

StdP: 100.93

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.7	-5.8	-12.3	1.3	-7.1	-10.5	1.5	-5.2	23.8	3.3	22.6	3.0	11.1	120	0.971

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	19.6	15.2	18.1	14.3	16.8	13.7	15.7	18.8	14.8	17.4	13.9	16.2	5.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.1	17.1	13.3	9.6	16.2	12.6	9.1	15.4	44.0	19.0	41.5	17.5	39.2	16.3	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	19.5	17.4	-8.3	22.7	3.0	2.1	-10.5	24.2	-12.2	25.5	-13.9	26.7	-16.1	28.2		
(5)			-9.6	16.9	3.2	1.4	-11.9	18.0	-13.8	18.8	-15.6	19.6	-17.9	20.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	1.9	1.4	2.3	5.0	8.0	10.5	13.3	13.7	11.5	8.0	4.9	3.0
	DBStd	5.12	3.13	3.60	2.75	2.30	2.73	2.42	2.53	2.10	2.06	2.70	2.98	3.31
	HDD10.0	1435	252	240	238	152	74	22	1	1	9	72	154	218
	HDD18.3	4145	511	473	497	401	319	235	158	144	206	321	404	477
	CDD10.0	333	0	0	0	1	14	37	103	116	53	9	0	0
	CDD18.3	2	0	0	0	0	0	0	2	1	0	0	0	0
	CDH23.3	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	8.9	11.1	10.7	9.8	7.8	7.3	6.7	6.4	6.7	8.5	9.8	10.6	11.5
	PrecAvg	1438	145	132	137	88	70	93	83	95	143	150	140	160
(15) Precipitation	PrecMax	1801	337	308	307	190	128	180	182	169	323	243	274	288
	PrecMin	1019	8	31	56	29	33	21	33	21	40	40	23	48
	PrecStd	198	79	65	64	41	23	39	38	40	76	51	79	63
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.5	7.9	12.8	17.9	19.4	22.7	21.2	17.1	14.3	11.0	9.1
		MCWB	6.7	6.1	5.5	8.5	11.9	13.6	16.5	16.1	13.2	11.6	9.3	7.5
	2%	DB	7.2	6.9	7.0	10.3	15.3	17.3	20.3	19.1	15.8	13.1	10.1	8.3
		MCWB	6.1	5.7	5.6	7.2	10.6	13.1	16.0	15.2	12.7	10.9	8.7	6.9
	5%	DB	6.6	6.3	6.5	9.0	13.4	15.4	18.3	17.9	14.9	12.2	9.3	7.7
		MCWB	5.5	5.0	5.1	6.7	9.8	12.1	14.7	14.8	12.4	10.2	7.7	6.3
	10%	DB	6.0	5.6	6.0	7.7	11.8	14.0	16.8	16.8	14.2	11.5	8.6	7.1
		MCWB	4.8	4.3	4.5	5.8	8.9	11.3	13.9	14.0	12.0	9.7	6.9	5.5
	0.4%	WB	7.2	6.7	6.7	9.0	12.8	14.8	17.7	16.5	13.8	12.6	10.1	8.2
		MCDB	7.7	7.0	7.0	11.3	17.2	18.7	20.5	19.7	15.6	13.3	10.6	8.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.6	5.9	5.9	7.8	11.1	13.5	16.0	15.7	13.2	11.5	9.0	7.2
		MCDB	7.2	6.5	6.6	9.9	14.7	16.8	19.6	18.6	14.8	12.6	9.6	8.0
	5%	WB	5.8	5.2	5.3	6.9	10.0	12.5	14.8	15.0	12.7	10.7	8.0	6.4
		MCDB	6.6	6.1	6.2	8.4	13.1	15.1	17.7	17.4	14.4	12.1	9.1	7.4
	10%	WB	5.1	4.4	4.6	6.2	9.0	11.7	14.0	14.2	12.2	9.9	7.0	5.6
		MCDB	6.0	5.4	5.7	7.5	11.6	13.8	16.3	16.3	13.9	11.4	8.4	6.8
(35) Mean Daily Temperature Range	5% DB	MDBR	3.0	3.0	2.9	3.1	3.6	3.2	3.5	3.2	2.7	2.5	2.8	3.0
		MCDBR	3.1	3.1	3.1	4.3	6.3	5.7	6.4	5.1	3.4	2.9	3.0	3.6
		MCWBR	3.1	3.2	3.1	2.6	3.2	3.2	3.4	2.7	2.3	2.5	3.1	3.6
	5% WB	MCDDBR	2.7	3.2	3.2	4.0	6.2	5.4	6.0	4.8	3.2	2.8	3.2	3.2
		MCWBR	3.0	3.5	3.3	2.8	3.3	3.4	3.4	2.9	2.5	2.6	3.5	3.5
(40) Clear-Sky Solar Irradiance	taub	0.368	0.312	0.336	0.357	0.352	0.352	0.352	0.359	0.348	0.337	0.313	0.345	0.363
	taud	2.498	2.226	2.315	2.375	2.455	2.489	2.496	2.520	2.519	2.372	2.488	2.450	
	Ebn at Noon	262	574	739	815	857	864	846	823	749	580	263	89	
	Edh at Noon	25	56	79	94	95	94	91	81	66	48	22	12	
(44) All-Sky Solar Radiation	RadAvg	0.10	0.52	1.67	3.36	4.63	4.98	4.65	3.58	2.02	0.85	0.18	0.03	
	RadStd	0.01	0.08	0.28	0.32	0.29	0.61	0.49	0.36	0.25	0.13	0.03	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page