

SOLENET, Norway

WMO: 012870

Lat: 62.680N

Lon: 11.817E

Elev: 747

StdP: 92.67

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.6	(c) -21.2	(d) -26.1	(e) 0.4	(f) -23.5	(g) -23.5	(h) 0.5	(i) -20.9	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	22.5	14.2	20.2	13.2	18.1	12.4	15.6	20.8	14.3	18.5	13.1	16.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	10.5	17.1	12.4	9.8	16.1	11.3	9.1	14.8	46.2	21.2	42.6	18.5	39.1	16.9	18.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) -26.8	(f) 24.6	(g) 3.5	(h) 2.2	(i) -29.2	(j) 26.2	(k) -31.3	(l) 27.5	(m) -33.2	(n) 28.8	(o) -35.7	(p) 30.4		
(4) N/A	(5) N/A	(6) N/A	(e) -27.0	(f) 16.5	(g) 3.6	(h) 1.6	(i) -29.5	(j) 17.7	(k) -31.6	(l) 18.6	(m) -33.6	(n) 19.5	(o) -36.2	(p) 20.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.3	-8.6	-6.3	-4.8	-0.1	5.0	8.5	12.0	10.4	7.1	1.4	-3.4	-6.2
	DBStd	8.13	6.07	5.01	4.63	3.92	4.54	3.52	3.67	2.75	3.09	3.47	4.52	5.19
	HDD10.0	3356	578	458	459	303	169	71	20	29	96	269	402	502
	HDD18.3	6229	836	691	718	553	414	296	197	247	338	527	652	761
	CDD10.0	171	0	0	0	0	13	24	83	41	8	1	0	0
	CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH23.3	32	0	0	0	0	1	2	29	0	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	704	55	47	45	32	50	76	90	87	65	58	49	48
	PrecMax	892	134	80	110	99	87	142	158	145	142	111	142	108
	PrecMin	556	4	3	19	10	23	31	33	36	22	15	6	18
	PrecStd	83	35	23	24	18	19	27	34	30	32	21	35	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.3	4.2	6.0	12.3	22.2	23.3	26.2	21.2	18.2	13.3	7.5	4.3
		MCWB	1.3	2.1	2.2	5.9	12.1	13.0	15.9	14.3	11.7	11.8	5.7	3.1
	2%	DB	1.6	2.2	3.9	9.9	19.1	20.2	23.8	19.1	16.0	9.6	5.0	2.9
		MCWB	0.7	0.6	1.7	4.5	11.3	12.1	15.7	12.9	11.2	7.4	3.9	2.0
	5%	DB	0.3	0.8	2.5	7.7	16.2	17.4	21.5	17.3	13.7	7.7	3.5	1.6
		MCWB	-0.5	-0.3	0.7	3.2	10.3	11.0	14.7	12.4	10.3	5.9	2.7	0.7
	10%	DB	-0.9	-0.1	1.3	5.8	13.0	14.9	19.2	15.5	12.2	6.3	2.1	0.1
		MCWB	-1.7	-1.0	-0.3	2.3	8.8	10.0	13.7	11.8	9.7	4.9	1.2	-0.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.7	2.5	3.2	6.4	13.5	14.2	17.6	15.5	12.9	12.0	6.0	3.5
		MCDB	2.9	4.0	4.7	11.5	18.4	20.1	22.8	18.4	15.8	13.8	7.3	3.8
	2%	WB	0.7	0.9	2.1	4.9	12.1	12.8	16.5	14.2	11.8	7.9	4.1	2.2
		MCDB	1.5	1.8	3.7	8.8	18.0	18.3	22.3	17.5	14.3	8.9	4.8	2.7
	5%	WB	-0.4	-0.1	0.9	3.6	10.5	11.7	15.4	13.1	10.9	6.3	2.8	0.7
		MCDB	0.3	0.7	2.1	7.0	15.7	16.5	20.8	16.0	13.5	7.6	3.5	1.5
	10%	WB	-1.6	-1.1	-0.2	2.6	8.8	10.5	14.2	12.1	9.8	4.8	1.3	-0.6
		MCDB	-1.0	-0.2	1.2	5.4	12.8	14.2	18.6	14.8	11.8	6.2	2.0	0.0
Mean Daily Temperature Range	5% DB	MDBR	6.1	5.8	7.7	8.2	8.5	8.8	9.4	8.6	7.6	5.5	5.0	6.0
		MCDBR	5.5	5.5	7.5	10.7	14.1	14.0	13.4	11.3	10.6	7.7	5.4	6.1
		MCWBR	5.0	4.7	5.6	6.0	7.5	6.8	6.3	6.2	6.3	5.8	4.6	5.8
	5% WB	MCDBR	5.4	5.3	6.8	9.1	13.0	12.3	12.5	9.5	9.4	6.7	5.2	6.3
		MCWBR	5.0	4.7	5.2	5.1	7.1	6.3	5.9	5.6	6.0	5.5	4.7	6.0
Clear-Sky Solar Irradiance	taub	0.193	0.249	0.279	0.309	0.322	0.319	0.330	0.321	0.294	0.275	0.204	0.171	
	taud	2.044	2.233	2.237	2.256	2.415	2.501	2.481	2.498	2.560	2.458	2.101	1.955	
	Ebn at Noon	495	722	831	877	897	906	884	864	828	698	467	302	
	Edh at Noon	31	59	87	107	100	94	94	84	65	48	29	17	
All-Sky Solar Radiation	RadAvg	0.22	0.84	2.30	4.15	4.82	4.93	4.62	3.56	2.23	0.98	0.30	0.11	
	RadStd	0.02	0.11	0.20	0.30	0.30	0.43	0.50	0.35	0.22	0.13	0.04	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-142	-178	N/A	N/A

Nomenclature: See separate page