

FEDJE, Norway

WMO: 013070

Lat: 60.753N

Lon: 4.711E

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	25.4	27.3	10.1	9.2	28.2	13.5	11.0	30.6	46.8	40.4	43.8	39.5	12.3	110	0.851

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	69.8	60.0	66.4	59.0	64.2	58.0	61.9	66.9	60.4	64.7	59.0	63.2	9.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.6	76.2	64.5	58.2	72.5	63.3	56.7	68.8	61.9	27.7	67.1	26.7	64.8	25.8	63.3	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.2	37.8	34.1	DB	25.2	76.0	3.5	4.8	22.7	79.4	20.7	82.2	18.7	84.9	16.2	88.4	(4)
(5)			WB	21.6	63.8	3.4	2.7	19.2	65.8	17.2	67.4	15.3	68.9	12.8	70.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	37.5	37.5	39.0	43.4	48.2	53.3	57.8	58.8	55.3	49.0	43.7	40.2		
	DBStd	8.78	4.96	4.57	3.99	4.00	4.80	4.03	4.19	4.07	3.78	4.13	5.13	5.64		
	HDD50	1948	387	349	342	202	93	11	0	1	4	64	192	303		
	HDD65	6568	852	769	807	647	522	353	229	198	290	495	638	768		
	CDD50	866	0	0	0	4	36	109	243	273	164	34	3	0		
	CDD65	15	0	0	0	0	0	1	7	6	1	0	0	0		
	CDH74	26	0	0	0	0	0	0	15	11	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	WSAvg	16.7	20.3	18.8	16.7	15.0	14.5	13.3	13.2	13.9	16.8	18.7	18.9	20.1		
	PrecAvg	61.8	6.8	5.4	4.8	3.8	2.7	3.3	4.1	4.6	5.4	6.8	7.2	7.0		
(15) Precipitation	PrecMax	79.8	12.0	10.0	8.7	8.0	5.0	7.8	6.5	8.3	10.2	12.6	13.2	13.8		
	PrecMin	39.6	0.2	0.0	0.0	0.4	0.4	0.0	0.1	1.7	0.2	2.6	0.6	1.3		
	PrecStd	11.2	3.5	2.8	2.4	1.7	1.1	2.1	1.6	1.8	2.9	2.7	3.5	3.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	46.8	48.9	58.9	67.4	68.9	76.1	74.9	68.3	60.8	54.8	50.9		
		MCWB	44.6	43.5	43.0	48.4	54.4	57.5	62.4	57.2	57.8	54.2	50.6	47.4		
	2%	DB	46.5	45.5	45.5	54.1	62.3	64.8	70.5	69.3	64.0	57.3	52.7	49.4		
		MCWB	44.2	43.0	42.1	46.7	52.8	55.6	61.7	60.0	56.2	52.0	49.3	46.3		
	5%	DB	45.6	44.7	44.6	51.2	58.5	61.6	66.5	66.1	62.1	55.5	51.4	48.5		
		MCWB	43.2	42.4	42.0	45.4	51.1	54.8	60.6	59.6	56.0	51.1	47.8	45.7		
	10%	DB	44.4	43.8	43.8	48.7	54.8	58.7	63.6	64.1	60.4	54.3	50.3	47.5		
		MCWB	41.9	41.4	41.3	44.4	49.4	53.9	58.7	58.7	55.6	50.2	46.8	44.6		
	0.4%	WB	45.8	44.6	44.8	50.0	56.3	59.3	64.8	63.0	59.8	56.0	51.8	48.5		
		MCDB	46.6	45.3	45.8	54.6	63.6	66.1	72.1	68.3	64.8	58.7	53.5	49.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.8	43.8	43.8	48.2	53.9	57.2	62.7	61.6	58.3	54.1	50.2	47.4		
		MCDB	46.1	44.9	44.8	52.1	60.5	62.6	68.6	65.6	61.9	56.5	52.4	49.0		
	5%	WB	43.8	43.0	42.9	46.5	52.1	55.5	60.8	60.5	57.3	52.5	48.9	46.3		
		MCDB	45.4	44.5	44.2	50.6	57.3	60.2	65.9	64.1	60.8	54.8	51.2	48.1		
	10%	WB	42.1	41.9	41.8	44.9	49.9	54.0	59.2	59.3	55.9	50.9	47.5	45.0		
		MCDB	44.1	43.8	43.5	48.2	54.6	57.8	63.5	63.2	59.8	53.6	49.9	47.2		
	5% DB	MDBR	5.2	5.0	5.3	6.5	6.6	6.3	5.9	5.9	5.6	5.7	5.5	5.2		
		MCDBR	5.8	5.5	5.5	10.7	13.2	11.7	11.1	9.1	8.2	6.7	5.8	5.7		
		MCWBR	6.1	4.8	4.5	5.5	6.2	5.6	5.0	4.3	4.5	5.2	6.0	5.9		
		MCWBR	5.6	5.0	4.8	9.7	12.0	9.6	10.0	6.9	6.8	6.0	5.8	5.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	6.3	4.9	4.5	5.5	6.2	5.4	5.1	4.4	4.5	6.0	6.5	6.2		
	taub		0.301	0.331	0.351	0.376	0.364	0.359	0.374	0.369	0.357	0.334	0.303	0.387		
		taud	2.125	2.254	2.316	2.311	2.425	2.474	2.455	2.465	2.473	2.392	2.198	2.487		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		132	204	243	259	273	277	268	260	242	204	132	88		
		Edh at Noon	13	22	28	34	32	31	31	29	24	19	12	9		
	RadAvg		66	226	556	1066	1546	1643	1471	1122	673	326	99	41		
(45) All-Sky Solar Radiation	RadStd		11	41	86	113	137	197	137	116	93	50	16	6		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (40 neighbors)		N/A	+1.17	N/A	N/A	N/A	-166	-243	N/A	N/A

Nomenclature: See separate page