

FEDJE, Norway

WMO: 013070

Lat: 60.753N

Lon: 4.711E

Elev: 20

StdP: 101.08

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.7	-2.6	-12.2	1.3	-2.1	-10.3	1.6	-0.8	20.9	4.6	19.6	4.1	5.5	110	0.851

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	21.0	15.5	19.1	15.0	17.9	14.4	16.6	19.4	15.8	18.2	15.0	17.3	4.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.3	10.9	18.0	14.5	10.4	17.4	13.7	9.8	16.6	46.6	19.5	44.3	18.2	42.1	17.4	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	16.9	15.2	-3.8	24.4	1.9	2.7	-5.2	26.3	-6.3	27.9	-7.4	29.4	-8.8	31.3		
(5)			-5.8	17.7	1.9	1.5	-7.1	18.8	-8.2	19.6	-9.3	20.5	-10.6	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	3.1	3.1	3.9	6.3	9.0	11.8	14.4	14.9	13.0	9.5	6.5	4.6		
	DBStd	4.88	2.75	2.54	2.22	2.22	2.66	2.24	2.33	2.26	2.10	2.29	2.85	3.13		
	HDD10.0	1082	215	194	190	112	52	6	0	1	2	36	107	168		
	HDD18.3	3649	473	427	448	359	290	196	127	110	161	275	354	427		
	CDD10.0	481	0	0	0	2	20	61	135	152	91	19	2	0		
	CDD18.3	8	0	0	0	0	0	1	4	3	1	0	0	0		
	CDH23.3	14	0	0	0	0	0	0	8	6	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	7.5	9.1	8.4	7.4	6.7	6.5	5.9	5.9	6.2	7.5	8.4	8.4	9.0		
(15) Precipitation	PrecAvg	1569	173	138	121	97	68	83	105	117	137	172	183	177		
	PrecMax	2026	306	253	221	202	127	197	166	210	259	319	336	351		
	PrecMin	1006	6	0	0	10	9	0	2	44	5	67	14	34		
	PrecStd	285	89	71	61	44	28	53	41	46	74	68	90	86		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	8.2	9.4	15.0	19.7	20.5	24.5	23.8	20.2	16.0	12.7	10.5		
		MCWB	7.0	6.4	6.1	9.1	12.4	14.2	16.9	14.0	14.3	12.3	10.3	8.5		
	2%	DB	8.0	7.5	7.5	12.3	16.8	18.2	21.4	20.7	17.8	14.1	11.5	9.7		
		MCWB	6.8	6.1	5.6	8.2	11.6	13.1	16.5	15.6	13.4	11.1	9.6	8.0		
	5%	DB	7.5	7.0	7.0	10.7	14.7	16.5	19.1	18.9	16.7	13.1	10.8	9.2		
		MCWB	6.2	5.8	5.6	7.5	10.6	12.7	15.9	15.3	13.3	10.6	8.8	7.6		
	10%	DB	6.9	6.6	6.6	9.3	12.7	14.8	17.6	17.8	15.8	12.4	10.2	8.6		
		MCWB	5.5	5.2	5.1	6.9	9.6	12.2	14.8	14.8	13.1	10.1	8.2	7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	7.0	7.1	10.0	13.5	15.1	18.2	17.2	15.4	13.3	11.0	9.2		
		MCDB	8.1	7.4	7.7	12.5	17.6	19.0	22.3	20.2	18.2	14.8	11.9	10.0		
	2%	WB	7.1	6.5	6.5	9.0	12.2	14.0	17.1	16.5	14.6	12.3	10.1	8.6		
		MCDB	7.8	7.1	7.1	11.2	15.9	17.0	20.4	18.7	16.6	13.6	11.4	9.5		
	5%	WB	6.5	6.1	6.1	8.1	11.2	13.1	16.0	15.9	14.0	11.4	9.4	7.9		
		MCDB	7.4	6.9	6.8	10.3	14.0	15.7	18.8	17.9	16.0	12.7	10.6	9.0		
	10%	WB	5.6	5.5	5.5	7.2	9.9	12.2	15.1	15.2	13.3	10.5	8.6	7.2		
		MCDB	6.7	6.5	6.4	9.0	12.6	14.4	17.5	17.4	15.4	12.0	9.9	8.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.9	2.8	3.0	3.6	3.6	3.5	3.3	3.3	3.1	3.2	3.0	2.9		
		MCDBR	3.2	3.0	3.0	5.9	7.3	6.5	6.1	5.0	4.6	3.7	3.2	3.2		
	5% WB	MCWBR	3.4	2.7	2.5	3.0	3.4	3.1	2.8	2.4	2.5	2.9	3.3	3.3		
		MCWBR	3.1	2.8	2.7	5.4	6.7	5.3	5.6	3.8	3.8	3.4	3.2	3.1		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.331	0.351	0.376	0.364	0.359	0.374	0.369	0.357	0.334	0.303	0.387		
		taud	2.125	2.254	2.316	2.311	2.425	2.474	2.455	2.465	2.473	2.392	2.198	2.487		
	Ebn at Noon		416	643	766	816	861	872	846	820	763	642	415	277		
		Edh at Noon	42	68	88	106	102	98	98	90	76	59	39	28		
(44) All-Sky Solar Radiation	RadAvg		0.21	0.71	1.75	3.36	4.87	5.18	4.64	3.54	2.12	1.03	0.31	0.13		
	RadStd		0.03	0.13	0.27	0.35	0.43	0.62	0.43	0.37	0.29	0.16	0.05	0.02		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (40 neighbors)		N/A	+0.65	N/A	N/A	N/A	N/A	-92	-135	N/A	N/A	

Nomenclature: See separate page