

STRYN, Norway

WMO: 013210

Lat: 61.916N

Lon: 6.558E

Elev: 682

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	11.7	0.3	5.7	15.6	3.8	6.9	17.1	15.4	36.1	13.5	35.6	2.8	150	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	78.7	60.5	74.2	58.8	70.7	57.6	62.8	73.4	61.0	70.6	59.4	67.7	5.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.7	75.7	64.2	57.3	71.8	63.2	55.7	67.8	62.2	28.6	73.9	27.3	70.7	26.3	67.9	67.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.6	8.1	6.1	83.1	4.0	3.4	3.2	85.6	0.8	87.6	-1.4	89.6	-4.3	92.1		
(5)			6.2	64.8	4.6	1.8	2.9	66.1	0.2	67.1	-2.4	68.1	-5.8	69.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.8	29.6	30.3	34.1	41.0	48.2	54.0	59.4	56.9	50.7	42.5	35.0	30.9		
	DBStd	12.35	7.51	7.72	6.04	6.20	6.99	5.22	6.05	5.06	5.51	6.64	7.58	7.97		
	HDD50	3447	632	552	494	277	121	18	2	6	57	247	450	591		
	HDD65	8130	1097	972	959	719	522	331	196	253	428	698	899	1056		
	CDD50	819	0	0	0	8	65	139	293	220	79	14	1	0		
	CDD65	28	0	0	0	0	1	2	22	3	0	0	0	0		
	CDH74	383	0	0	0	0	23	64	267	29	0	0	0	0		
	CDH80	67	0	0	0	0	2	3	61	1	0	0	0	0		
	WSAvg	3.7	3.9	3.6	3.6	3.7	4.1	4.0	3.7	3.2	3.3	3.4	3.5	3.6		
	PrecAvg	62.6	6.7	4.8	5.0	2.8	2.2	2.9	3.3	3.9	7.8	7.4	7.7	8.5		
(15) Precipitation	PrecMax	102.2	23.8	18.3	26.1	7.3	6.8	7.6	6.9	6.4	14.3	20.0	22.6	21.7		
	PrecMin	41.5	0.5	0.3	0.1	0.7	0.6	0.3	0.7	0.8	1.7	2.0	1.1	0.6		
	PrecStd	16.0	5.4	3.8	5.0	1.9	1.3	1.7	1.6	1.5	3.2	4.1	5.0	5.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	50.6	52.2	65.9	77.1	79.9	85.8	77.5	70.3	65.3	55.4	50.1		
		MCWB	39.1	41.9	42.8	49.8	58.3	58.8	64.0	59.5	57.9	52.6	48.8	43.1		
	2%	DB	44.3	45.4	47.2	62.3	71.8	75.4	81.4	73.4	65.7	59.3	51.0	45.9		
		MCWB	37.6	38.9	39.6	48.0	54.7	57.1	62.8	58.8	54.3	49.5	44.5	39.8		
	5%	DB	40.8	42.7	44.5	57.1	67.5	70.3	76.3	70.1	62.7	54.9	48.5	43.4		
		MCWB	36.4	36.3	38.2	45.3	52.6	55.2	61.0	58.3	53.4	47.6	43.2	38.8		
	10%	DB	38.5	40.1	42.4	52.6	62.6	66.1	71.7	66.8	60.0	52.2	45.6	40.8		
		MCWB	34.9	35.2	37.0	43.3	50.4	54.2	59.9	57.3	52.6	46.2	41.7	37.3		
	0.4%	WB	41.3	43.3	44.0	51.7	59.0	60.6	65.8	63.0	59.9	54.4	49.2	44.5		
		MCDB	44.7	48.3	48.4	62.5	74.6	75.6	81.4	71.9	65.2	60.6	53.1	48.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.9	40.2	41.8	48.8	56.1	58.5	64.0	61.2	57.4	51.8	46.7	42.3		
		MCDB	42.0	44.2	45.5	58.4	68.5	71.1	76.9	69.1	62.3	57.5	49.5	45.3		
	5%	WB	37.4	38.0	39.7	46.4	53.7	56.8	62.4	60.0	55.4	49.4	44.4	39.9		
		MCDB	40.1	41.3	42.8	56.0	65.1	67.0	73.1	67.2	60.2	54.3	47.5	42.4		
	10%	WB	35.9	36.0	38.1	44.5	51.4	55.1	60.7	58.7	53.6	47.3	42.1	37.8		
		MCDB	38.2	39.2	41.4	52.1	61.8	63.6	70.5	65.0	58.4	51.3	45.5	40.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	10.5	13.5	16.7	18.1	17.7	16.9	15.4	13.4	11.8	8.5	8.1		
		MCDBR	9.5	11.0	15.2	24.2	26.6	27.5	26.0	21.3	18.2	14.8	11.1	10.8		
		MCWBR	6.6	6.4	9.2	12.7	12.3	12.1	10.3	9.7	9.5	8.7	7.1	7.3		
		MCDBR	8.4	10.3	12.7	21.4	25.1	22.3	22.8	18.2	15.4	13.2	10.5	10.9		
	5% WB	MCWBR	6.5	7.1	8.5	11.8	12.2	10.6	9.7	9.2	9.2	8.9	7.8	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.234	0.283	0.314	0.343	0.347	0.345	0.357	0.349	0.325	0.302	0.244	N/A		
	taud		2.053	2.189	2.193	2.213	2.334	2.411	2.423	2.443	2.498	2.412	2.128	N/A		
	Ebn at Noon		143	215	250	266	276	279	272	265	251	212	138	N/A		
	Edh at Noon		11	21	30	36	35	33	32	29	23	17	10	N/A		
(44) All-Sky Solar Radiation	RadAvg		57	212	573	1097	1473	1535	1453	1109	669	306	88	36		
	RadStd		13	56	111	161	165	158	140	113	92	47	18	5		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page