

MJOLFJELL, Norway

WMO: 013440

Lat: 60.702N

Lon: 6.937E

Elev: 2280

StdP: 13.52

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.5	4.6	-5.2	4.5	6.4	-2.6	5.2	6.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	72.9	57.2	68.6	55.4	64.8	53.5	58.6	69.4	56.9	66.2	55.1	63.1	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.2	67.9	61.2	52.5	63.8	59.7	51.0	60.3	58.2	26.5	69.9	25.3	66.8	24.1	63.3	65.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	DB	-1.3	77.0	2.7	4.0	-3.3	79.9	-4.8	82.2	-6.3	84.5	-8.3	87.3	
			WB	-2.2	60.6	2.7	2.9	-4.1	62.8	-5.7	64.5	-7.2	66.1	-9.1	68.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.6	24.9	24.9	29.9	35.9	43.0	49.2	54.9	53.0	47.2	39.1	32.4	28.0	
	DBStd	12.36	8.22	9.14	7.06	6.52	6.29	4.88	6.09	4.77	5.51	6.18	7.17	8.03	
	HDD50	4541	777	702	623	423	232	73	19	22	118	341	528	683	
	HDD65	9634	1242	1122	1088	872	681	475	319	372	534	803	978	1148	
	CDD50	386	0	0	0	0	16	48	171	115	34	2	0	0	
	CDD65	5	0	0	0	0	0	0	5	0	0	0	0	0	
	CDH74	77	0	0	0	0	1	0	73	3	0	0	0	0	
	CDH80	5	0	0	0	0	0	0	5	0	0	0	0	0	
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Precipitation	PrecAvg	67.5	8.2	5.6	6.0	3.2	3.0	3.4	4.0	4.8	6.0	5.9	6.5	8.2	
	PrecMax	94.5	16.1	14.6	21.3	6.8	5.9	6.9	6.1	7.4	10.4	12.4	12.9	16.9	
	PrecMin	46.4	0.8	0.0	1.1	1.3	0.7	1.0	1.7	2.1	2.0	1.3	0.7	0.5	
	PrecStd	12.4	4.3	3.9	4.4	1.4	1.5	1.6	1.2	1.4	2.5	3.1	3.5	4.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.3	43.2	48.2	56.6	70.6	71.0	80.4	73.4	66.4	57.2	51.1	43.8	
		MCWB	36.5	37.9	38.6	43.6	53.2	54.4	60.2	57.8	53.3	48.5	43.8	40.0	
	2%	DB	38.4	39.7	43.1	52.0	63.3	66.4	75.7	68.7	62.4	52.9	47.3	41.2	
		MCWB	35.2	36.2	36.8	42.1	50.3	51.7	58.5	56.2	52.5	47.1	41.9	38.1	
	5%	DB	36.8	37.5	40.1	49.7	59.0	62.9	71.5	65.0	58.7	50.1	44.0	39.1	
		MCWB	34.1	34.4	35.5	41.3	48.0	50.4	57.2	54.3	50.9	44.7	39.9	36.1	
	10%	DB	34.9	35.7	38.2	47.0	55.0	60.0	66.7	62.0	56.1	47.7	41.6	37.2	
		MCWB	32.6	32.8	34.2	39.5	45.8	49.0	55.4	52.9	49.5	42.9	38.0	34.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.8	39.0	39.9	46.2	54.1	56.1	62.0	59.3	56.4	51.6	44.9	40.7
			MCDB	39.2	41.8	44.8	53.2	67.1	66.6	75.2	69.4	62.9	54.8	49.2	42.5
2%		WB	35.9	36.7	38.0	43.5	51.2	53.9	59.8	57.5	53.8	47.7	42.7	38.7	
		MCDB	37.6	39.0	41.4	50.5	61.5	63.9	72.1	66.5	59.5	51.7	46.1	40.8	
5%		WB	34.4	35.1	36.5	41.4	48.7	52.1	58.1	55.8	51.8	45.8	40.7	36.6	
		MCDB	36.2	37.2	39.4	48.7	58.1	60.5	68.9	63.2	57.8	49.8	43.5	38.5	
10%		WB	32.9	33.2	34.7	39.6	46.3	50.2	56.3	54.1	49.9	43.6	38.0	34.9	
		MCDB	34.6	35.1	37.7	46.2	54.2	57.4	65.7	60.0	55.2	47.0	41.0	36.7	
Mean Daily Temperature Range		5% DB	MDBR	9.7	10.5	12.5	14.4	15.2	16.1	15.3	13.4	11.7	10.1	8.5	9.0
			MCDBR	9.2	8.5	13.3	18.0	22.3	23.0	24.0	19.0	17.2	13.2	10.5	9.0
	MCWBR		7.6	6.7	8.5	10.0	11.6	11.1	9.3	8.6	9.1	8.5	7.7	7.6	
	5% WB	MCDBR	8.8	8.6	12.1	16.3	20.9	19.5	20.9	17.1	15.2	11.0	10.1	9.2	
		MCWBR	7.6	7.2	8.4	9.3	11.4	10.4	8.8	8.7	8.5	8.2	8.3	8.1	
Clear-Sky Solar Irradiance	taub	0.222	0.264	0.296	0.329	0.334	0.331	0.344	0.336	0.309	0.290	0.234	0.194		
	taud	2.106	2.231	2.202	2.180	2.327	2.443	2.435	2.450	2.516	2.442	2.166	1.989		
	Ebn at Noon	172	234	262	273	282	285	278	271	261	226	164	127		
	Edh at Noon	12	21	30	37	35	32	32	29	23	17	11	9		
All-Sky Solar Radiation	RadAvg	77	240	641	1219	1520	1521	1456	1131	713	329	108	51		
	RadStd	19	69	126	207	254	177	176	104	85	48	17	7		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page