

FINSEVATN, Norway

WMO: 013500

Lat: 60.593N

Lon: 7.524E

Elev: 3963

StdP: 12.71

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-11.9	-21.8	1.9	-16.7	-16.9	2.5	-11.6	46.3	24.1	42.5	23.3	3.0	270	0.937

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	62.9	52.2	59.4	50.5	56.4	49.6	54.1	60.1	52.5	57.6	50.5	55.2	9.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
51.4	65.2	56.1	49.7	61.1	54.7	47.9	57.1	52.9	24.2	60.2	23.1	57.6	21.9	55.3	58.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.2	33.0	29.1	-22.8	66.8	5.7	3.8	-26.9	69.5	-30.3	71.7	-33.5	73.8	-37.6	76.6		
(5)			-23.1	55.2	5.2	2.7	-26.9	57.1	-29.9	58.7	-32.8	60.2	-36.6	62.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	30.3	15.6	16.3	18.8	25.4	33.2	41.3	48.0	47.2	41.0	32.1	24.4	19.0		
	DBStd	14.07	11.47	10.83	10.21	7.92	6.06	4.60	5.37	4.46	5.01	7.00	8.80	11.21		
	HDD50	7274	1067	943	968	737	521	263	105	111	272	556	769	962		
	HDD65	12680	1532	1363	1433	1187	986	711	527	553	721	1021	1219	1427		
	CDD50	69	0	0	0	0	0	2	43	23	1	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.5	15.9	14.5	14.6	11.5	9.6	9.4	9.7	10.1	12.9	12.1	13.7	15.6		
	PrecAvg	39.4	4.3	3.4	3.1	2.0	1.9	2.5	3.2	3.5	3.7	4.0	3.7	4.2		
(15) Precipitation	PrecMax	54.2	9.5	7.2	11.8	3.5	3.5	5.4	5.2	5.8	5.9	7.6	8.5	10.4		
	PrecMin	24.8	0.3	0.2	0.3	0.9	0.3	0.7	1.5	1.3	1.6	1.0	0.5	0.4		
	PrecStd	6.8	2.4	2.1	2.2	0.7	0.8	1.1	0.9	1.0	1.2	1.7	2.0	2.6		
	PrecStd	6.8	2.4	2.1	2.2	0.7	0.8	1.1	0.9	1.0	1.2	1.7	2.0	2.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	35.9	37.9	39.7	44.6	55.3	62.0	68.4	64.8	57.6	50.9	41.9	39.1			
	0.4% MCWB	33.7	34.5	34.7	37.5	44.3	48.3	54.9	52.4	46.6	46.7	39.2	36.5			
	2% DB	33.2	34.5	35.7	41.2	48.1	57.5	64.7	60.6	54.2	46.5	39.4	36.6			
	2% MCWB	31.8	32.9	32.8	36.3	40.7	47.2	53.2	52.3	47.9	42.7	37.8	34.9			
	5% DB	31.5	31.9	33.6	38.6	44.6	53.2	61.4	57.4	51.0	43.6	37.3	34.0			
	5% MCWB	30.4	31.0	32.0	35.2	39.0	45.0	52.1	50.8	47.1	40.6	35.9	32.6			
	10% DB	29.0	29.4	31.6	36.2	41.8	50.2	58.0	54.6	48.5	41.0	34.9	31.6			
	10% MCWB	28.1	28.3	30.3	33.7	37.6	43.7	50.7	49.7	45.5	38.8	33.6	30.5			
	0.4% WB	34.6	35.3	36.0	39.3	45.0	50.4	56.7	54.9	51.3	48.1	40.3	37.7			
	0.4% MCDB	35.6	36.5	38.5	42.6	53.4	58.5	64.4	59.8	53.3	50.6	41.3	38.9			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	32.2	33.0	33.8	37.5	42.1	48.3	55.0	53.2	49.1	43.5	38.3	35.0			
	2% MCDB	33.0	34.1	34.9	39.9	47.2	54.7	61.9	58.0	52.3	45.7	39.4	36.3			
	5% WB	30.3	30.9	32.3	35.9	39.9	46.1	53.7	51.5	47.4	41.3	35.9	32.6			
	5% MCDB	31.2	31.7	33.6	38.5	44.1	51.9	59.8	55.9	50.6	43.3	37.1	33.6			
	10% WB	28.1	28.4	29.8	34.0	38.2	44.2	51.9	49.9	45.7	39.3	33.8	30.2			
	10% MCDB	28.8	29.3	31.4	36.4	41.7	49.4	57.2	53.9	48.7	41.1	34.8	31.0			
(35) Mean Daily Temperature Range	MDBR	11.8	11.9	12.9	15.0	11.8	13.0	11.3	9.6	8.5	8.9	9.1	12.1			
	5% DB	10.4	10.4	12.9	18.3	17.2	20.3	18.2	14.8	13.7	12.6	9.5	11.1			
	5% WB	9.9	9.5	11.1	13.7	11.4	12.1	8.8	8.3	8.5	8.9	8.4	10.8			
	MCDBR	10.4	10.1	11.3	14.9	15.6	18.3	15.6	13.2	11.9	10.4	8.9	11.1			
	MCWBR	10.1	9.5	9.4	11.0	10.4	11.6	8.4	8.3	8.2	8.2	8.0	10.5			
	MCWBR	10.1	9.5	9.4	11.0	10.4	11.6	8.4	8.3	8.2	8.2	8.0	10.5			
(40) Clear-Sky Solar Irradiance	taub	0.198	0.237	0.267	0.297	0.303	0.303	0.315	0.308	0.282	0.260	0.206	0.169			
	taud	2.139	2.267	2.235	2.209	2.295	2.468	2.472	2.482	2.545	2.433	2.160	1.995			
	Ebn at Noon	193	250	275	286	292	295	288	282	273	239	183	149			
	Edh at Noon	12	20	29	36	36	31	30	28	22	17	11	8			
	RadAvg	80	245	650	1232	1521	1520	1455	1134	718	331	110	53			
(45) All-Sky Solar Radiation	RadStd	20	69	125	208	257	179	179	103	85	48	17	7			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page