

FINSEVATN, Norway

WMO: 013500

Lat: 60.593N

Lon: 7.524E

Elev: 1208

StdP: 87.63

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.2	-24.4	-29.9	0.3	-27.1	-27.1	0.4	-24.2	20.7	-4.4	19.0	-4.8	1.4	270	0.937

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	17.2	11.2	15.2	10.3	13.5	9.8	12.3	15.6	11.4	14.2	10.3	12.9	4.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.3	13.4	9.8	8.7	12.6	8.8	8.2	11.6	38.3	15.7	35.8	14.2	33.1	12.9	14.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 16.6	14.7	13.0		-30.5	19.3	3.2	2.1	-32.7	20.8	-34.6	22.1	-36.4	23.2	-38.7	24.8	
(5)				-30.6	12.9	2.9	1.5	-32.7	14.0	-34.4	14.8	-36.0	15.7	-38.1	16.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-1.0	-9.1	-8.7	-7.4	-3.6	0.7	5.2	8.9	8.4	5.0	0.0	-4.2	-7.2
	DBStd	7.81	6.37	6.01	5.67	4.40	3.37	2.55	2.98	2.48	2.78	3.89	4.89	6.23
	HDD10.0	4041	593	524	538	409	289	146	58	62	151	309	427	534
	HDD18.3	7044	851	757	796	659	548	395	293	307	401	567	677	793
	CDD10.0	38	0	0	0	0	0	1	24	13	1	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.6	7.1	6.5	6.5	5.2	4.3	4.2	4.3	4.5	5.8	5.4	6.1	7.0
Precipitation	PrecAvg	1002	108	87	80	50	49	63	81	89	95	101	94	107
	PrecMax	1377	241	183	299	89	90	136	132	147	149	194	217	265
	PrecMin	629	8	5	8	22	8	18	38	32	40	26	13	11
	PrecStd	173	61	53	57	17	21	29	24	26	31	44	50	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	3.3	4.3	7.0	12.9	16.7	20.2	18.2	14.2	10.5	5.5	3.9
		MCWB	1.0	1.4	1.5	3.1	6.9	9.0	12.7	11.3	8.1	4.2	1.6	2.5
	2%	DB	0.7	1.4	2.1	5.1	8.9	14.2	18.2	15.9	12.4	8.1	4.1	2.5
		MCWB	-0.1	0.5	0.4	2.4	4.8	8.4	11.8	11.3	8.8	5.9	3.2	1.6
	5%	DB	-0.3	-0.1	0.9	3.6	7.0	11.8	16.4	14.1	10.6	6.5	3.0	1.1
		MCWB	-0.9	-0.6	0.0	1.8	3.9	7.2	11.2	10.5	8.4	4.8	2.2	0.3
	10%	DB	-1.7	-1.5	-0.2	2.3	5.5	10.1	14.5	12.6	9.2	5.0	1.6	-0.2
		MCWB	-2.2	-2.0	-1.0	0.9	3.1	6.5	10.4	9.8	7.5	3.8	0.9	-0.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.4	1.8	2.2	4.1	7.2	10.2	13.7	12.7	10.7	9.0	4.6	3.2
		MCDB	2.0	2.5	3.6	5.9	11.9	14.7	18.0	15.4	11.8	10.3	5.2	3.8
	2%	WB	0.1	0.6	1.0	3.0	5.6	9.0	12.8	11.8	9.5	6.4	3.5	1.7
		MCDB	0.5	1.2	1.6	4.4	8.4	12.6	16.6	14.4	11.3	7.6	4.1	2.4
	5%	WB	-0.9	-0.6	0.2	2.2	4.4	7.8	12.0	10.9	8.6	5.2	2.2	0.3
		MCDB	-0.5	-0.1	0.9	3.6	6.7	11.0	15.4	13.3	10.4	6.3	2.8	0.9
	10%	WB	-2.2	-2.0	-1.2	1.1	3.4	6.8	11.1	9.9	7.6	4.1	1.0	-1.0
		MCDB	-1.8	-1.5	-0.3	2.5	5.4	9.6	14.0	12.2	9.3	5.0	1.5	-0.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	6.6	7.2	8.3	6.6	7.2	6.3	5.3	4.7	4.9	5.0	6.7
		MCDBR	5.8	5.8	7.2	10.2	9.6	11.3	10.1	8.2	7.6	7.0	5.3	6.2
		MCWBR	5.5	5.3	6.1	7.6	6.4	6.7	4.9	4.6	4.7	4.9	4.7	6.0
	5% WB	MCDBR	5.8	5.6	6.3	8.3	8.7	10.2	8.7	7.3	6.6	5.8	4.9	6.2
		MCWBR	5.6	5.3	5.2	6.1	5.8	6.5	4.6	4.6	4.6	4.6	4.4	5.8
Clear-Sky Solar Irradiance	taub	0.198	0.237	0.267	0.297	0.303	0.303	0.315	0.308	0.282	0.260	0.206	0.169	
	taud	2.139	2.267	2.235	2.209	2.295	2.468	2.472	2.482	2.545	2.433	2.160	1.995	
	Ebn at Noon	607	788	868	901	922	929	907	888	860	755	577	469	
	Edh at Noon	37	63	91	114	114	98	96	87	68	53	35	26	
All-Sky Solar Radiation	RadAvg	0.25	0.77	2.05	3.88	4.79	4.79	4.59	3.57	2.26	1.04	0.35	0.17	
	RadStd	0.06	0.22	0.39	0.66	0.81	0.56	0.56	0.32	0.27	0.15	0.06	0.02	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page