

FILEFJELL, Norway

WMO: 013640

Lat: 61.1778N

Lon: 8.1125E

Elev: 3134

StdP: 13.11

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.0	-10.9	-21.8	1.8	-17.0	-15.4	2.7	-10.8	32.7	27.8	28.6	28.6	2.2	100	0.752

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	69.7	54.5	66.5	53.2	62.9	51.8	57.1	65.3	55.3	62.9	53.6	60.4	6.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.9	69.5	59.1	52.0	64.6	57.5	50.1	60.3	55.9	25.8	65.3	24.6	63.0	23.4	60.5	64.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.3	22.0	18.9	DB	-20.0	73.0	6.5	3.4	-24.7	75.4	-28.5	77.4	-32.1	79.3	-36.9	81.8	(4)
(5)			WB	-18.3	59.9	7.6	2.2	-23.8	61.6	-28.3	62.9	-32.6	64.1	-38.2	65.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.4	18.2	18.1	22.4	30.0	39.4	47.2	52.4	49.8	43.6	34.3	24.3	19.8	
	DBStd	15.02	11.92	11.62	10.20	7.52	6.25	4.72	5.35	5.13	5.32	6.45	10.39	12.32	
	HDD50	6273	987	894	856	599	332	108	37	67	200	486	771	936	
	HDD65	11539	1452	1314	1321	1049	794	533	390	471	642	951	1221	1401	
	CDD50	210	0	0	0	0	3	24	112	61	9	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	8	0	0	0	0	0	1	6	1	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	7.9	9.1	9.1	9.9	7.7	7.1	7.2	6.5	6.3	7.6	7.8	7.7	8.7	
Precipitation	PrecAvg	26.9	2.2	1.9	2.0	1.3	1.5	2.3	3.0	3.2	2.5	2.4	2.4	2.2	
	PrecMax	39.0	5.8	4.1	7.3	2.6	3.9	5.2	6.4	6.5	4.0	4.1	5.8	4.8	
	PrecMin	19.5	0.0	0.0	0.4	0.5	0.2	0.6	0.9	0.9	0.9	0.9	0.4	0.2	
	PrecStd	4.4	1.6	1.2	1.3	0.5	0.8	1.1	1.3	1.2	0.7	1.0	1.3	1.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.6	40.6	42.6	50.5	65.7	69.0	74.4	72.5	64.3	54.5	44.8	42.2	
		MCWB	35.5	36.0	36.9	41.0	50.6	51.6	57.5	55.0	51.9	48.1	40.4	38.3	
	2%	DB	37.9	37.9	39.6	46.6	59.4	64.6	71.1	68.1	59.4	48.8	41.9	39.5	
		MCWB	34.3	34.7	35.3	38.5	47.8	50.3	55.9	53.6	50.2	43.8	38.4	36.4	
	5%	DB	35.8	35.5	37.9	43.3	55.1	60.6	68.3	64.0	55.8	46.2	39.5	37.2	
		MCWB	32.6	32.0	34.1	37.2	45.1	48.6	54.6	52.6	48.5	42.1	36.5	34.6	
	10%	DB	33.1	32.9	35.7	40.8	50.8	57.3	64.8	60.1	52.8	43.6	36.7	34.5	
		MCWB	30.2	30.0	32.0	35.8	42.6	47.5	53.3	51.4	47.3	40.1	34.0	32.1	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.8	36.9	38.0	42.9	52.6	55.1	60.2	57.9	53.9	49.0	41.5	38.8
			MCDB	39.8	39.5	41.3	49.1	62.8	63.8	69.4	64.6	59.7	53.2	44.7	41.4
2%		WB	34.8	34.9	36.0	39.5	48.7	52.7	58.2	55.8	51.7	45.0	39.0	36.8	
		MCDB	37.6	37.8	39.2	44.6	57.4	59.1	67.2	63.1	57.3	48.0	41.5	39.3	
5%		WB	32.8	32.4	34.4	37.7	46.2	50.8	56.4	54.1	50.0	42.7	36.9	34.6	
		MCDB	35.6	35.2	37.6	42.2	52.9	57.6	64.6	61.2	54.4	45.4	39.4	36.9	
10%		WB	30.3	30.0	32.2	36.3	43.8	48.9	54.8	52.5	48.2	40.2	34.2	32.2	
		MCDB	32.9	32.8	35.4	40.6	49.9	55.4	62.2	58.9	52.0	43.3	36.4	34.3	
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.8	14.1	14.3	14.6	15.7	16.5	15.6	12.8	10.3	10.8	11.8	
		MCDBR	11.4	10.1	11.9	16.9	24.4	24.4	25.6	22.8	20.8	14.7	11.6	10.3	
		MCWBR	9.9	8.8	9.2	10.8	14.2	12.6	12.5	10.7	13.0	11.0	9.6	8.9	
	5% WB	MCDBR	11.0	10.7	11.2	15.3	21.8	18.5	21.1	18.0	16.5	11.3	11.4	10.2	
		MCWBR	10.1	9.7	9.1	10.2	13.8	11.3	11.9	10.3	11.4	9.2	9.8	9.2	
Clear-Sky Solar Irradiance	taub	0.197	0.241	0.272	0.302	0.309	0.309	0.322	0.314	0.285	0.264	0.206	0.166		
	taud	2.123	2.264	2.240	2.224	2.304	2.457	2.470	2.481	2.546	2.425	2.145	1.974		
	Ebn at Noon	184	245	272	283	290	292	285	279	270	234	174	137		
	Edh at Noon	11	19	29	36	36	31	30	28	22	17	11	8		
All-Sky Solar Radiation	RadAvg	86	278	721	1283	1552	1585	1472	1140	728	336	112	51		
	RadStd	16	62	100	173	193	163	170	98	84	50	19	5		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (55 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page