

BEITOSTOLEN II, Norway

WMO: 013650

Lat: 61.251N

Lon: 8.923E

Elev: 965

StdP: 90.26

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.7	-16.0	-21.7	0.6	-16.2	-20.0	0.7	-14.9	13.0	-3.1	11.2	-2.0	2.0	0	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	20.9	12.9	19.0	12.2	17.0	11.3	14.3	18.3	13.2	16.9	12.4	15.7	3.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.7	10.3	14.9	11.8	9.7	14.3	10.8	9.1	13.5	43.1	18.2	40.2	17.0	37.8	15.7	16.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.0	7.6	DB	-19.8	22.8	2.6	2.2	-21.6	24.4	-23.1	25.7	-24.6	26.9	-26.4	28.6	(4)
(5)			WB	-19.9	15.7	2.6	0.9	-21.8	16.3	-23.4	16.8	-24.8	17.3	-26.7	18.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	1.6	-7.3	-6.1	-4.0	-0.1	5.1	9.4	12.0	10.2	6.9	1.4	-3.3	-5.6	(6)
(7)		DBStd	7.70	4.56	4.61	4.38	3.97	4.57	2.75	3.37	2.26	2.98	3.38	4.14	4.63	(7)
(8)		HDD10.0	3218	536	450	433	304	163	42	16	25	102	266	401	482	(8)
(9)		HDD18.3	6106	794	683	691	554	409	267	197	252	344	523	651	741	(9)
(10)		CDD10.0	156	0	0	0	0	12	25	78	31	8	1	0	0	(10)
(11)		CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(11)
(12)		CDH23.3	5	0	0	0	0	0	1	4	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.1	3.5	4.2	3.7	3.5	3.3	3.0	2.7	3.1	3.0	2.9	3.4	(14)
(15)	Precipitation	PrecAvg	787	62	39	39	41	53	79	100	104	72	74	70	53	(15)
(16)		PrecMax	1083	127	84	73	90	168	183	198	192	128	165	181	102	(16)
(17)		PrecMin	571	17	12	7	12	2	6	30	16	26	18	21	9	(17)
(18)		PrecStd	103	27	19	18	22	33	39	43	42	26	36	34	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.2	5.2	8.1	12.4	20.5	21.6	23.9	20.0	17.4	12.9	7.6	5.6	(19)
(20)			MCWB	2.0	2.6	4.0	6.0	10.4	11.7	14.9	12.5	11.5	10.6	4.4	3.8	(20)
(21)		2%	DB	2.6	3.6	5.5	9.7	17.3	18.9	22.0	17.6	15.2	9.6	5.3	4.0	(21)
(22)			MCWB	0.7	1.4	2.5	5.0	10.1	10.7	14.1	12.0	10.5	6.5	3.4	2.4	(22)
(23)		5%	DB	0.6	1.7	3.9	7.4	14.5	16.6	20.2	15.9	13.1	7.7	3.7	2.3	(23)
(24)			MCWB	-0.9	-0.5	1.4	3.3	8.5	9.6	13.3	11.2	9.3	4.8	2.5	0.8	(24)
(25)		10%	DB	-1.1	0.1	2.4	5.5	12.1	14.5	18.2	14.3	11.3	5.9	2.0	0.5	(25)
(26)			MCWB	-2.3	-1.6	0.1	2.4	7.7	8.8	12.6	10.6	8.5	3.5	0.8	-0.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.3	3.0	4.2	7.0	12.4	13.3	16.0	14.2	12.7	11.0	5.0	4.2	(27)
(28)			MCDWB	3.7	4.8	7.3	11.8	18.0	16.0	22.0	16.6	15.3	12.4	7.0	5.5	(28)
(29)		2%	WB	0.6	1.7	2.7	5.1	10.7	12.2	15.0	13.1	11.2	7.5	3.6	2.4	(29)
(30)			MCDWB	2.1	3.5	5.2	9.0	15.3	16.0	19.8	15.5	13.7	9.3	4.7	3.7	(30)
(31)		5%	WB	-0.8	-0.1	1.6	3.7	9.3	11.3	14.1	12.2	10.2	5.5	2.5	0.8	(31)
(32)			MCDWB	0.6	1.4	3.7	6.9	13.8	14.5	18.4	14.9	12.5	6.8	3.7	2.2	(32)
(33)		10%	WB	-2.1	-1.5	0.2	2.5	8.0	10.2	13.2	11.3	9.1	4.0	0.9	-0.7	(33)
(34)			MCDWB	-1.2	-0.1	2.1	5.4	11.8	13.7	17.1	13.6	11.2	5.6	1.7	0.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	4.7	5.8	6.4	7.2	8.2	8.0	7.0	6.2	5.0	4.2	4.5	(35)
(36)			MCDBR	5.6	5.6	6.3	8.3	10.4	11.5	10.8	9.2	8.9	7.5	5.3	6.2	(36)
(37)			MCWBR	4.7	4.4	4.7	4.9	5.4	6.1	5.1	4.7	5.1	5.2	4.5	5.4	(37)
(38)		5% WB	MCDWB	5.1	5.1	6.2	7.6	9.1	8.3	9.2	7.8	7.8	6.2	5.1	6.1	(38)
(39)			MCWBR	4.5	4.1	4.8	4.6	5.1	5.3	4.7	4.7	4.8	4.8	4.4	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.192	0.235	0.265	0.296	0.305	0.305	0.317	0.309	0.281	0.263	0.204	0.159	(40)	
(41)		taud	2.159	2.297	2.295	2.318	2.447	2.533	2.510	2.518	2.585	2.496	2.206	1.999	(41)	
(42)		Ebn at Noon	598	785	870	903	921	926	904	884	859	749	566	454	(42)	
(43)		Edh at Noon	34	59	85	102	98	92	92	84	65	49	31	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.30	0.97	2.48	4.28	4.98	5.08	4.66	3.63	2.35	1.08	0.37	0.17	(44)	
(45)		RadStd	0.05	0.18	0.27	0.49	0.53	0.50	0.55	0.28	0.25	0.16	0.06	0.01	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (51 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page