

EVENSTAD-DIH, Norway

WMO: 013830

Lat: 61.425N

Lon: 11.080E

Elev: 837

StdP: 14.26

Time Zone: 1.00 (EUC)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.7	-8.7	-17.8	2.1	-14.0	-12.7	2.8	-9.0	20.6	34.9	18.7	33.7	2.0	310	0.647

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	79.2	61.9	75.5	61.2	71.5	59.1	65.0	73.7	63.0	70.9	61.2	68.4	6.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.8	85.0	67.4	60.1	80.1	65.7	58.4	75.1	63.7	30.4	73.9	28.9	70.6	27.6	68.5	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.4	15.1	13.3	DB	-18.2	83.2	6.4	3.8	-22.9	86.0	-26.6	88.2	-30.2	90.4	-34.9	93.2	
			WB	-20.7	67.9	6.0	2.6	-25.0	69.8	-28.6	71.3	-31.9	72.7	-36.3	74.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.8	15.6	18.9	27.7	38.1	47.4	55.1	59.7	56.6	49.4	38.0	27.6	18.5
	DBStd	17.46	12.93	11.28	9.36	5.72	7.05	5.77	5.19	4.74	5.57	6.75	9.01	12.76
	HDD50	5245	1065	871	691	358	135	16	0	5	77	377	673	977
	HDD65	9942	1530	1291	1156	807	546	300	178	262	469	838	1123	1442
	CDD50	798	0	0	0	1	54	170	302	210	58	3	0	0
	CDD65	20	0	0	0	0	0	3	15	2	0	0	0	0
	CDH74	454	0	0	0	0	46	132	239	37	0	0	0	0
	CDH80	60	0	0	0	0	3	18	37	2	0	0	0	0
Wind	WSAvg	5.1	4.7	5.5	5.9	5.6	5.3	5.2	4.9	4.6	5.0	4.9	4.6	5.0
Precipitation	PrecAvg	30.6	2.2	1.5	1.3	1.7	2.7	3.1	3.7	4.1	2.8	2.8	2.7	2.0
	PrecMax	41.7	4.0	3.5	3.4	4.1	5.9	5.8	7.5	7.7	5.3	7.6	8.7	3.5
	PrecMin	23.2	0.5	0.4	0.0	0.2	0.1	0.1	0.8	1.1	1.3	0.5	0.9	0.2
	PrecStd	4.2	1.0	0.7	0.7	0.9	1.4	1.3	1.5	1.4	1.1	1.6	1.7	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	45.0	53.4	65.0	79.2	82.5	84.3	78.1	69.0	58.1	50.3	45.1
		MCWB	38.1	39.2	43.5	50.3	59.0	61.8	66.2	61.7	57.9	51.6	48.6	41.9
	2%	DB	38.9	40.2	47.5	59.6	73.0	78.1	80.1	73.6	65.5	54.3	45.5	41.1
		MCWB	35.8	36.4	39.8	47.0	56.8	59.9	64.1	61.1	56.7	50.2	43.9	38.4
	5%	DB	35.3	36.3	43.7	54.7	68.0	73.1	76.3	70.0	62.4	51.4	42.7	38.3
		MCWB	33.6	34.2	37.1	44.6	53.7	58.5	62.7	59.6	55.0	47.9	41.4	36.0
	10%	DB	32.9	33.7	40.0	50.4	62.0	68.4	72.1	66.6	59.5	48.6	38.8	35.4
		MCWB	31.8	32.5	35.2	41.9	50.8	56.3	61.0	58.5	53.7	46.0	37.3	33.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.9	40.1	44.1	51.5	61.5	64.0	68.8	65.4	60.8	54.5	49.0	42.3
		MCDB	41.8	44.0	52.7	60.9	73.7	73.9	78.7	71.6	65.3	56.7	50.3	44.8
	2%	WB	36.4	36.9	40.4	48.2	58.3	61.9	66.4	63.3	58.9	51.3	44.6	39.0
		MCDB	38.4	39.5	46.3	57.8	71.0	72.9	76.6	69.5	63.1	53.7	45.4	40.9
	5%	WB	33.8	34.6	37.9	45.3	55.5	59.9	64.4	61.8	56.9	48.8	41.9	36.4
		MCDB	35.1	36.1	42.3	53.8	65.1	70.4	73.1	67.5	61.2	50.8	43.0	38.1
	10%	WB	31.8	32.5	35.8	42.8	52.3	57.9	62.4	60.1	55.0	46.7	38.0	33.9
		MCDB	32.9	33.8	39.5	48.9	61.0	66.9	70.2	65.4	58.8	49.0	39.0	35.3
Mean Daily Temperature Range	5% DB	MDBR	12.5	15.1	19.4	20.2	21.1	21.3	19.9	18.6	18.0	12.9	9.8	12.2
		MCDBR	12.4	16.1	22.2	29.3	32.5	30.7	28.2	25.0	23.1	17.6	12.5	14.9
		MCWBR	11.1	13.8	14.3	17.5	16.7	15.3	14.5	12.6	13.2	11.9	10.3	12.1
	5% WB	MCDBR	13.0	15.9	19.7	27.9	29.7	26.8	25.2	19.7	17.4	14.3	11.1	14.0
		MCWBR	10.8	12.5	13.1	16.9	15.3	13.6	13.5	11.3	11.5	11.3	10.3	12.1
Clear-Sky Solar Irradiance	taub	0.220	0.270	0.302	0.340	0.350	0.344	0.361	0.352	0.318	0.302	0.237	0.186	
	taud	2.112	2.233	2.224	2.235	2.405	2.470	2.433	2.452	2.529	2.472	2.195	1.996	
	Ebn at Noon	164	226	258	269	277	280	271	265	256	217	155	118	
	Edh at Noon	11	20	29	36	33	31	32	29	22	16	10	7	
All-Sky Solar Radiation	RadAvg	91	305	808	1354	1503	1660	1509	1167	755	338	110	51	
	RadStd	15	61	72	128	144	157	188	104	92	57	24	5	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (53 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page