

DREVSJO, Norway

WMO: 013930

Lat: 61.890N

Lon: 12.033E

Elev: 674

StdP: 93.49

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -29.9	(c) -26.7	(d) -33.0	(e) 0.2	(f) -29.9	(g) -29.4	(h) 0.3	(i) -26.6	(j) 7.4	(k) -1.2	(l) 6.7	(m) -1.7	(n) 0.8	(o) 290	(p) 0.706

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	23.3	14.0	21.4	13.5	19.3	12.6	15.6	20.9	14.5	19.2	13.5	17.9	2.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	10.4	17.2	12.4	9.7	16.2	11.5	9.1	15.2	45.7	20.9	42.6	19.1	39.8	18.0	18.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.9	5.2	-33.2	26.1	2.7	1.8	-35.1	27.4	-36.7	28.4	-38.2	29.4	-40.2	30.7		
			-33.4	16.4	2.6	1.5	-35.2	17.5	-36.7	18.4	-38.2	19.2	-40.0	20.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.9	-9.9	-8.8	-5.6	-0.1	5.4	9.4	12.6	10.6	7.0	1.3	-3.4	-7.8
	DBStd	9.09	7.35	6.27	6.05	4.08	4.09	3.37	3.05	2.73	3.16	3.88	4.52	6.81
	HDD10.0	3494	618	527	483	302	153	52	11	26	98	271	401	553
	HDD18.3	6351	876	760	741	552	401	269	180	239	340	529	651	812
	CDD10.0	186	0	0	0	0	11	33	89	45	8	1	0	0
	CDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH23.3	54	0	0	0	0	2	12	38	1	0	0	0	0
	CDH26.7	3	0	0	0	0	0	1	2	0	0	0	0	0
(14) Wind	WSAvg	2.2	1.8	1.9	2.3	2.3	2.5	2.6	2.3	2.1	2.2	2.1	1.9	1.8
(15) Precipitation	PrecAvg	651	44	30	30	37	58	69	82	88	58	60	51	39
	PrecMax	871	81	56	58	99	116	149	139	131	111	130	134	81
	PrecMin	521	12	6	7	4	9	7	21	33	13	14	22	5
	PrecStd	86	20	13	13	22	31	30	31	32	26	35	24	16
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.1	5.2	9.2	14.4	23.1	25.0	26.5	22.5	18.8	13.7	8.4	5.2
		MCWB	1.8	1.9	4.3	7.5	12.3	13.4	16.1	14.1	12.3	10.4	6.7	3.4
	2%	DB	2.5	3.4	6.6	11.9	20.2	22.5	24.3	20.1	16.4	10.5	6.3	3.6
		MCWB	0.9	1.0	2.6	5.8	11.6	12.8	15.5	13.1	11.1	7.8	4.8	2.0
	5%	DB	1.0	1.6	4.5	9.7	17.2	19.6	22.2	18.3	14.6	8.8	4.4	2.4
		MCWB	-0.3	-0.1	1.4	4.5	10.0	11.7	14.4	12.8	10.7	6.5	3.2	1.0
	10%	DB	-0.3	0.1	2.8	7.4	13.9	17.1	20.1	16.6	12.9	7.4	2.8	0.8
		MCWB	-1.4	-1.2	0.3	3.2	8.5	10.9	13.5	12.2	9.9	5.7	1.6	-0.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	2.8	4.5	8.2	13.7	15.1	17.6	15.7	13.2	10.7	6.8	3.6
		MCDB	3.6	4.8	8.0	12.5	20.0	20.3	23.4	19.7	16.4	13.0	8.3	4.8
	2%	WB	1.1	1.2	2.9	6.3	12.2	13.7	16.3	14.6	12.2	8.3	4.9	2.2
		MCDB	2.4	2.9	5.9	11.1	18.9	19.8	22.2	17.9	15.0	10.1	6.1	3.5
	5%	WB	-0.1	0.0	1.7	4.8	10.8	12.6	15.2	13.6	11.1	6.8	3.4	1.0
		MCDB	1.1	1.6	4.2	9.2	16.5	18.8	20.9	16.9	14.0	8.4	4.4	2.2
	10%	WB	-1.4	-1.2	0.5	3.6	9.0	11.4	14.2	12.7	10.1	5.8	1.7	-0.3
		MCDB	-0.4	0.1	2.7	7.0	13.9	16.5	19.2	15.9	12.6	7.4	2.6	0.7
(35) Mean Daily Temperature Range	MDBR		9.2	10.5	11.9	11.0	10.9	10.9	10.9	10.1	9.3	7.6	7.0	8.5
	5% DB	MCDBR	7.0	9.6	11.7	15.0	17.6	16.6	15.8	13.8	13.0	9.8	7.5	7.5
		MCWBR	6.3	7.8	8.2	9.4	9.5	8.4	8.0	8.4	7.4	6.5	6.8	
	5% WB	MCDBR	6.9	8.6	10.6	13.6	15.3	14.1	14.1	10.6	10.7	8.0	7.2	7.5
		MCWBR	6.4	7.1	7.6	8.6	8.5	7.3	7.4	6.5	7.4	6.5	6.4	6.9
(40) Clear-Sky Solar Irradiance	taub		0.201	0.253	0.282	0.316	0.327	0.322	0.337	0.328	0.298	0.282	0.215	0.171
	taud		2.097	2.255	2.257	2.297	2.458	2.510	2.475	2.490	2.556	2.486	2.171	1.979
	Ebn at Noon		532	736	836	875	896	906	880	859	829	707	502	370
	Edh at Noon		33	60	87	104	97	94	95	86	67	49	31	20
(44) All-Sky Solar Radiation	RadAvg		0.27	0.92	2.47	4.21	4.76	5.12	4.69	3.63	2.33	1.04	0.33	0.14
	RadStd		0.03	0.16	0.22	0.36	0.40	0.45	0.57	0.33	0.27	0.16	0.07	0.01

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page