

EKOFISK OIL PLATFORM, Norway

WMO: 014000

Lat: 56.542N

Lon: 3.224E

Elev: 160

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.7	32.8	20.0	15.1	33.9	22.8	17.3	35.3	56.6	39.9	52.4	40.0	26.7	110	0.930

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	67.6	64.4	65.5	62.4	64.0	61.2	64.9	66.9	63.0	65.0	61.6	63.5	13.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.0	66.2	62.2	84.2	64.4	60.8	79.9	63.1	29.9	66.8	28.6	64.8	27.6	63.6	70.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.4	42.5	38.1	DB	29.2	69.4	3.6	4.2	26.6	72.4	24.5	74.9	22.5	77.2	19.9	80.2	(4)
(5)			WB	26.7	64.9	3.3	3.0	24.3	67.1	22.4	68.9	20.5	70.6	18.1	72.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	41.9	40.7	41.3	43.9	48.8	53.7	58.7	60.4	57.2	52.2	47.0	43.7
	DBStd	7.64	3.50	4.10	3.74	3.03	3.53	3.04	3.52	3.18	2.92	3.23	3.49	3.75
	HDD50	1341	250	260	269	182	65	4	0	0	0	16	98	197
	HDD65	5780	715	680	734	632	502	338	198	148	233	398	540	662
	CDD50	1046	0	0	0	1	28	116	270	322	217	84	8	0
	CDD65	8	0	0	0	0	0	0	3	5	0	0	0	0
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	19.4	24.0	22.9	20.8	17.6	16.7	16.0	15.0	15.9	18.5	21.4	22.0	22.2
Precipitation	PrecAvg	44.6	5.5	4.4	3.7	2.2	1.8	2.4	2.8	3.5	3.9	4.3	5.1	5.1
	PrecMax	55.3	9.6	7.3	6.5	3.9	2.7	4.3	4.0	5.7	6.5	6.2	8.1	9.9
	PrecMin	36.1	1.9	1.9	1.3	0.9	0.9	0.9	1.3	1.5	1.8	1.7	3.2	2.5
	PrecStd	4.4	1.9	1.5	1.2	0.7	0.5	0.7	0.8	0.9	1.1	1.2	1.2	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	48.9	49.1	52.3	59.8	62.7	69.8	70.1	65.7	60.0	55.6	51.4
		MCWB	47.9	47.1	46.0	48.1	54.4	58.5	65.6	66.0	61.9	57.5	53.8	49.1
	2%	DB	48.3	47.9	47.5	50.3	56.9	60.6	66.7	68.2	63.5	58.7	53.6	50.1
		MCWB	46.5	46.5	45.5	47.5	53.3	57.5	63.4	65.1	60.5	56.5	51.8	48.4
	5%	DB	47.2	46.5	46.5	48.8	54.8	59.1	64.8	66.3	62.3	57.4	52.2	48.9
		MCWB	45.4	45.1	44.8	46.9	51.9	56.5	61.9	63.4	59.7	55.3	50.3	47.3
	10%	DB	46.3	45.5	45.6	47.9	53.3	57.6	63.4	64.6	61.1	56.3	51.4	48.2
		MCWB	44.4	44.0	44.1	46.3	50.7	55.2	60.8	61.9	58.5	54.0	49.5	46.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.4	48.2	47.1	49.6	56.0	59.6	67.1	68.1	62.8	58.4	54.3	50.1
		MCDB	49.0	48.3	48.1	51.0	58.0	61.4	69.3	69.2	64.6	59.4	55.2	50.5
	2%	WB	46.9	46.6	46.1	48.3	54.0	58.2	64.2	65.6	61.5	57.3	52.4	48.7
		MCDB	47.7	47.2	46.9	49.2	55.9	59.8	66.0	67.5	63.0	58.4	53.3	49.3
	5%	WB	45.9	45.4	45.1	47.3	52.6	57.2	62.7	63.8	60.4	56.1	51.0	47.8
		MCDB	46.7	46.1	45.9	48.3	54.3	58.7	64.5	65.9	61.8	57.2	51.9	48.6
	10%	WB	44.8	44.3	44.3	46.5	51.2	55.9	61.2	62.3	59.3	54.8	50.0	46.8
		MCDB	45.7	45.1	45.2	47.5	52.8	57.4	63.1	64.3	60.9	56.0	50.9	47.8
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.3	4.1	4.1	4.5	4.1	4.1	4.1	3.9	3.7	3.9	4.1
		MCDBR	4.7	4.5	4.6	5.1	6.8	5.9	5.9	5.5	4.8	4.2	4.4	4.1
		MCWBR	5.7	4.6	4.2	4.0	4.7	4.4	4.3	4.5	4.6	4.7	5.2	5.0
	5% WB	MCDBR	4.4	4.1	4.2	4.7	6.1	5.3	5.3	5.0	4.3	4.0	4.0	3.9
		MCWBR	5.6	4.9	4.3	4.0	4.9	4.5	4.4	4.8	4.7	5.1	5.1	5.0
Clear-Sky Solar Irradiance	taub	0.334	0.349	0.367	0.395	0.376	0.380	0.387	0.386	0.375	0.352	0.333	0.311	
	taud	2.205	2.289	2.313	2.275	2.413	2.424	2.419	2.425	2.434	2.390	2.264	2.194	
	Ebn at Noon	167	221	250	260	274	273	269	261	246	219	168	144	
	Edh at Noon	18	24	30	36	34	34	33	31	27	22	17	14	
All-Sky Solar Radiation	RadAvg	133	334	750	1303	1772	1777	1658	1355	898	454	183	97	
	RadStd	16	50	68	95	131	115	183	97	106	33	22	12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page