

SLATTEROY FYR, Norway

WMO: 014060

Lat: 59.908N

Lon: 5.068E

Elev: 52

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	25.9	27.9	12.0	10.2	29.7	15.6	12.2	31.8	41.9	40.6	38.0	40.6	9.8	140	0.745

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	70.5	61.2	67.8	60.5	65.5	59.5	63.7	68.1	62.2	66.0	60.6	64.2	11.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	82.9	65.9	60.3	78.4	64.6	58.8	74.1	63.0	29.1	68.2	28.0	66.0	26.9	64.3	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
37.5	33.1	29.4	DB	23.4	78.2	3.9	4.5	20.6	81.4	18.3	84.1	16.1	86.6	13.2	89.9
			WB	21.4	64.9	4.3	2.3	18.3	66.5	15.8	67.9	13.3	69.2	10.2	70.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	38.0	37.0	38.9	43.6	48.7	53.6	58.3	59.7	56.0	49.8	43.9	39.6	(6)
	DBStd	9.07	4.54	4.74	3.99	4.38	4.70	4.01	4.44	4.18	3.92	4.42	4.77	5.30	(7)
	HDD50	1938	373	363	344	201	80	8	0	0	3	57	187	322	(8)
	HDD65	6474	838	783	809	643	505	344	215	173	272	472	633	787	(9)
	CDD50	959	0	0	0	8	40	116	258	302	182	49	4	0	(10)
	CDD65	21	0	0	0	0	0	2	8	10	1	0	0	0	(11)
	CDH74	33	0	0	0	0	0	1	18	14	0	0	0	0	(12)
	CDH80	4	0	0	0	0	0	0	4	0	0	0	0	0	(13)
(14) Wind	WSAvg	13.6	16.1	14.5	13.7	12.5	12.7	12.4	11.0	12.1	12.9	14.7	14.9	15.3	(14)
(15) Precipitation	PrecAvg	74.4	7.2	5.7	5.7	4.3	3.4	4.3	4.8	6.0	7.4	8.6	8.5	8.2	(15)
	PrecMax	91.0	15.0	13.4	10.4	8.2	7.2	9.6	7.8	9.4	12.8	16.2	15.7	14.4	(16)
	PrecMin	50.9	0.5	0.6	0.2	1.8	0.3	1.1	1.8	2.0	1.9	2.8	1.6	2.2	(17)
	PrecStd	11.5	3.7	3.2	2.6	1.5	1.6	2.0	1.7	1.9	3.2	3.3	3.7	3.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.9	47.2	50.3	62.3	68.3	70.9	75.6	76.1	69.1	63.4	55.6	50.4	(19)
		MCWB	44.8	44.3	44.2	51.0	55.4	57.6	63.0	62.2	60.1	56.5	51.4	48.4	(20)
	2%	DB	46.4	45.5	46.2	55.8	62.5	65.0	70.1	70.7	65.4	59.2	53.1	48.6	(21)
		MCWB	44.0	43.7	42.1	46.7	52.7	57.1	62.0	61.8	57.9	54.0	50.1	46.9	(22)
	5%	DB	45.4	44.6	44.8	52.0	58.5	61.1	67.1	68.1	63.0	56.9	51.5	47.7	(23)
		MCWB	43.2	43.0	42.2	45.6	52.0	55.9	60.9	61.3	57.6	52.9	48.6	45.8	(24)
	10%	DB	44.2	43.6	43.8	49.3	55.2	58.8	64.5	65.8	61.3	55.4	50.1	46.5	(25)
		MCWB	42.2	41.9	41.5	45.0	50.7	54.8	59.6	60.7	56.7	51.9	47.3	44.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	45.6	45.7	53.0	57.6	60.8	65.7	65.7	62.3	57.5	53.0	49.1	(27)
		MCDB	47.1	46.1	47.0	58.3	64.5	65.8	71.1	70.1	65.3	60.9	54.4	49.7	(28)
	2%	WB	44.9	44.4	44.1	48.7	54.4	58.2	63.8	64.1	60.3	55.5	51.0	47.6	(29)
		MCDB	45.9	45.0	45.2	52.9	59.7	62.5	68.2	68.6	63.4	58.1	52.6	48.5	(30)
	5%	WB	43.8	43.4	43.1	46.9	52.5	56.6	61.9	62.8	58.9	54.0	49.3	46.3	(31)
		MCDB	44.9	44.4	44.4	50.2	57.2	60.5	65.8	66.6	61.9	56.3	51.0	47.4	(32)
	10%	WB	42.5	42.1	42.0	45.6	50.7	55.3	60.2	61.3	57.4	52.7	47.7	44.7	(33)
		MCDB	43.9	43.4	43.4	48.5	54.8	58.2	63.7	64.8	60.3	55.0	49.6	46.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.9	5.2	6.1	6.0	5.4	5.3	5.7	5.3	5.3	4.9	5.1	(35)
		MCDBR	6.1	5.1	6.0	11.0	11.9	9.5	10.0	9.6	7.4	6.5	5.7	5.6	(36)
	5% WB	MCWBR	6.0	5.0	4.5	5.7	5.8	5.4	5.5	4.8	4.8	4.8	5.9	6.0	(37)
		MCWBR	5.6	4.8	5.2	8.6	10.2	8.1	8.7	7.5	6.2	6.2	5.8	5.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.303	0.330	0.350	0.378	0.365	0.361	0.375	0.373	0.358	0.335	0.306	0.407	(40)
		taud	2.161	2.285	2.345	2.315	2.427	2.473	2.452	2.455	2.481	2.417	2.234	2.606	(41)
	Ebn at Noon		144	211	247	260	274	277	269	260	244	209	143	103	(42)
		Edh at Noon	14	22	28	34	32	31	31	29	24	19	13	10	(43)
(44) All-Sky Solar Radiation	RadAvg		78	250	607	1136	1601	1709	1501	1154	720	349	114	49	(44)
	RadStd		12	43	88	109	166	205	143	111	75	49	15	7	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-211	N/A	N/A

Nomenclature: See separate page