

KVITSOY NORDBO, Norway

WMO: 014110

Lat: 59.0705N

Lon: 5.4121E

Elev: 72

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.7	27.2	10.3	9.3	28.1	14.3	11.4	30.0	40.6	39.6	36.6	39.5	11.1	60	0.782

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	70.6	62.4	67.8	61.0	65.6	59.9	63.7	68.5	62.1	66.2	60.7	64.3	10.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.4	81.6	66.2	60.1	77.9	64.6	58.9	74.3	63.1	29.0	68.4	27.9	66.5	26.9	64.4	71.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.6	32.4	29.1	DB	24.2	76.7	4.2	3.9	21.2	79.5	18.7	81.8	16.3	83.9	13.3	86.7	(4)
(5)			WB	21.0	65.6	4.1	2.1	18.1	67.1	15.7	68.3	13.4	69.5	10.5	71.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	37.8	36.8	38.7	44.1	49.6	54.6	59.5	60.0	56.5	50.3	44.5	40.7
	DBStd	9.27	4.90	4.79	4.38	4.10	5.00	4.01	4.30	3.37	3.73	4.05	4.90	5.39
	HDD50	1855	380	369	350	184	66	4	0	0	1	44	169	288
	HDD65	6287	845	789	815	628	477	313	182	160	256	455	614	753
	CDD50	1064	0	0	0	7	54	143	294	310	196	54	6	0
	CDD65	19	0	0	0	0	1	1	11	5	1	0	0	0
	CDH74	26	0	0	0	0	0	1	22	3	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	14.5	16.9	14.8	13.7	13.0	13.7	13.4	12.5	13.3	14.6	15.1	16.4	16.4
Precipitation	PrecAvg	62.7	6.4	5.1	4.6	3.5	3.0	3.3	3.8	5.7	6.3	7.2	6.9	7.5
	PrecMax	75.9	11.7	9.8	9.1	6.1	5.9	6.1	6.5	10.2	10.6	11.1	12.6	12.4
	PrecMin	42.1	0.4	1.1	0.1	1.6	1.0	0.9	1.8	1.4	1.8	2.4	1.4	1.5
	PrecStd	9.1	3.0	2.6	2.2	1.0	1.2	1.4	1.2	1.9	2.6	2.6	3.0	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	46.4	50.7	59.5	68.9	71.5	77.0	72.6	69.0	61.8	55.3	50.9
		MCWB	46.3	44.4	44.6	50.5	59.3	60.4	65.0	62.7	61.2	56.0	51.8	48.8
	2%	DB	46.7	45.0	46.4	55.5	63.8	66.6	72.2	68.9	65.3	58.8	53.5	49.4
		MCWB	44.6	43.1	42.4	48.9	55.0	58.9	64.0	61.7	59.2	54.7	51.1	47.3
	5%	DB	45.6	44.0	44.6	52.5	60.4	62.8	68.3	66.9	63.1	56.9	52.1	48.3
		MCWB	43.5	42.2	41.9	47.2	53.5	57.5	62.1	60.9	58.3	53.3	49.4	46.3
	10%	DB	44.5	43.3	43.7	49.7	56.9	60.2	65.7	64.9	61.6	55.5	50.8	47.3
		MCWB	42.4	41.5	41.3	46.0	51.4	55.6	60.8	59.9	57.4	52.2	48.1	45.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	45.3	45.3	51.2	60.8	61.9	66.9	64.8	62.6	57.0	53.0	49.5
		MCDB	47.6	45.8	48.5	57.2	68.2	67.7	74.2	69.3	66.5	59.6	54.2	50.3
	2%	WB	45.1	43.8	43.6	49.1	56.8	60.0	64.7	62.9	60.6	55.5	51.6	48.0
		MCDB	46.2	44.6	45.4	52.8	62.5	65.2	70.4	66.9	63.3	57.8	53.2	49.0
	5%	WB	44.1	42.8	42.6	47.7	54.3	57.9	62.9	61.5	59.3	54.3	50.1	46.8
		MCDB	45.3	44.0	43.9	50.9	59.5	62.2	67.4	65.2	62.5	56.5	51.8	48.2
	10%	WB	42.8	41.6	41.8	46.0	52.3	56.1	61.2	60.4	57.9	52.9	48.7	45.5
		MCDB	44.3	43.0	43.2	48.4	56.5	59.5	64.9	63.8	61.0	55.2	50.5	47.1
Mean Daily Temperature Range	5% DB	MDBR	4.9	4.7	5.5	7.0	7.4	7.0	6.8	6.3	5.6	5.2	5.0	4.9
		MCDBR	6.2	4.9	6.1	11.0	13.2	11.3	11.3	8.8	7.1	5.9	5.4	5.5
		MCWBR	6.6	4.8	4.6	6.2	7.0	5.6	5.8	5.2	5.0	5.0	5.7	6.2
	5% WB	MCDBR	5.8	4.9	5.6	9.1	12.4	10.0	10.3	7.6	6.5	5.7	5.5	5.6
		MCWBR	6.6	5.0	4.6	5.7	7.2	5.9	5.7	5.6	5.6	5.7	6.4	6.5
Clear-Sky Solar Irradiance	taub	0.308	0.331	0.351	0.381	0.368	0.363	0.377	0.377	0.359	0.339	0.311	0.285	
	taud	2.179	2.287	2.337	2.307	2.419	2.465	2.445	2.442	2.477	2.416	2.253	2.120	
	Ebn at Noon	153	215	249	260	274	277	269	260	246	212	152	116	
	Edh at Noon	15	22	28	34	33	32	32	30	25	20	14	11	
All-Sky Solar Radiation	RadAvg	90	275	657	1202	1650	1766	1559	1203	770	370	127	57	
	RadStd	13	44	77	108	174	202	148	105	66	43	16	7	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	-209	N/A	N/A

Nomenclature: See separate page