

EIK HOVE, Norway

WMO: 014250

Lat: 58.508N

Lon: 6.511E

Elev: 66

StdP: 100.53

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.8	-11.2	-16.8	0.9	-13.7	-13.8	1.1	-9.2	9.3	3.8	8.3	4.2	1.0	350	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.1	17.4	23.1	16.6	21.1	15.6	18.5	23.2	17.5	21.5	16.5	19.9	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.8	12.0	19.9	15.8	11.3	18.7	15.0	10.8	17.9	52.5	23.2	49.3	21.5	46.4	20.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.7	6.5	5.5	DB	-17.1	27.8	3.9	1.4	-19.9	28.7	-22.2	29.5	-24.4	30.3	-27.2	31.3	(4)
(5)			WB	-17.3	20.0	3.9	1.1	-20.1	20.9	-22.4	21.5	-24.5	22.2	-27.3	23.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.9	-0.1	-0.4	1.8	5.7	9.6	12.8	15.1	14.5	11.8	7.2	3.4	0.7	(6)
(7)		DBStd	6.57	4.60	4.36	3.58	2.97	3.33	2.53	2.58	2.41	2.52	3.22	3.65	4.82	(7)
(8)		HDD10.0	1637	314	292	253	132	48	4	0	1	11	96	197	289	(8)
(9)		HDD18.3	4184	572	526	511	378	271	167	104	121	195	344	447	548	(9)
(10)		CDD10.0	502	0	0	0	4	36	88	159	140	66	9	1	0	(10)
(11)		CDD18.3	9	0	0	0	0	1	1	6	2	0	0	0	0	(11)
(12)		CDH23.3	143	0	0	0	0	12	21	83	26	1	0	0	0	(12)
(13)		CDH26.7	11	0	0	0	0	1	1	8	1	0	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.4	2.3	2.3	2.3	2.5	2.5	2.2	2.0	2.1	2.2	2.2	(14)	
(15)	Precipitation	PrecAvg	2410	304	215	179	126	111	117	141	185	195	276	264	298	(15)
(16)		PrecMax	3291	567	534	419	216	222	215	316	299	404	551	577	654	(16)
(17)		PrecMin	1357	19	13	28	61	15	16	32	34	44	30	68	7	(17)
(18)		PrecStd	434	145	136	100	43	59	54	64	62	85	136	133	177	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	8.9	14.1	18.9	25.3	25.7	27.7	26.1	21.8	15.6	12.0	10.0	(19)
(20)			MCWB	7.5	7.0	7.8	11.6	16.3	16.6	18.9	18.2	16.9	12.8	10.6	8.7	(20)
(21)		2%	DB	7.6	7.1	9.8	16.4	21.6	23.2	25.8	23.5	18.9	14.0	10.9	9.0	(21)
(22)			MCWB	6.4	5.7	6.6	10.1	13.7	15.8	18.2	17.5	15.0	12.0	9.7	8.1	(22)
(23)		5%	DB	6.5	6.1	8.0	13.6	19.2	20.9	23.6	21.2	17.5	13.0	9.8	8.1	(23)
(24)			MCWB	5.4	4.9	5.4	8.5	12.6	14.5	17.4	16.4	14.3	11.5	8.7	7.1	(24)
(25)		10%	DB	5.5	5.1	6.7	11.4	16.7	18.8	21.4	19.5	16.2	12.0	8.8	7.0	(25)
(26)			MCWB	4.5	4.0	4.8	7.5	11.7	13.7	16.5	15.5	13.6	10.8	7.8	5.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	7.6	8.6	13.1	16.9	17.9	20.2	19.2	17.6	13.7	11.1	9.1	(27)
(28)			MCD B	8.8	8.3	11.9	16.6	24.0	23.2	25.7	23.9	20.0	14.6	11.7	9.6	(28)
(29)		2%	WB	6.6	6.1	7.1	10.6	14.7	16.5	19.0	18.1	16.1	12.6	9.9	8.2	(29)
(30)			MCD B	7.5	6.7	9.5	14.7	19.7	21.1	24.1	21.9	18.2	13.4	10.7	8.9	(30)
(31)		5%	WB	5.6	5.2	6.0	9.2	13.3	15.3	18.0	17.1	15.0	11.9	8.9	7.2	(31)
(32)			MCD B	6.4	5.9	7.5	12.7	17.9	19.4	22.5	20.2	16.7	12.7	9.6	8.0	(32)
(33)		10%	WB	4.6	4.1	5.0	8.0	12.1	14.2	16.9	16.1	14.1	11.0	8.0	6.0	(33)
(34)			MCD B	5.4	5.0	6.4	10.7	16.2	17.9	20.7	18.5	15.8	11.9	8.8	6.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	5.9	7.3	8.6	10.0	9.5	9.1	8.6	7.4	6.5	5.4	5.1	(35)
(36)			MCD BR	5.7	5.8	9.9	13.8	15.3	14.6	14.2	11.7	9.9	7.2	5.8	5.4	(36)
(37)			MCWBR	5.1	4.5	6.6	8.2	8.4	7.9	7.9	6.5	6.2	5.1	5.3	4.9	(37)
(38)		5% WB	MCD BR	5.5	5.0	8.5	11.9	13.4	12.3	12.7	10.1	7.8	5.0	5.7	5.5	(38)
(39)			MCWBR	5.1	4.4	6.2	7.4	7.8	7.2	7.5	6.0	5.5	4.3	5.3	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.320	0.343	0.378	0.369	0.360	0.375	0.376	0.354	0.336	0.305	0.274	(40)	
(41)		taud	2.188	2.267	2.310	2.301	2.390	2.437	2.413	2.407	2.467	2.420	2.282	2.148	(41)	
(42)		Ebn at Noon	521	700	796	827	863	876	852	823	785	683	513	414	(42)	
(43)		Edh at Noon	48	72	92	109	107	104	104	98	79	63	44	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.34	0.96	2.27	3.71	4.93	5.58	4.94	3.75	2.43	1.18	0.46	0.23	(44)	
(45)		RadStd	0.07	0.20	0.27	0.43	0.66	0.55	0.60	0.32	0.28	0.21	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-122	N/A	N/A

Nomenclature: See separate page