

EIGEROYA, Norway

WMO: 014260

Lat: 58.4352N

Lon: 5.8718E

Elev: 49

StdP: 100.74

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.9	-4.5	N/A	N/A	N/A	N/A	N/A	N/A	23.2	3.1	21.4	3.7	5.7	50	0.896

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.3	20.9	N/A	19.3	N/A	18.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.8	18.3	16.5	-6.3	24.5	2.6	2.1	-8.2	26.1	-9.7	27.3	-11.2	28.5	-13.0	30.1		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	2.6	2.3	3.5	6.4	9.8	12.1	14.4	15.2	13.3	9.6	6.2	4.2
	DBStd	5.27	2.99	3.04	2.50	2.66	3.42	2.10	2.46	1.75	2.06	2.29	3.23	3.47
	HDD10.0	1141	229	217	201	116	44	4	0	0	1	33	117	179
	HDD18.3	3656	488	450	459	359	264	186	127	98	152	269	365	437
	CDD10.0	535	0	0	0	6	39	68	135	163	101	22	2	0
	CDD18.3	7	0	0	0	0	1	0	4	2	1	0	0	0
	CDH23.3	12	0	0	0	0	2	0	9	0	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	8.0	9.8	9.0	7.7	7.2	7.4	7.2	6.9	7.0	7.8	8.5	8.2	9.7
Precipitation	PrecAvg	1487	135	96	112	76	83	83	102	131	166	182	182	146
	PrecMax	2080	349	262	234	180	210	171	299	267	286	306	318	272
	PrecMin	1132	8	0	2	2	2	14	22	6	50	62	62	10
	PrecStd	230	75	60	65	37	49	33	61	74	58	72	69	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	7.5	9.0	16.1	22.0	20.1	24.6	21.6	20.3	15.3	12.4	10.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	7.7	6.7	7.5	13.9	19.3	17.9	21.4	20.1	18.2	14.2	11.5	9.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	7.2	6.3	6.7	12.0	17.0	16.3	19.2	18.7	17.0	13.3	10.8	8.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	6.7	5.9	6.3	10.2	14.9	15.2	17.8	17.8	16.1	12.6	10.1	8.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	3.0	2.9	3.0	3.9	3.8	3.5	3.4	3.3	3.3	3.0	3.1	
		MCDBR	3.5	2.7	3.1	6.1	7.0	5.6	5.6	4.2	4.0	3.4	2.8	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.311	0.333	0.352	0.383	0.370	0.363	0.377	0.380	0.361	0.342	0.315	0.289	
	taud	2.180	2.273	2.323	2.298	2.402	2.449	2.429	2.419	2.461	2.397	2.254	2.139	
	Ebn at Noon	498	684	788	822	863	874	851	820	778	674	495	394	
	Edh at Noon	50	73	91	110	106	103	103	97	80	64	46	37	
All-Sky Solar Radiation	RadAvg	0.32	0.94	2.21	3.83	5.17	5.64	5.05	3.89	2.51	1.20	0.44	0.21	
	RadStd	0.05	0.16	0.22	0.38	0.57	0.58	0.53	0.31	0.24	0.15	0.07	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	-122	N/A	N/A

Nomenclature: See separate page