

OKSOY FYR, Norway

WMO: 014480

Lat: 58.073N

Lon: 8.053E

Elev: 26

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.4	21.0	10.3	9.3	22.1	13.7	11.0	25.2	39.3	34.3	36.4	32.6	15.1	0	0.757

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	72.3	64.8	70.1	63.3	68.1	61.9	66.4	70.7	64.5	68.8	62.9	66.8	13.1	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	90.9	69.7	62.6	84.9	67.2	61.0	80.3	65.6	31.0	70.8	29.6	69.0	28.4	66.9	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.5	31.7	28.4	DB	14.8	74.6	4.5	2.9	11.5	76.7	8.9	78.4	6.4	80.1	3.1	82.2	(4)
(5)			WB	13.6	67.6	4.2	2.3	10.6	69.3	8.1	70.6	5.8	71.8	2.8	73.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	35.0	34.3	37.1	42.8	50.2	56.8	61.7	61.9	56.4	49.1	42.2	37.2	(6)	
	DBStd	11.15	6.48	6.49	5.14	4.22	4.71	3.90	3.70	3.66	3.52	4.65	5.87	7.35	(7)	
	HDD50	2284	465	438	399	220	53	1	0	0	2	72	238	396	(8)	
	HDD65	6550	930	858	864	667	460	248	116	111	258	493	684	861	(9)	
	CDD50	1243	0	0	0	4	59	205	363	370	194	44	4	0	(10)	
	CDD65	33	0	0	0	0	0	2	15	16	0	0	0	0	(11)	
	CDH74	16	0	0	0	0	0	1	7	8	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	14.2	16.7	15.1	14.6	13.1	13.0	12.0	12.3	12.4	14.2	15.3	15.9	15.7	(14)	
	PrecAvg	54.4	6.0	3.9	3.1	2.8	3.0	3.3	3.3	5.0	5.4	6.5	6.5	5.4	(15)	
(16) Precipitation	PrecMax	76.4	16.1	11.3	6.0	7.1	6.9	8.1	8.7	10.0	11.8	12.5	17.4	11.5	(16)	
	PrecMin	30.6	1.0	0.5	0.4	0.4	0.2	0.1	0.1	0.4	1.4	2.2	1.6	1.3	(17)	
	PrecStd	10.9	3.2	2.5	1.5	1.6	1.7	2.0	2.0	2.3	2.6	2.8	3.5	2.6	(18)	
	PrecStd	10.9	3.2	2.5	1.5	1.6	1.7	2.0	2.0	2.3	2.6	2.8	3.5	2.6	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	47.7	51.8	57.4	68.6	71.7	74.9	75.2	66.9	59.6	54.8	50.8	(19)	
		MCWB	45.2	44.0	44.7	50.3	60.1	60.9	66.5	67.6	59.8	55.6	52.1	48.6	(20)	
	2%	DB	46.3	45.4	47.0	53.8	63.6	68.6	72.5	72.6	64.6	57.8	53.2	49.4	(21)	
		MCWB	43.8	42.7	41.4	47.4	55.8	59.7	64.9	65.6	59.2	54.8	50.9	47.3	(22)	
	5%	DB	44.9	44.1	44.9	51.3	60.2	65.7	70.2	70.4	63.1	56.6	51.6	48.2	(23)	
		MCWB	42.9	42.1	40.8	45.6	53.9	58.2	63.5	64.2	58.8	54.0	49.3	46.1	(24)	
	10%	DB	43.7	42.7	43.2	49.0	57.4	63.2	68.2	68.2	62.0	55.5	50.2	46.8	(25)	
		MCWB	41.8	41.1	40.4	44.2	52.0	56.9	62.1	62.7	58.1	53.0	48.1	44.6	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	45.4	45.6	52.2	60.4	63.5	68.4	69.2	63.2	57.3	53.1	49.4	(27)	
		MCDB	47.3	46.5	49.8	55.9	67.1	69.3	73.3	73.3	64.6	58.5	54.2	50.2	(28)	
	2%	WB	44.4	43.9	43.2	48.4	56.9	61.0	66.1	67.2	61.3	55.9	51.3	47.8	(29)	
		MCDB	45.6	44.8	45.3	52.3	61.6	66.0	70.7	71.4	63.2	57.1	52.7	48.9	(30)	
	5%	WB	43.3	42.4	42.1	46.7	54.7	59.4	64.5	65.2	60.0	54.8	49.7	46.4	(31)	
		MCDB	44.5	43.5	43.9	49.9	58.8	64.1	69.2	69.2	62.1	56.1	51.1	47.8	(32)	
	10%	WB	42.1	41.1	41.0	45.2	52.6	58.0	62.9	63.5	58.8	53.6	48.4	44.9	(33)	
		MCDB	43.5	42.5	42.8	47.9	56.2	62.1	67.2	67.3	61.1	55.1	49.9	46.5	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.4	7.0	7.7	8.1	8.4	8.2	8.1	7.2	6.5	6.2	6.2	(35)	
		MCDBR	6.7	6.5	9.2	10.5	11.5	11.7	10.8	10.2	8.5	6.3	6.6	5.8	(36)	
		MCWBR	6.9	5.8	6.5	6.8	7.1	7.5	7.0	6.9	6.4	5.7	7.4	6.5	(37)	
	5% WB	MCDBR	6.2	5.5	7.6	8.5	9.8	9.5	9.2	9.1	6.7	5.7	6.5	5.9	(38)	
		MCWBR	6.7	5.7	6.1	5.9	6.9	7.0	6.6	6.8	6.1	6.1	7.3	6.7	(39)	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)				
(40) Clear-Sky Solar Irradiance	taub		0.301	0.327	0.344	0.386	0.375	0.362	0.380	0.382	0.360	0.338	0.310	0.279	(40)	
	taud		2.240	2.320	2.366	2.299	2.406	2.468	2.435	2.425	2.475	2.443	2.301	2.193	(41)	
	Ebn at Noon		170	223	255	260	272	278	270	260	248	219	166	139	(42)	
	Edh at Noon		15	23	28	35	34	32	32	31	25	20	14	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		108	290	732	1238	1672	1880	1711	1316	854	400	147	75	(44)	
	RadStd		23	60	70	149	185	152	170	93	91	60	33	10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-216	-290	N/A	N/A

Nomenclature: See separate page