

AURSKOG, Norway

WMO: 014840

Lat: 59.9119N

Lon: 11.5800E

Elev: 128

StdP: 99.80

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.2	-19.3	-25.6	0.4	-23.3	-21.4	0.6	-19.3	9.4	2.1	8.4	2.2	1.5	0	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	26.8	16.5	24.8	16.1	22.7	15.2	18.2	23.7	17.2	22.4	16.3	20.8	2.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	11.7	19.9	15.3	11.0	18.7	14.4	10.4	17.9	51.8	23.8	48.8	22.3	46.0	21.1	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	7.1	6.2	-25.7	28.9	3.8	2.5	-28.5	30.7	-30.7	32.1	-32.9	33.5	-35.6	35.3		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-25.9	19.5	3.8	1.2	-28.6	20.4	-30.9	21.1	-33.0	21.8	-35.8	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-5.7	-4.6	-0.6	4.7	10.0	13.3	15.8	14.2	10.7	5.2	0.8	-2.9
	DBStd	8.51	6.48	5.91	4.69	3.45	4.21	2.80	2.70	2.30	3.36	3.70	4.61	5.65
	HDD10.0	2306	486	408	328	162	54	4	1	1	32	156	276	399
	HDD18.3	4829	744	641	586	408	260	154	87	128	230	408	526	658
	CDD10.0	529	0	0	0	4	53	102	180	132	52	6	0	0
	CDD18.3	12	0	0	0	0	1	2	8	1	0	0	0	0
	CDH23.3	335	0	0	0	0	41	76	196	22	1	0	0	0
	CDH26.7	57	0	0	0	0	3	11	44	0	0	0	0	0
Wind	WSAvg	2.6	2.5	2.5	2.7	2.7	2.9	2.9	2.6	2.5	2.7	2.6	2.6	2.6
Precipitation	PrecAvg	770	56	39	36	42	52	77	83	89	76	80	77	60
	PrecMax	1051	137	92	111	79	90	139	179	159	166	208	211	119
	PrecMin	570	5	11	0	5	7	19	9	25	24	22	18	12
	PrecStd	121	33	22	24	21	26	31	40	35	33	41	48	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.1	6.6	15.1	19.7	26.8	28.0	30.2	25.7	22.0	15.8	11.1	9.0
		MCWB	4.8	3.8	7.9	10.7	14.6	16.1	18.0	16.6	15.6	12.5	9.9	7.7
	2%	DB	4.6	4.8	10.6	18.0	24.2	25.7	27.9	23.5	20.2	13.7	9.4	7.4
		MCWB	3.6	3.2	5.6	10.2	14.2	15.5	17.7	15.9	14.0	11.1	8.2	6.2
	5%	DB	3.4	3.6	7.5	15.2	21.5	22.7	25.5	21.6	18.2	12.7	8.2	5.9
		MCWB	2.5	2.6	3.7	8.7	13.2	14.4	17.2	15.1	13.3	10.7	7.1	4.8
	10%	DB	2.1	2.7	5.7	12.5	19.0	20.5	23.4	19.9	16.7	11.3	7.1	4.4
		MCWB	1.2	1.8	3.1	7.2	12.5	13.2	16.4	14.6	13.0	9.5	6.1	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.2	4.9	8.8	12.1	17.0	17.6	20.1	18.6	16.9	13.2	10.2	8.1
		MCDB	6.0	5.5	14.6	17.9	22.0	23.8	25.3	21.3	20.3	15.1	11.1	8.9
	2%	WB	3.7	3.5	6.0	10.7	15.6	16.4	18.9	17.4	15.3	12.0	8.5	6.4
		MCDB	4.3	4.4	9.7	16.7	21.5	23.0	25.3	21.1	17.9	13.2	9.3	7.3
	5%	WB	2.6	2.7	4.6	9.2	14.1	15.3	17.9	16.4	14.3	10.9	7.3	5.0
		MCDB	3.4	3.5	6.7	14.1	19.8	21.3	24.0	19.9	17.2	12.2	8.1	5.7
	10%	WB	1.3	1.8	3.4	7.7	12.8	14.2	16.9	15.5	13.4	9.7	6.2	3.6
		MCDB	2.0	2.6	5.4	12.0	18.0	19.2	22.1	18.5	16.1	11.2	7.1	4.3
Mean Daily Temperature Range	MDBR		6.7	7.9	10.1	11.7	11.8	11.7	12.0	10.7	10.6	7.9	5.4	6.2
	5% DB	MCDBR	5.7	7.3	12.7	16.7	17.1	17.2	17.3	14.4	12.9	8.9	6.5	6.5
		MCWBR	5.2	5.9	8.2	9.8	8.5	8.3	8.4	7.9	8.0	6.6	5.9	6.0
	5% WB	MCDBR	5.3	5.9	11.1	15.1	13.5	14.0	15.0	11.0	9.9	7.2	6.2	6.1
		MCWBR	4.9	4.9	7.5	9.1	7.1	7.5	8.0	6.6	6.6	6.1	5.8	5.8
Clear-Sky Solar Irradiance	taub		0.262	0.303	0.327	0.368	0.365	0.355	0.376	0.368	0.336	0.324	0.281	0.236
	taud		2.213	2.296	2.352	2.331	2.406	2.456	2.416	2.433	2.512	2.454	2.291	2.127
	Ebn at Noon		527	703	806	830	863	878	847	824	797	679	501	403
	Edh at Noon		41	66	85	104	104	101	103	94	74	57	38	29
All-Sky Solar Radiation	RadAvg		0.29	0.89	2.38	3.77	4.90	5.61	5.01	3.94	2.62	1.16	0.38	0.19
	RadStd		0.05	0.16	0.26	0.51	0.50	0.41	0.65	0.32	0.30	0.22	0.10	0.02

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (58 neighbors)	N/A	N/A	+1.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page