

STATFJORD B OIL PLATFORM, Norway

WMO: 014881

Lat: 61.206N

Lon: 1.829E

Elev: 466

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.3	33.9	17.2	13.3	35.9	19.5	14.9	36.5	84.0	42.3	77.3	42.2	23.7	320	1.161

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	64.7	58.9	61.2	57.6	60.4	57.2	60.2	63.9	59.0	61.2	57.7	59.7	22.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.0	75.8	61.4	57.5	71.8	59.6	57.0	70.5	59.1	26.9	63.3	25.9	61.3	25.1	59.2	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
61.7	54.5	49.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	25.9	61.7	2.8	2.0	23.9	63.1	22.2	64.2	20.6	65.3	18.6	66.8
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	41.6	41.5	42.0	44.0	47.5	51.3	55.6	56.6	53.6	49.8	45.7	42.6
	DBStd	6.42	3.41	3.22	3.56	3.79	4.00	2.76	3.96	2.44	3.02	3.14	3.77	4.29
	HDD50	1452	261	238	248	184	96	16	0	0	5	40	133	231
	HDD65	6323	726	658	713	631	544	411	294	260	341	471	578	696
	CDD50	609	0	0	0	3	18	55	175	205	114	34	5	0
	CDD65	3	0	0	0	0	0	0	3	0	0	0	0	0
	CDH74	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	25.3	30.4	30.6	26.4	23.0	21.4	20.7	19.3	20.7	24.8	27.1	28.3	31.3
Precipitation	PrecAvg	52.8	6.3	5.2	5.0	2.8	1.9	2.6	3.2	3.9	4.6	5.6	5.5	6.1
	PrecMax	65.0	9.9	10.1	9.3	4.8	3.3	5.2	6.0	6.4	7.5	8.5	8.7	9.4
	PrecMin	37.6	3.0	2.3	1.8	1.0	0.9	1.0	1.6	2.6	1.9	2.3	1.7	2.6
	PrecStd	6.5	1.9	2.1	1.8	0.9	0.6	0.9	0.9	1.0	1.3	1.6	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.6	48.5	48.6	55.2	62.4	60.7	72.0	66.2	62.4	57.6	53.8	51.5
		MCWB	47.6	47.5	46.6	47.4	55.4	56.0	61.7	58.3	58.8	53.3	50.9	49.7
	2%	DB	48.4	48.1	48.4	51.9	57.2	57.4	67.9	62.8	60.6	55.6	52.2	50.2
		MCWB	47.4	47.2	46.6	47.2	50.9	53.6	61.5	57.7	56.5	52.1	49.7	49.1
	5%	DB	48.0	46.7	47.9	49.9	53.8	55.7	64.0	60.9	59.0	54.0	51.8	49.6
		MCWB	47.0	45.4	46.1	46.6	49.2	52.7	59.5	57.5	56.0	51.0	49.5	48.6
	10%	DB	46.6	46.3	46.5	48.4	51.9	55.0	60.7	59.4	57.4	53.7	50.4	48.3
		MCWB	45.0	44.9	44.5	45.9	48.9	52.3	58.1	56.6	55.1	50.7	48.3	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	47.8	47.8	49.5	55.7	56.8	63.7	60.2	59.3	55.1	52.2	50.3
		MCDB	48.6	47.9	48.1	50.6	60.8	59.1	68.9	63.4	61.6	56.3	53.1	50.5
	2%	WB	47.7	46.8	47.0	48.3	52.6	54.7	61.6	59.3	57.7	53.7	51.2	49.4
		MCDB	47.9	47.0	47.5	49.7	56.0	56.7	67.1	61.6	59.3	55.0	52.2	49.7
	5%	WB	46.5	45.8	46.2	47.2	50.8	53.7	59.9	58.5	56.8	52.6	50.2	48.3
		MCDB	47.1	46.3	46.9	48.6	52.6	55.4	63.5	60.5	58.3	54.1	51.2	48.7
	10%	WB	45.0	44.5	44.7	46.2	49.7	52.9	58.5	57.6	55.7	51.7	49.2	47.1
		MCDB	46.1	45.5	45.7	47.6	51.0	54.7	60.7	59.6	57.5	53.3	50.4	48.0
Mean Daily Temperature Range	5% DB	MDBR	4.8	4.5	4.8	5.0	5.4	4.4	5.0	4.8	4.2	4.3	4.4	5.1
		MCDBR	4.5	4.6	4.8	6.0	8.5	6.2	8.7	6.4	5.2	4.6	4.6	5.2
		MCWBR	5.6	6.2	5.8	4.6	5.6	4.3	5.0	4.9	4.2	4.8	5.3	6.9
	5% WB	MCDBR	4.3	4.4	4.7	4.7	7.6	5.5	7.5	5.6	4.8	4.6	4.1	4.9
		MCWBR	6.0	6.3	6.7	4.6	5.4	4.3	4.7	4.8	4.5	5.6	5.3	7.3
Clear-Sky Solar Irradiance	taub	0.323	0.347	0.360	0.373	0.362	0.354	0.372	0.362	0.357	0.338	0.309	0.385	
	taud	2.065	2.202	2.290	2.328	2.429	2.487	2.453	2.479	2.450	2.324	2.129	2.351	
	Ebn at Noon	113	192	238	259	273	278	268	262	240	196	118	71	
	Edh at Noon	14	22	28	33	32	31	31	28	24	19	12	9	
All-Sky Solar Radiation	RadAvg	60	214	573	1121	1567	1608	1455	1154	699	326	94	37	
	RadStd	8	28	68	98	110	177	126	105	56	42	12	3	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (22 neighbors)		N/A	+1.24	N/A	N/A	N/A	N/A	-178	-256	N/A	N/A	

Nomenclature: See separate page